

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: CORELITE

Report Number: P854226

Luminaire Tested: SQ2-PR1-125U-100D-930-UNV-STD-W-4

Issue Date: 7/12/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P854226  
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2104-222-13, G2-2308-131-9)  
Test Lab: INNOVATION CENTER  
Issue Date: 7/12/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: CORELITE  
Catalog Number: SQ2-PR1-125U-100D-930-UNV-STD-W-4  
Description: CORELITE SQ2 SUSPENDED LED LUMINAIRE  
DOWNLIGHT 1000 LUMENS PER FOOT  
UPLIGHT 1250 LUMENS PER FOOT  
Light Source: -  
Ballast/Driver: -


**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 9183.5 lumens  
Efficiency: N/A  
Efficacy: 112.7 lumens/watt  
Spacing Criteria (0/90/45): 1.28 / 1.34 / 1.36  
Luminous Opening: Rectangular (W 0.17' x L: 4' x H: 0')  
CIE Type: General Diffuse  
  
Input Watts (W): 81.5  
Input Voltage (V): 120  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P854226

CATALOG NUMBER: SQ2-PR1-125U-100D-930-UNV-STD-W-4

### Luminous Intensity Polar Plot





TEST NUMBER: P854226

CATALOG NUMBER: SQ2-PR1-125U-100D-930-UNV-STD-W-4

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	107	107	107	107	98	98	98	98	82	82	82	68	68	68	54	54	54	48
1	98	94	90	87	90	87	83	81	73	71	69	60	59	58	49	48	47	42
2	90	83	77	72	82	76	71	67	65	61	58	54	51	49	44	42	40	36
3	82	73	66	61	75	68	62	57	57	53	49	48	45	42	39	37	35	31
4	75	65	57	52	69	60	54	49	51	46	42	43	39	36	35	33	31	27
5	69	58	50	45	64	54	47	42	46	41	37	39	35	32	32	29	27	24
6	64	52	44	39	59	49	42	37	42	36	32	35	31	28	29	26	24	21
7	59	47	40	34	54	44	37	32	38	33	29	32	28	25	27	24	21	19
8	55	43	35	30	51	40	33	29	35	29	25	29	25	22	25	22	19	17
9	51	39	32	27	47	37	30	26	32	27	23	27	23	20	23	20	17	15
10	48	36	29	24	44	34	27	23	29	24	21	25	21	18	21	18	16	14

**AVERAGE LUMINANCE (cd/sqm):**

	0°	45°	90°
0°	29547	29547	29547
5°	29509	29691	30054
10°	29819	30585	31044
15°	29810	29966	30215
20°	29328	29776	30771
25°	29245	30077	32037
30°	29215	30745	32345
35°	28937	31401	30114
40°	28270	30235	26500
45°	26750	26537	20957
50°	24320	21695	16259
55°	21371	17855	12656
60°	18493	14276	10421
65°	15966	11832	9123
70°	14356	10480	8101
75°	13150	9077	7448
80°	11446	7280	7280
85°	8299	6558	3464

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 22.5°  
 Vertical Angle: 45°  
 Luminance: 28917 cd/sqm



TEST NUMBER: P854226

CATALOG NUMBER: SQ2-PR1-125U-100D-930-UNV-STD-W-4

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	176.7	1.9
10°-20°	511.6	5.6
20°-30°	790.8	8.6
30°-40°	951.2	10.4
40°-50°	854.1	9.3
50°-60°	572.2	6.2
60°-70°	332.8	3.6
70°-80°	170.9	1.9
80°-90°	43.0	0.5
90°-100°	296.4	3.2
100°-110°	964.9	10.5
110°-120°	954.5	10.4
120°-130°	780.0	8.5
130°-140°	637.5	6.9
140°-150°	496.5	5.4
150°-160°	357.9	3.9
160°-170°	218.8	2.4
170°-180°	73.8	0.8
0°-30°	1479.1	16.1
0°-40°	2430.3	26.5
0°-60°	3856.5	42.0
0°-90°	4403.2	47.9
90°-120°	2215.8	24.1
90°-150°	4129.8	45.0
90°-180°	4780.0	52.0
0°-180°	9183.5	100.0

**CANDELA DISTRIBUTION:**

	0°	22.5°	45°	67.5°	90°	Flux
0°	1830	1830	1830	1830	1830	
5°	1821	1852	1832	1836	1854	174
15°	1783	1856	1793	1798	1808	501
25°	1642	1707	1688	1751	1798	757
35°	1468	1481	1593	1562	1528	915
45°	1172	1266	1162	980	918	896
55°	759	788	634	490	450	682
65°	418	427	310	252	239	423
75°	211	205	146	123	119	224
85°	45	36	35	24	19	55
90°	0	3	7	6	6	4
95°	40	122	543	194	119	47
105°	164	237	956	1826	1729	175
115°	303	362	779	1605	1888	300
125°	421	470	768	1267	1493	375
135°	509	562	764	1093	1233	393
145°	595	638	762	942	1031	372
155°	678	701	767	843	875	313
165°	740	747	769	798	807	209
175°	772	772	772	778	776	73
180°	775	775	775	775	775	



TEST NUMBER: P854226

CATALOG NUMBER: SQ2-PR1-125U-100D-930-UNV-STD-W-4

**CANDELA DISTRIBUTION (FULL):**

	0°	22.5°	45°	67.5°	90°
0°	1830.0	1830.0	1830.0	1830.0	1830.0
2.5°	1822.6	1844.5	1824.1	1825.6	1830.0
5°	1820.7	1851.7	1831.9	1836.0	1854.3
7.5°	1820.3	1864.5	1855.0	1866.4	1890.5
10°	1818.8	1871.7	1865.5	1867.9	1893.5
12.5°	1809.9	1871.5	1843.1	1840.8	1854.7
15°	1783.4	1856.3	1792.7	1798.5	1807.6
17.5°	1736.8	1813.0	1752.4	1773.0	1790.9
20°	1706.9	1781.7	1733.0	1759.8	1790.9
22.5°	1680.0	1754.8	1715.1	1752.6	1795.3
25°	1641.6	1707.3	1688.3	1750.9	1798.3
27.5°	1601.3	1640.0	1662.5	1746.5	1779.7
30°	1567.0	1592.5	1649.1	1722.1	1734.9
32.5°	1529.7	1545.0	1631.2	1669.2	1652.8
35°	1468.1	1480.9	1593.1	1562.5	1527.8
37.5°	1395.0	1421.3	1507.7	1419.5	1379.7
40°	1341.3	1385.0	1434.5	1302.9	1257.3
42.5°	1275.6	1345.7	1337.5	1169.9	1114.1
45°	1171.5	1266.4	1162.2	979.8	917.8
47.5°	1048.8	1146.2	975.6	812.8	754.8
50°	968.2	1046.6	863.7	711.2	647.3
52.5°	886.1	942.6	768.2	615.8	557.8
55°	759.2	788.4	634.3	489.7	449.6
57.5°	642.8	661.4	518.2	395.6	366.0
60°	572.7	585.5	442.1	346.4	322.7
62.5°	508.5	518.4	380.9	304.8	286.9
65°	417.9	427.0	309.7	251.5	238.8
67.5°	345.9	350.6	254.8	209.0	197.0
70°	304.1	305.9	222.0	180.7	171.6
72.5°	266.8	264.2	190.7	156.9	150.7
75°	210.8	205.3	145.5	123.0	119.4
77.5°	157.4	151.6	102.2	94.8	94.8
80°	123.1	115.8	78.3	78.3	78.3
82.5°	91.8	81.6	60.4	60.4	58.9
85°	44.8	35.7	35.4	24.1	18.7
87.5°	11.9	12.5	5.8	5.6	5.6
90°	0.0	2.8	6.7	5.7	5.7
92.5°	13.7	49.3	157.6	52.0	40.0
95°	40.0	122.0	543.2	193.7	119.1
97.5°	75.3	158.8	921.9	561.5	342.7
100°	98.2	180.2	1064.5	949.2	615.6
102.5°	124.1	203.1	1047.0	1404.3	1067.7
105°	163.9	236.6	955.9	1825.6	1728.7
107.5°	207.0	275.4	869.3	1862.2	1964.9
110°	238.2	300.7	828.2	1816.8	2002.2



TEST NUMBER: P854226

CATALOG NUMBER: SQ2-PR1-125U-100D-930-UNV-STD-W-4

**CANDELA DISTRIBUTION (continued):**

	0°	22.5°	45°	67.5°	90°
112.5°	264.2	325.9	802.2	1734.9	1974.0
115°	303.1	361.8	778.6	1604.6	1887.9
117.5°	343.1	396.0	769.4	1485.3	1767.2
120°	365.9	418.1	767.2	1411.9	1684.9
122.5°	388.1	439.5	767.9	1348.2	1602.6
125°	421.2	469.7	768.1	1266.9	1493.3
127.5°	449.6	499.2	767.9	1206.0	1394.8
130°	467.9	518.2	767.2	1171.3	1339.9
132.5°	483.9	536.5	766.4	1139.0	1297.2
135°	508.9	562.0	764.3	1093.4	1233.2
137.5°	533.3	586.8	762.2	1047.1	1171.2
140°	550.8	602.1	761.4	1015.7	1133.1
142.5°	567.6	616.6	761.4	985.7	1090.4
145°	594.7	638.5	762.4	941.7	1031.1
147.5°	621.0	659.0	763.7	904.2	973.4
150°	638.5	672.1	765.3	881.9	940.6
152.5°	656.0	683.6	766.0	864.9	911.6
155°	678.5	700.9	767.2	843.2	874.8
157.5°	699.9	715.9	768.3	827.1	849.3
160°	712.8	725.9	769.1	817.1	834.8
162.5°	724.3	734.3	769.1	808.6	821.9
165°	740.5	747.0	769.1	797.9	807.2
167.5°	751.9	756.0	769.3	789.8	794.6
170°	759.5	761.4	770.0	784.4	786.2
172.5°	764.9	766.0	771.5	781.3	780.9
175°	771.9	771.9	771.9	777.6	775.7
177.5°	774.8	774.0	773.3	777.0	774.0
180°	774.8	774.8	774.8	774.8	774.8



TEST NUMBER: P854226

CATALOG NUMBER: SQ2-PR1-125U-100D-930-UNV-STD-W-4

**CIE UGR TABLE:**

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	18.35	19.15	19.33	20.14	21.45	15.07	15.88	16.06	16.87	18.17
	3H	19.58	20.30	20.57	21.30	22.62	16.13	16.85	17.13	17.85	19.18
	4H	20.03	20.71	21.04	21.71	23.04	16.53	17.21	17.54	18.21	19.55
	6H	20.34	20.97	21.36	21.97	23.32	16.86	17.48	17.88	18.49	19.84
	8H	20.42	21.02	21.45	22.04	23.38	16.94	17.54	17.97	18.56	19.90
	12H	20.45	21.01	21.48	22.03	23.40	16.95	17.51	17.98	18.53	19.90
4H	2H	18.42	19.10	19.43	20.10	21.44	15.64	16.31	16.65	17.32	18.65
	3H	19.89	20.45	20.91	21.48	22.83	16.90	17.46	17.92	18.49	19.84
	4H	20.48	20.99	21.51	22.02	23.39	17.40	17.91	18.43	18.94	20.31
	6H	20.93	21.37	21.97	22.42	23.78	17.83	18.27	18.87	19.32	20.69
	8H	21.06	21.47	22.10	22.51	23.89	17.95	18.37	19.00	19.41	20.79
	12H	21.11	21.48	22.17	22.54	23.92	17.97	18.34	19.03	19.40	20.79
8H	4H	20.50	20.91	21.54	21.95	23.33	17.70	18.11	18.74	19.15	20.53
	6H	21.05	21.39	22.11	22.47	23.85	18.24	18.58	19.30	19.66	21.04
	8H	21.25	21.55	22.32	22.61	24.01	18.42	18.72	19.49	19.79	21.18
	12H	21.35	21.61	22.42	22.67	24.11	18.48	18.74	19.55	19.80	21.24
12H	4H	20.46	20.83	21.52	21.88	23.27	17.72	18.09	18.77	19.14	20.53
	6H	21.03	21.33	22.11	22.40	23.80	18.30	18.59	19.37	19.66	21.06
	8H	21.24	21.51	22.32	22.57	24.01	18.50	18.76	19.57	19.82	21.26