

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: CORELITE

Report Number: P854311

Luminaire Tested: SQ2-PW1-125U-100D-935-UNV-STD-W-4

Issue Date: 7/12/2024

Test Information

Test Method: LM-79-2019
Report Number: P854311
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2104-222-13, G2-2308-131-8)
Test Lab: INNOVATION CENTER
Issue Date: 7/12/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: CORELITE
Catalog Number: SQ2-PW1-125U-100D-935-UNV-STD-W-4
Description: CORELITE SQ2 SUSPENDED LED LUMINAIRE
DOWNLIGHT 1000 LUMENS PER FOOT
UPLIGHT 1250 LUMENS PER FOOT
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 9489.8 lumens
Efficiency: N/A
Efficacy: 116.4 lumens/watt
Spacing Criteria (0/90/45): 1.27 / 1.11 / 1.22
Luminous Opening: Rectangular (W 0.17' x L: 4' x H: 0')
CIE Type: General Diffuse

Input Watts (W): 81.5
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P854311

CATALOG NUMBER: SQ2-PW1-125U-100D-935-UNV-STD-W-4

Luminous Intensity Polar Plot





TEST NUMBER: P854311

CATALOG NUMBER: SQ2-PW1-125U-100D-935-UNV-STD-W-4

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	107	107	107	107	98	98	98	98	82	82	82	67	67	67	54	54	54	48
1	98	94	90	87	90	86	83	80	73	71	68	60	59	57	49	48	47	41
2	90	82	77	72	82	76	71	67	64	61	58	53	51	49	43	42	40	35
3	82	73	66	60	75	67	61	57	57	53	49	48	44	42	39	37	35	31
4	75	65	57	52	69	60	53	48	51	46	42	43	39	36	35	33	30	27
5	69	58	50	44	64	54	47	42	46	41	37	39	35	32	32	29	27	24
6	64	52	44	39	59	49	42	37	42	36	32	35	31	28	29	26	24	21
7	59	47	40	34	54	44	37	32	38	32	29	32	28	25	27	24	21	19
8	55	43	35	30	51	40	33	29	35	29	26	29	25	22	25	22	19	17
9	51	39	32	27	47	37	30	26	32	27	23	27	23	20	23	20	17	15
10	48	36	29	24	44	34	27	23	29	24	21	25	21	18	21	18	16	14

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	32881	32881	32881
5°	32661	32913	33227
10°	32721	33103	33516
15°	32712	33329	33718
20°	32727	33292	33060
25°	32550	32584	30718
30°	32328	30700	27772
35°	32075	28251	25080
40°	31436	25754	22156
45°	30204	23162	19354
50°	28110	20705	16566
55°	25714	18291	13430
60°	23050	15910	11586
65°	20157	13708	10300
70°	16480	12179	9338
75°	12826	10524	8590
80°	9558	9019	7578
85°	6465	6836	4316

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 30204 cd/sqm



TEST NUMBER: P854311

CATALOG NUMBER: SQ2-PW1-125U-100D-935-UNV-STD-W-4

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	193.9	2.0
10°-20°	561.9	5.9
20°-30°	826.9	8.7
30°-40°	904.0	9.5
40°-50°	811.0	8.5
50°-60°	605.0	6.4
60°-70°	382.3	4.0
70°-80°	189.4	2.0
80°-90°	45.2	0.5
90°-100°	308.2	3.2
100°-110°	1003.2	10.6
110°-120°	992.4	10.5
120°-130°	811.0	8.5
130°-140°	662.8	7.0
140°-150°	516.3	5.4
150°-160°	372.1	3.9
160°-170°	227.4	2.4
170°-180°	76.7	0.8
0°-30°	1582.7	16.7
0°-40°	2486.7	26.2
0°-60°	3902.7	41.1
0°-90°	4519.6	47.6
90°-120°	2303.8	24.3
90°-150°	4293.8	45.2
90°-180°	4970.0	52.4
0°-180°	9489.8	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2036	2036	2036	2036	2036	
5°	2015	2048	2031	2033	2050	192
15°	1957	1995	1994	2008	2017	553
25°	1827	1867	1829	1753	1724	841
35°	1627	1610	1433	1308	1272	1015
45°	1323	1217	1014	887	848	1014
55°	914	826	650	509	477	816
65°	528	484	359	289	270	523
75°	206	221	169	142	138	226
85°	35	44	37	25	23	44
90°	0	3	7	6	6	3
95°	42	127	565	201	124	48
105°	170	246	994	1898	1797	182
115°	315	376	810	1668	1963	312
125°	438	488	799	1317	1553	390
135°	529	584	795	1137	1282	409
145°	618	664	793	979	1072	387
155°	706	729	798	877	910	325
165°	770	777	800	830	839	217
175°	803	803	803	808	806	76
180°	806	806	806	806	806	



TEST NUMBER: P854311

CATALOG NUMBER: SQ2-PW1-125U-100D-935-UNV-STD-W-4

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2036.5	2036.5	2036.5	2036.5	2036.5
2.5°	2022.6	2048.4	2031.9	2033.6	2038.1
5°	2015.2	2047.5	2030.7	2033.1	2050.1
7.5°	2005.1	2037.7	2025.3	2032.3	2049.0
10°	1995.8	2030.0	2019.1	2029.1	2044.3
12.5°	1983.4	2019.1	2011.3	2022.9	2038.1
15°	1957.0	1995.0	1993.9	2007.7	2017.2
17.5°	1926.4	1964.3	1962.5	1966.1	1970.6
20°	1904.7	1942.6	1937.6	1924.1	1924.1
22.5°	1873.6	1914.6	1901.9	1864.8	1852.7
25°	1827.1	1866.9	1829.0	1752.7	1724.3
27.5°	1772.8	1805.0	1728.9	1620.6	1581.1
30°	1734.0	1758.6	1646.7	1527.5	1489.6
32.5°	1693.6	1703.1	1562.9	1439.0	1398.0
35°	1627.3	1610.2	1433.3	1308.4	1272.4
37.5°	1548.9	1498.1	1308.8	1178.0	1138.1
40°	1491.5	1419.5	1221.9	1091.1	1051.2
42.5°	1427.9	1337.6	1139.7	1008.8	967.5
45°	1322.8	1216.6	1014.4	887.4	847.6
47.5°	1204.5	1099.0	897.2	774.3	740.1
50°	1119.1	1016.7	824.3	701.2	659.5
52.5°	1032.2	940.5	752.9	626.4	569.5
55°	913.5	826.3	649.8	509.4	477.1
57.5°	791.3	715.9	556.3	428.8	402.3
60°	713.8	647.4	492.7	385.4	358.8
62.5°	639.3	580.5	430.6	345.1	323.1
65°	527.6	483.9	358.8	288.6	269.6
67.5°	418.9	394.7	298.3	236.7	224.2
70°	349.1	341.5	258.0	207.3	197.8
72.5°	288.6	291.6	219.2	179.5	173.0
75°	205.6	220.8	168.7	141.5	137.7
77.5°	140.0	162.8	124.9	104.7	101.6
80°	102.8	125.6	97.0	81.5	81.5
82.5°	71.8	90.0	69.0	61.3	61.3
85°	34.9	44.4	36.9	25.2	23.3
87.5°	9.3	14.4	7.6	5.8	5.8
90°	0.0	2.9	6.9	5.9	5.9
92.5°	14.3	51.3	163.9	54.0	41.6
95°	41.6	126.9	564.8	201.4	123.9
97.5°	78.3	165.1	958.5	583.8	356.3
100°	102.1	187.3	1106.8	986.9	640.1
102.5°	129.0	211.2	1088.5	1460.1	1110.1
105°	170.4	246.0	993.8	1898.2	1797.4
107.5°	215.2	286.3	903.9	1936.2	2042.9
110°	247.7	312.6	861.0	1889.0	2081.8



TEST NUMBER: P854311

CATALOG NUMBER: SQ2-PW1-125U-100D-935-UNV-STD-W-4

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	274.7	338.8	834.1	1803.8	2052.4
115°	315.1	376.1	809.5	1668.3	1962.9
117.5°	356.7	411.7	800.0	1544.3	1837.4
120°	380.5	434.7	797.6	1468.0	1751.8
122.5°	403.5	457.0	798.4	1401.7	1666.2
125°	438.0	488.3	798.6	1317.2	1552.7
127.5°	467.5	519.0	798.4	1253.9	1450.2
130°	486.5	538.8	797.6	1217.8	1393.1
132.5°	503.2	557.8	796.8	1184.2	1348.7
135°	529.1	584.3	794.7	1136.8	1282.2
137.5°	554.5	610.1	792.5	1088.7	1217.8
140°	572.7	626.0	791.7	1056.0	1178.1
142.5°	590.1	641.1	791.7	1024.8	1133.7
145°	618.3	663.8	792.7	979.1	1072.1
147.5°	645.6	685.2	794.1	940.2	1012.1
150°	663.9	698.7	795.7	916.9	978.0
152.5°	682.1	710.8	796.4	899.2	947.8
155°	705.5	728.7	797.6	876.7	909.6
157.5°	727.7	744.3	798.8	860.0	883.0
160°	741.2	754.7	799.6	849.6	868.0
162.5°	753.0	763.5	799.6	840.7	854.5
165°	769.9	776.7	799.6	829.6	839.2
167.5°	781.8	786.0	799.8	821.1	826.2
170°	789.7	791.6	800.6	815.5	817.4
172.5°	795.3	796.4	802.2	812.3	811.9
175°	802.6	802.6	802.6	808.5	806.5
177.5°	805.6	804.8	804.0	807.9	804.8
180°	805.6	805.6	805.6	805.6	805.6

TEST NUMBER: P854311

CATALOG NUMBER: SQ2-PW1-125U-100D-935-UNV-STD-W-4

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	18.96	19.77	19.95	20.76	22.07	15.45	16.25	16.44	17.25	18.56
	3H	20.28	21.00	21.28	22.00	23.33	16.65	17.37	17.65	18.37	19.70
	4H	20.65	21.33	21.66	22.34	23.68	17.10	17.78	18.10	18.78	20.12
	6H	20.85	21.48	21.87	22.49	23.84	17.41	18.04	18.43	19.04	20.39
	8H	20.88	21.48	21.91	22.51	23.85	17.48	18.08	18.51	19.10	20.45
	12H	20.88	21.44	21.91	22.46	23.83	17.49	18.06	18.52	19.08	20.45
4H	2H	19.06	19.74	20.08	20.74	22.08	16.13	16.81	17.14	17.81	19.15
	3H	20.60	21.16	21.62	22.20	23.55	17.51	18.07	18.53	19.11	20.46
	4H	21.11	21.62	22.14	22.65	24.02	18.05	18.57	19.08	19.59	20.97
	6H	21.44	21.88	22.48	22.93	24.30	18.45	18.90	19.50	19.95	21.32
	8H	21.51	21.93	22.55	22.97	24.35	18.56	18.97	19.60	20.01	21.40
	12H	21.53	21.90	22.59	22.95	24.34	18.58	18.95	19.64	20.01	21.40
8H	4H	21.14	21.55	22.18	22.60	23.98	18.38	18.79	19.42	19.83	21.21
	6H	21.58	21.92	22.64	23.00	24.38	18.88	19.22	19.94	20.30	21.69
	8H	21.72	22.02	22.79	23.09	24.49	19.04	19.34	20.12	20.41	21.81
	12H	21.78	22.05	22.86	23.11	24.55	19.10	19.36	20.18	20.43	21.87
12H	4H	21.10	21.47	22.16	22.53	23.92	18.39	18.76	19.45	19.82	21.21
	6H	21.57	21.87	22.64	22.93	24.34	18.94	19.24	20.02	20.31	21.71
	8H	21.73	21.99	22.80	23.05	24.50	19.13	19.39	20.20	20.45	21.90