

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: CORELITE

Report Number: P855330

Luminaire Tested: SQ2-PP3-125U-125D-840-UNV-STD-W-4

Issue Date: 7/12/2024

Test Information

Test Method: LM-79-2019
Report Number: P855330
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2104-222-13, G2-2308-131-7)
Test Lab: INNOVATION CENTER
Issue Date: 7/12/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: CORELITE
Catalog Number: SQ2-PP3-125U-125D-840-UNV-STD-W-4
Description: CORELITE SQ2 SUSPENDED LED LUMINAIRE
DOWNLIGHT 1250 LUMENS PER FOOT
UPLIGHT 1250 LUMENS PER FOOT
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 12478.5 lumens
Efficiency: N/A
Efficacy: 134.0 lumens/watt
Spacing Criteria (0/90/45): 1.26 / 1.41 / 1.4
Luminous Opening: Rectangular (W 0.17' x L: 4' x H: 0')
CIE Type: General Diffuse

Input Watts (W): 93.1
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P855330
CATALOG NUMBER: SQ2-PP3-125U-125D-840-UNV-STD-W-4

Luminous Intensity Polar Plot





TEST NUMBER: P855330

CATALOG NUMBER: SQ2-PP3-125U-125D-840-UNV-STD-W-4

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	108	108	108	108	100	100	100	100	85	85	85	72	72	72	60	60	60	54
1	99	95	91	88	92	88	85	82	76	74	71	64	63	61	54	53	51	46
2	91	84	78	73	84	78	73	68	67	63	60	57	54	52	48	46	44	40
3	83	74	67	61	77	69	63	58	60	55	51	51	47	44	43	40	38	34
4	76	66	58	52	71	61	55	49	53	48	44	46	42	38	38	36	33	30
5	70	59	51	45	65	55	48	43	48	42	38	41	37	34	35	32	29	26
6	65	53	45	39	60	49	42	37	43	38	33	37	33	30	32	28	26	23
7	60	48	40	34	55	45	38	33	39	34	29	34	29	26	29	26	23	20
8	56	43	36	31	52	41	34	29	36	30	26	31	27	23	27	23	21	18
9	52	40	32	27	48	37	31	26	33	27	24	29	24	21	25	21	19	17
10	48	36	29	24	45	34	28	23	30	25	21	26	22	19	23	19	17	15

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	42988	42988	42988
5°	42652	43016	43426
10°	42868	43191	43745
15°	42765	43188	43846
20°	42459	43474	44732
25°	42218	44023	47081
30°	41978	44916	48065
35°	41384	45046	48153
40°	40278	44965	44491
45°	39075	42930	33867
50°	37540	36620	28208
55°	34939	30821	20284
60°	30083	26447	14541
65°	25379	20432	14300
70°	21125	16074	13690
75°	17904	13874	12820
80°	15184	12041	11520
85°	11986	9911	6262

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 45°
 Vertical Angle: 45°
 Luminance: 42930 cd/sqm



TEST NUMBER: P855330

CATALOG NUMBER: SQ2-PP3-125U-125D-840-UNV-STD-W-4

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	253.5	2.0
10°-20°	733.7	5.9
20°-30°	1149.5	9.2
30°-40°	1418.0	11.4
40°-50°	1335.1	10.7
50°-60°	945.3	7.6
60°-70°	538.6	4.3
70°-80°	266.5	2.1
80°-90°	66.2	0.5
90°-100°	357.9	2.9
100°-110°	1165.1	9.3
110°-120°	1152.5	9.2
120°-130°	941.8	7.5
130°-140°	769.8	6.2
140°-150°	599.6	4.8
150°-160°	432.2	3.5
160°-170°	264.1	2.1
170°-180°	89.1	0.7
0°-30°	2136.7	17.1
0°-40°	3554.7	28.5
0°-60°	5835.1	46.8
0°-90°	6706.4	53.7
90°-120°	2675.5	21.4
90°-150°	4986.7	40.0
90°-180°	5772.0	46.3
0°-180°	12478.5	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2662	2662	2662	2662	2662	
5°	2632	2678	2654	2660	2679	251
15°	2558	2594	2584	2609	2623	721
25°	2370	2430	2471	2571	2643	1092
35°	2100	2157	2285	2416	2443	1309
45°	1711	1840	1880	1593	1483	1317
55°	1241	1316	1095	825	721	1095
65°	664	700	535	377	374	667
75°	287	317	222	208	206	311
85°	65	59	54	42	34	76
90°	0	3	8	7	7	5
95°	48	147	656	234	144	56
105°	198	286	1154	2204	2088	211
115°	366	437	940	1938	2280	362
125°	509	567	928	1530	1803	453
135°	614	679	923	1320	1489	475
145°	718	771	921	1137	1245	450
155°	819	846	926	1018	1056	377
165°	894	902	929	963	975	252
175°	932	932	932	939	937	88
180°	936	936	936	936	936	



TEST NUMBER: P855330

CATALOG NUMBER: SQ2-PP3-125U-125D-840-UNV-STD-W-4

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2662.5	2662.5	2662.5	2662.5	2662.5
2.5°	2642.3	2679.7	2655.7	2660.4	2664.8
5°	2631.6	2678.3	2654.1	2660.1	2679.4
7.5°	2621.5	2669.4	2645.7	2655.7	2679.4
10°	2614.7	2655.9	2634.4	2648.8	2668.2
12.5°	2594.4	2633.5	2614.1	2633.1	2650.1
15°	2558.4	2594.2	2583.7	2609.3	2623.1
17.5°	2509.5	2552.9	2552.8	2589.1	2603.4
20°	2471.1	2523.4	2530.2	2575.9	2603.4
22.5°	2430.6	2491.7	2503.2	2571.8	2619.2
25°	2369.8	2430.3	2471.1	2571.2	2642.8
27.5°	2298.9	2358.9	2443.0	2555.1	2611.9
30°	2251.6	2309.4	2409.2	2525.8	2578.1
32.5°	2193.1	2253.1	2359.7	2485.2	2533.0
35°	2099.6	2157.4	2285.4	2415.5	2443.0
37.5°	1992.1	2057.6	2201.0	2273.6	2275.2
40°	1911.0	1996.3	2133.4	2146.7	2110.9
42.5°	1832.2	1941.8	2038.9	1979.4	1820.5
45°	1711.3	1840.5	1880.1	1593.3	1483.2
47.5°	1582.3	1710.0	1647.1	1336.2	1260.4
50°	1494.5	1615.6	1457.9	1194.5	1123.0
52.5°	1395.5	1503.4	1289.1	1058.7	949.6
55°	1241.2	1315.5	1094.9	825.1	720.6
57.5°	1055.4	1107.7	936.1	619.3	502.1
60°	931.6	972.9	819.0	508.1	450.3
62.5°	819.0	855.9	697.5	441.5	421.1
65°	664.3	700.1	534.8	377.1	374.3
67.5°	528.5	567.7	410.3	329.2	326.0
70°	447.5	488.8	340.5	295.4	290.0
72.5°	379.9	419.1	288.8	259.4	256.2
75°	287.0	317.3	222.4	208.3	205.5
77.5°	208.3	227.5	165.5	158.1	155.3
80°	163.3	171.5	129.5	126.6	123.9
82.5°	122.7	119.9	97.9	95.0	90.1
85°	64.7	59.2	53.5	42.1	33.8
87.5°	20.3	21.0	10.6	8.2	8.2
90°	0.0	3.4	8.0	6.9	6.9
92.5°	16.5	59.6	190.3	62.7	48.4
95°	48.4	147.3	655.9	233.9	143.8
97.5°	90.9	191.7	1113.2	678.0	413.8
100°	118.5	217.6	1285.3	1146.2	743.4
102.5°	149.9	245.2	1264.2	1695.7	1289.3
105°	197.9	285.6	1154.2	2204.5	2087.5
107.5°	250.0	332.5	1049.7	2248.5	2372.5
110°	287.7	363.0	1000.0	2193.8	2417.7



TEST NUMBER: P855330

CATALOG NUMBER: SQ2-PP3-125U-125D-840-UNV-STD-W-4

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	319.0	393.4	968.7	2094.9	2383.6
115°	365.9	436.8	940.1	1937.6	2279.6
117.5°	414.3	478.2	929.1	1793.4	2134.0
120°	441.9	504.9	926.4	1704.9	2034.4
122.5°	468.6	530.7	927.3	1627.9	1935.0
125°	508.6	567.1	927.5	1529.8	1803.2
127.5°	543.0	602.7	927.3	1456.3	1684.2
130°	565.0	625.8	926.4	1414.2	1617.9
132.5°	584.3	647.8	925.4	1375.3	1566.4
135°	614.5	678.6	922.9	1320.3	1489.0
137.5°	644.0	708.6	920.3	1264.3	1414.2
140°	665.1	727.0	919.4	1226.5	1368.2
142.5°	685.4	744.6	919.4	1190.2	1316.7
145°	718.0	770.9	920.6	1137.1	1245.1
147.5°	749.8	795.7	922.2	1091.9	1175.3
150°	771.0	811.5	924.0	1064.8	1135.8
152.5°	792.1	825.5	925.0	1044.3	1100.8
155°	819.3	846.3	926.4	1018.1	1056.3
157.5°	845.1	864.5	927.8	998.7	1025.6
160°	860.8	876.5	928.6	986.6	1008.1
162.5°	874.5	886.8	928.6	976.4	992.3
165°	894.1	902.0	928.6	963.4	974.6
167.5°	908.0	912.9	928.8	953.6	959.5
170°	917.2	919.4	929.8	947.1	949.3
172.5°	923.6	925.0	931.6	943.4	942.9
175°	932.1	932.1	932.1	939.0	936.7
177.5°	935.6	934.7	933.7	938.3	934.7
180°	935.6	935.6	935.6	935.6	935.6



TEST NUMBER: P855330

CATALOG NUMBER: SQ2-PP3-125U-125D-840-UNV-STD-W-4

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	20.95	21.81	21.88	22.76	23.98	17.35	18.21	18.28	19.15	20.37
	3H	22.05	22.82	22.99	23.77	25.01	18.45	19.22	19.40	20.18	21.42
	4H	22.39	23.12	23.35	24.07	25.33	18.92	19.64	19.87	20.60	21.85
	6H	22.61	23.27	23.57	24.24	25.50	19.26	19.93	20.23	20.89	22.16
	8H	22.65	23.29	23.63	24.27	25.53	19.35	19.98	20.32	20.96	22.23
	12H	22.67	23.27	23.65	24.25	25.53	19.36	19.97	20.34	20.94	22.23
4H	2H	21.06	21.79	22.02	22.74	24.00	18.06	18.79	19.03	19.75	21.00
	3H	22.37	22.97	23.34	23.96	25.23	19.31	19.91	20.29	20.90	22.17
	4H	22.84	23.39	23.83	24.37	25.66	19.87	20.42	20.85	21.40	22.69
	6H	23.18	23.65	24.18	24.66	25.95	20.31	20.78	21.30	21.79	23.08
	8H	23.27	23.71	24.27	24.71	26.02	20.43	20.87	21.43	21.87	23.17
	12H	23.31	23.71	24.32	24.72	26.03	20.46	20.86	21.47	21.87	23.18
8H	4H	22.86	23.30	23.86	24.30	25.60	20.14	20.58	21.14	21.58	22.88
	6H	23.29	23.66	24.31	24.70	26.00	20.69	21.05	21.71	22.09	23.39
	8H	23.45	23.77	24.48	24.80	26.12	20.87	21.19	21.90	22.22	23.54
	12H	23.54	23.82	24.57	24.84	26.21	20.95	21.23	21.98	22.25	23.62
12H	4H	22.82	23.22	23.83	24.23	25.54	20.15	20.55	21.16	21.56	22.87
	6H	23.28	23.60	24.31	24.63	25.95	20.74	21.06	21.77	22.09	23.41
	8H	23.45	23.74	24.48	24.76	26.12	20.95	21.23	21.98	22.25	23.62