

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: CORELITE

Report Number: P937010

Luminaire Tested: SQ4-FB-075U-050D-830-1D-UNV-STD-W-4

Issue Date: 12/17/2024

Test Information

Test Method: LM-79-2019
Report Number: P937010
REPORT IS A COMBINATION OF REPORTS P933501 AND P933786
Test Lab: INNOVATION CENTER
Issue Date: 12/17/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: CORELITE
Catalog Number: SQ4-FB-075U-050D-830-1D-UNV-STD-W-4
Description: CORELITE SQ4 SUSPENDED INDIRECT LED LUMINAIRE WITH Batwing Frosted Continuous Roll L
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4407.2 lumens
Efficiency: N/A
Efficacy: 128.1 lumens/watt
Spacing Criteria (0/90/45): 0.71 / 2.69 / 2.33
Luminous Opening: Rectangular w/ Sides (W: 0.29' x L: 4' x H: 0.1')
CIE Type: Semi-Indirect

Input Watts (W): 34.4
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P937010
CATALOG NUMBER: SQ4-FB-075U-050D-830-1D-UNV-STD-W-4

Luminous Intensity Polar Plot





TEST NUMBER: P937010

CATALOG NUMBER: SQ4-FB-075U-050D-830-1D-UNV-STD-W-4

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				20	
RC	80				70				50				30				10				0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	104	104	104	104	94	94	94	94	75	75	75	58	58	58	42	42	42	35				35
1	94	90	86	82	85	81	78	75	65	63	61	50	49	47	37	36	35	29				29
2	85	78	72	66	77	70	65	61	57	53	50	44	41	39	32	30	29	23				23
3	77	68	61	55	70	62	55	50	49	45	41	38	35	32	28	26	24	19				19
4	71	60	52	46	63	54	47	42	44	39	35	34	30	27	25	22	20	16				16
5	65	53	45	39	58	48	41	36	39	33	29	30	26	23	22	19	17	14				14
6	59	47	39	33	53	43	36	31	35	29	25	27	23	20	20	17	15	12				12
7	55	42	34	29	49	38	31	26	31	26	22	24	20	17	18	15	13	10				10
8	50	38	30	25	45	35	28	23	28	23	19	22	18	15	16	14	12	9				9
9	47	35	27	22	42	32	25	20	26	21	17	20	16	14	15	12	10	8				8
10	44	32	24	20	39	29	22	18	23	18	15	18	15	12	14	11	9	7				7

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	1850	1850	1850
5°	1807	2137	2487
10°	1637	3114	4124
15°	1389	4065	4980
20°	1130	4708	5076
25°	941	4922	4973
30°	792	4949	4963
35°	699	4863	5091
40°	609	4753	5224
45°	549	4670	5245
50°	503	4595	5158
55°	481	4488	4929
60°	489	4285	4567
65°	508	3978	4072
70°	536	3462	3440
75°	590	2816	2684
80°	632	1945	1810
85°	530	1028	924

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°
 Vertical Angle: 45°
 Luminance: 5245 cd/sqm



TEST NUMBER: P937010

CATALOG NUMBER: SQ4-FB-075U-050D-830-1D-UNV-STD-W-4

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	25.8	0.6
10°-20°	114.4	2.6
20°-30°	200.0	4.5
30°-40°	257.5	5.8
40°-50°	287.6	6.5
50°-60°	275.4	6.2
60°-70°	218.3	5.0
70°-80°	128.4	2.9
80°-90°	37.3	0.8
90°-100°	215.3	4.9
100°-110°	565.9	12.8
110°-120°	586.8	13.3
120°-130°	470.7	10.7
130°-140°	369.3	8.4
140°-150°	283.4	6.4
150°-160°	204.1	4.6
160°-170°	124.9	2.8
170°-180°	42.2	1.0
0°-30°	340.2	7.7
0°-40°	597.6	13.6
0°-60°	1160.7	26.3
0°-90°	1544.7	35.0
90°-120°	1367.9	31.0
90°-150°	2491.3	56.5
90°-180°	2863.0	65.0
0°-180°	4407.2	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	199	199	199	199	199	
5°	194	208	235	266	275	18
15°	146	269	453	549	566	41
25°	93	305	539	563	564	43
35°	63	291	508	537	558	39
45°	43	232	449	514	538	33
55°	31	148	381	442	455	28
65°	24	78	283	318	323	24
75°	18	48	155	171	171	19
85°	6	15	38	42	43	7
90°	3	8	23	11	11	3
95°	28	112	371	191	130	32
105°	102	154	626	950	886	108
115°	181	220	501	1000	1141	179
125°	252	282	456	770	909	224
135°	300	330	442	622	705	232
145°	348	370	436	530	572	218
155°	394	404	436	479	492	181
165°	425	430	436	453	459	120
175°	442	442	439	444	444	42
180°	442	442	442	442	442	



TEST NUMBER: P937010

CATALOG NUMBER: SQ4-FB-075U-050D-830-1D-UNV-STD-W-4

CANDELA DISTRIBUTION (FULL):

	0°	10°	20°	22.5°	30°	40°	45°	50°	60°	67.5°	70°
0°	199.4	199.4	199.4	199.4	199.4	199.4	199.4	199.4	199.4	199.4	199.4
2.5°	199.4	199.4	200.8	201.3	202.7	203.3	204.6	205.8	209.7	210.3	211.7
5°	194.4	196.9	205.3	208.4	217.4	229.6	234.7	243.1	260.4	265.5	268.7
7.5°	186.6	192.4	212.9	218.1	240.5	272.6	286.0	304.0	331.5	345.0	355.9
10°	174.5	186.6	223.2	235.4	271.9	320.6	345.7	370.7	412.4	431.0	438.0
12.5°	161.0	180.9	234.1	250.8	303.3	374.6	404.7	432.3	479.7	504.8	508.6
15°	145.6	172.6	244.4	268.7	336.7	419.4	452.8	486.8	531.1	548.9	553.4
17.5°	132.1	166.2	254.0	279.6	362.3	459.8	493.9	522.1	557.9	570.2	573.3
20°	115.5	155.8	260.4	293.8	389.3	489.4	522.1	543.9	568.2	575.9	577.2
22.5°	103.2	144.9	264.2	298.8	407.3	507.3	534.9	552.2	568.8	571.4	572.1
25°	93.0	132.8	263.6	304.7	422.6	518.2	539.4	552.2	561.8	563.1	563.1
27.5°	83.4	119.3	261.0	305.9	434.2	520.7	537.5	546.4	550.9	553.4	553.4
30°	75.0	106.5	254.6	303.3	439.3	518.2	531.6	536.1	540.6	544.5	546.4
32.5°	68.6	94.3	245.0	298.2	440.0	511.7	521.4	524.0	530.4	539.4	542.5
35°	62.8	82.1	234.1	291.2	436.1	501.5	507.9	510.5	523.3	536.8	541.3
37.5°	57.1	73.1	220.0	279.0	430.3	489.4	493.9	498.4	518.2	534.2	539.4
40°	51.3	65.4	203.3	265.5	421.4	474.6	478.5	485.5	511.7	530.4	535.6
42.5°	46.8	59.0	185.4	251.4	409.8	457.9	463.7	474.0	504.1	524.0	529.7
45°	42.9	52.6	166.2	232.1	395.0	440.6	448.9	463.1	495.1	514.3	519.5
47.5°	39.1	48.1	146.3	212.3	379.1	423.3	434.2	450.2	483.0	501.5	506.0
50°	35.9	43.6	126.4	191.1	361.8	404.7	417.5	434.2	467.6	484.9	490.6
52.5°	33.4	39.8	107.7	170.0	341.9	385.5	400.2	417.5	448.9	465.6	469.5
55°	30.8	36.5	91.7	147.5	321.3	364.9	381.0	397.6	428.4	442.5	445.1
57.5°	29.5	34.0	78.2	126.4	299.5	341.9	359.7	375.1	404.0	414.9	417.5
60°	27.5	32.0	68.0	108.4	275.8	320.1	335.5	350.9	375.1	384.1	386.1
62.5°	25.6	30.8	60.3	91.1	251.4	294.4	309.7	323.9	344.4	350.9	353.3
65°	24.4	29.5	54.5	78.2	226.4	267.4	282.8	295.0	311.7	318.1	319.4
67.5°	23.1	28.2	50.0	67.3	201.3	240.5	252.0	263.6	276.4	282.8	283.5
70°	21.1	27.0	46.2	59.7	175.7	209.7	219.3	231.5	241.8	245.0	246.9
72.5°	19.9	25.0	43.6	53.9	149.4	180.2	189.2	196.3	205.3	208.4	208.4
75°	18.0	22.5	41.0	48.1	122.5	147.5	155.2	162.2	169.3	170.6	168.6
77.5°	16.1	19.9	35.3	40.4	95.6	116.7	123.1	127.0	132.8	134.0	134.7
80°	13.5	17.3	27.5	31.5	69.3	85.9	90.4	93.6	98.8	98.8	100.1
82.5°	10.2	13.5	19.9	22.5	46.8	59.0	62.8	64.8	68.0	68.0	68.0
85°	6.4	8.3	12.8	14.7	28.2	35.9	38.5	39.1	41.7	42.4	42.4
87.5°	3.3	4.5	8.3	9.0	14.7	18.6	18.6	19.9	19.9	19.2	18.6
90°	3.0	5.4	7.7	8.3	13.1	19.4	22.6	20.1	15.0	11.3	11.3
92.5°	11.9	32.0	52.1	57.2	80.4	111.4	126.9	111.2	79.8	56.3	54.1
95°	28.5	65.4	102.3	111.5	197.9	313.1	370.7	330.8	251.0	191.1	184.3
97.5°	49.2	81.7	114.2	122.4	266.5	458.7	554.8	529.5	479.1	441.3	428.4
100°	65.2	94.6	124.2	131.5	291.5	504.8	611.4	613.2	616.9	619.7	604.3
102.5°	78.9	106.4	133.8	140.7	303.0	519.3	627.4	659.5	723.8	772.0	758.8
105°	101.9	125.2	148.6	154.4	311.5	520.9	625.6	697.7	841.8	949.8	942.7
107.5°	125.6	147.4	169.1	174.6	313.1	497.7	590.0	690.5	891.5	1042.2	1044.0
110°	141.7	161.3	181.0	185.8	310.7	477.1	560.4	672.7	897.4	1065.9	1073.3



TEST NUMBER: P937010

CATALOG NUMBER: SQ4-FB-075U-050D-830-1D-UNV-STD-W-4

CANDELA DISTRIBUTION (continued):

	0°	10°	20°	22.5°	30°	40°	45°	50°	60°	67.5°	70°
112.5°	157.4	176.1	194.7	199.4	310.8	459.3	533.4	648.5	878.4	1050.8	1062.2
115°	181.1	198.3	215.6	219.9	313.7	438.6	501.1	611.9	833.4	999.6	1015.3
117.5°	204.5	220.2	235.8	239.8	319.5	425.7	478.9	578.9	778.8	928.8	946.2
120°	218.2	232.9	247.6	251.3	324.2	421.4	470.0	561.4	744.1	881.0	898.0
122.5°	231.4	246.4	261.2	264.9	331.0	419.1	463.2	545.4	709.9	833.3	850.1
125°	251.9	265.5	279.1	282.4	340.2	417.3	455.8	525.7	665.5	770.2	785.6
127.5°	268.5	282.2	295.9	299.3	349.4	416.2	449.6	509.6	629.6	719.6	732.6
130°	277.4	292.2	306.9	310.6	356.1	416.8	447.2	500.7	607.4	687.6	699.5
132.5°	286.6	301.3	316.1	319.8	361.6	417.3	445.1	492.9	588.6	660.3	671.0
135°	300.2	313.6	327.0	330.4	367.5	416.9	441.6	481.6	561.7	621.8	631.1
137.5°	314.1	327.4	340.7	344.1	376.4	419.5	441.0	474.8	542.5	593.3	600.8
140°	325.7	337.9	350.2	353.2	381.8	419.9	438.9	468.2	526.6	570.4	577.5
142.5°	334.6	345.9	357.2	360.0	386.3	421.4	438.9	464.6	516.0	554.5	560.6
145°	348.2	358.1	368.0	370.4	392.2	421.4	435.9	457.0	498.9	530.5	535.1
147.5°	361.8	371.4	381.1	383.5	400.9	424.3	435.9	452.5	485.6	510.3	514.1
150°	370.7	379.4	388.1	390.3	405.5	425.8	435.9	449.9	477.8	498.7	501.8
152.5°	379.9	386.5	393.1	394.7	408.5	426.8	435.9	447.9	471.7	489.6	491.9
155°	393.6	398.5	403.2	404.5	415.0	429.0	435.9	445.4	464.3	478.6	480.1
157.5°	403.6	408.4	413.2	414.3	421.5	431.2	435.9	443.3	458.0	469.1	470.2
160°	410.4	414.1	417.8	418.7	424.5	432.1	435.9	442.2	455.0	464.4	465.0
162.5°	417.3	420.1	422.8	423.5	427.6	433.2	435.9	441.3	451.9	459.9	460.5
165°	424.7	427.1	429.6	430.3	432.2	434.7	435.9	439.8	447.4	453.1	453.8
167.5°	431.4	432.6	433.8	434.1	435.7	437.8	438.9	441.4	446.5	450.2	450.5
170°	435.9	437.1	438.3	438.6	438.7	438.8	438.9	441.4	446.5	450.2	450.2
172.5°	438.3	438.6	438.8	438.9	438.9	438.9	438.9	440.9	444.8	447.8	447.6
175°	441.6	441.6	441.6	441.6	440.7	439.5	438.9	440.1	442.6	444.5	444.5
177.5°	441.6	441.6	441.6	441.6	440.9	440.0	439.5	440.4	442.4	444.0	443.7
180°	441.6	441.6	441.6	441.6	441.6	441.6	441.6	441.6	441.6	441.6	441.6



TEST NUMBER: P937010

CATALOG NUMBER: SQ4-FB-075U-050D-830-1D-UNV-STD-W-4

CANDELA DISTRIBUTION (continued):

	80°	90°
0°	199.4	199.4
2.5°	212.9	211.7
5°	273.9	275.1
7.5°	368.7	368.2
10°	458.6	464.3
12.5°	524.0	525.2
15°	563.8	566.3
17.5°	579.1	579.8
20°	579.8	578.5
22.5°	572.7	571.4
25°	564.4	563.8
27.5°	556.7	557.3
30°	553.4	555.4
32.5°	553.4	556.7
35°	554.8	557.9
37.5°	554.1	557.9
40°	551.5	556.0
42.5°	544.5	547.7
45°	533.5	537.5
47.5°	519.5	522.1
50°	501.5	504.1
52.5°	479.1	479.7
55°	452.2	454.7
57.5°	423.3	423.9
60°	391.2	393.1
62.5°	357.3	357.3
65°	321.3	322.6
67.5°	284.1	287.3
70°	246.3	246.9
72.5°	209.1	209.1
75°	170.6	171.2
77.5°	134.0	134.0
80°	99.4	100.1
82.5°	68.6	69.9
85°	42.9	42.9
87.5°	19.9	18.0
90°	11.3	11.3
92.5°	45.1	36.1
95°	157.3	130.1
97.5°	376.8	325.1
100°	542.8	481.3
102.5°	706.1	653.4
105°	914.4	886.1
107.5°	1050.8	1057.7
110°	1102.8	1132.4



TEST NUMBER: P937010
CATALOG NUMBER: SQ4-FB-075U-050D-830-1D-UNV-STD-W-4

CANDELA DISTRIBUTION (continued):

	80°	90°
112.5°	1107.5	1152.8
115°	1078.2	1141.0
117.5°	1015.8	1085.5
120°	965.7	1033.3
122.5°	916.8	983.6
125°	847.1	908.6
127.5°	784.4	836.3
130°	747.5	795.4
132.5°	713.9	756.9
135°	668.1	705.0
137.5°	631.2	661.5
140°	605.9	634.2
142.5°	584.9	609.3
145°	553.5	572.0
147.5°	529.4	544.7
150°	514.2	526.7
152.5°	501.2	510.6
155°	486.3	492.5
157.5°	474.6	478.9
160°	467.5	470.0
162.5°	462.9	465.3
165°	456.3	458.8
167.5°	451.5	452.6
170°	450.2	450.2
172.5°	446.6	445.7
175°	444.5	444.5
177.5°	442.6	441.6
180°	441.6	441.6



TEST NUMBER: P937010
 CATALOG NUMBER: SQ4-FB-075U-050D-830-1D-UNV-STD-W-4

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	1.58	2.34	2.65	3.42	4.89	14.72	15.48	15.79	16.56	18.03
	3H	2.28	2.96	3.36	4.05	5.53	16.54	17.22	17.61	18.31	19.79
	4H	2.57	3.23	3.66	4.31	5.80	17.17	17.82	18.26	18.90	20.40
	6H	2.82	3.42	3.92	4.51	6.01	17.58	18.18	18.68	19.27	20.77
	8H	2.88	3.46	3.99	4.56	6.06	17.69	18.26	18.79	19.37	20.87
	12H	2.90	3.44	4.01	4.54	6.06	17.75	18.29	18.86	19.39	20.91
4H	2H	8.76	9.41	9.85	10.50	11.99	14.98	15.64	16.08	16.72	18.21
	3H	10.32	10.86	11.42	11.98	13.48	17.00	17.55	18.11	18.66	20.17
	4H	10.41	10.91	11.52	12.01	13.54	17.76	18.26	18.87	19.36	20.89
	6H	10.42	10.85	11.53	11.97	13.49	18.28	18.71	19.39	19.83	21.35
	8H	10.39	10.79	11.51	11.91	13.44	18.43	18.83	19.55	19.95	21.48
	12H	10.34	10.71	11.48	11.84	13.38	18.51	18.88	19.64	20.01	21.54
8H	4H	11.84	12.24	12.95	13.36	14.89	17.81	18.21	18.93	19.33	20.86
	6H	12.07	12.41	13.21	13.57	15.10	18.42	18.76	19.56	19.91	21.44
	8H	12.09	12.38	13.24	13.52	15.07	18.63	18.92	19.78	20.06	21.61
	12H	12.06	12.31	13.20	13.45	15.03	18.76	19.02	19.91	20.16	21.74
12H	4H	11.97	12.34	13.11	13.47	15.01	17.76	18.12	18.89	19.25	20.79
	6H	12.33	12.62	13.47	13.76	15.31	18.40	18.70	19.55	19.84	21.39
	8H	12.39	12.65	13.54	13.79	15.37	18.62	18.88	19.77	20.01	21.60