

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: CORELITE

Report Number: P938532

Luminaire Tested: SQ4-FB-150U-125D-92765-1D-UNV-STD-W-4-3000K

Issue Date: 12/17/2024

Test Information

Test Method: LM-79-2019
Report Number: P938532
REPORT IS A COMBINATION OF REPORTS P933632 AND P933786
Test Lab: INNOVATION CENTER
Issue Date: 12/17/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: CORELITE
Catalog Number: SQ4-FB-150U-125D-92765-1D-UNV-STD-W-4-3000K
Description: CORELITE SQ4 SUSPENDED INDIRECT LED LUMINAIRE WITH Batwing Frosted Continuous Roll L
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 8806.7 lumens
Efficiency: N/A
Efficacy: 105.8 lumens/watt
Spacing Criteria (0/90/45): 0.71 / 2.69 / 2.33
Luminous Opening: Rectangular w/ Sides (W: 0.29' x L: 4' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 83.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P938532
CATALOG NUMBER: SQ4-FB-150U-125D-92765-1D-UNV-STD-W-4-3000K

Luminous Intensity Polar Plot





TEST NUMBER: P938532

CATALOG NUMBER: SQ4-FB-150U-125D-92765-1D-UNV-STD-W-4-3000K

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	105	105	105	105	95	95	95	95	78	78	78	62	62	62	47	47	47	47	47	47	40
1	95	91	87	83	86	83	79	76	68	65	63	54	52	51	41	40	39	39	39	39	33
2	86	79	72	67	78	72	66	62	59	55	51	47	44	42	36	34	32	32	32	32	27
3	78	69	61	55	71	63	56	51	51	47	43	41	37	35	31	29	27	27	27	27	22
4	71	60	52	46	65	55	48	43	45	40	36	36	32	29	27	25	23	23	23	23	19
5	65	53	45	39	59	49	42	36	40	35	30	32	28	25	24	22	19	19	19	19	16
6	60	48	39	34	54	44	36	31	36	30	26	29	25	21	22	19	17	17	17	17	14
7	55	43	35	29	50	39	32	27	32	27	23	26	22	19	20	17	15	15	15	15	12
8	51	39	31	25	46	35	28	24	29	24	20	23	19	16	18	15	13	13	13	13	10
9	47	35	27	22	43	32	25	21	27	21	18	21	17	15	17	14	11	11	11	11	9
10	44	32	25	20	40	29	23	18	24	19	16	20	16	13	15	12	10	10	10	10	8

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	4258	4258	4258
5°	4156	4918	5724
10°	3765	7163	9489
15°	3196	9352	11458
20°	2599	10830	11678
25°	2166	11325	11441
30°	1824	11387	11419
35°	1610	11189	11713
40°	1401	10935	12019
45°	1266	10745	12066
50°	1159	10572	11866
55°	1106	10324	11340
60°	1130	9858	10511
65°	1169	9154	9368
70°	1236	7966	7915
75°	1354	6479	6177
80°	1451	4478	4162
85°	1217	2362	2131

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°
 Vertical Angle: 45°
 Luminance: 12066 cd/sqm



TEST NUMBER: P938532

CATALOG NUMBER: SQ4-FB-150U-125D-92765-1D-UNV-STD-W-4-3000K

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	59.4	0.7
10°-20°	263.1	3.0
20°-30°	460.2	5.2
30°-40°	592.4	6.7
40°-50°	661.7	7.5
50°-60°	633.7	7.2
60°-70°	502.2	5.7
70°-80°	295.3	3.4
80°-90°	85.2	1.0
90°-100°	395.0	4.5
100°-110°	1038.6	11.8
110°-120°	1076.9	12.2
120°-130°	863.8	9.8
130°-140°	677.8	7.7
140°-150°	520.2	5.9
150°-160°	374.6	4.3
160°-170°	229.2	2.6
170°-180°	77.4	0.9
0°-30°	782.6	8.9
0°-40°	1375.0	15.6
0°-60°	2670.4	30.3
0°-90°	3553.2	40.3
90°-120°	2510.5	28.5
90°-150°	4572.2	51.9
90°-180°	5254.0	59.7
0°-180°	8806.7	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	459	459	459	459	459	
5°	447	480	540	611	633	41
15°	335	618	1042	1263	1303	93
25°	214	701	1241	1296	1297	99
35°	145	670	1169	1235	1284	90
45°	99	534	1033	1183	1236	76
55°	71	339	876	1018	1046	65
65°	56	180	651	732	742	56
75°	41	111	357	392	394	43
85°	15	34	88	97	99	16
90°	5	15	41	21	21	5
95°	52	204	680	351	239	58
105°	187	283	1148	1743	1626	198
115°	332	404	920	1835	2094	328
125°	462	518	836	1414	1668	410
135°	551	606	810	1141	1294	426
145°	639	680	800	974	1050	400
155°	722	742	800	878	904	332
165°	779	790	800	832	842	220
175°	810	810	806	816	816	77
180°	810	810	810	810	810	



TEST NUMBER: P938532

CATALOG NUMBER: SQ4-FB-150U-125D-92765-1D-UNV-STD-W-4-3000K

CANDELA DISTRIBUTION (FULL):

	0°	10°	20°	22.5°	30°	40°	45°	50°	60°	67.5°	70°
0°	458.9	458.9	458.9	458.9	458.9	458.9	458.9	458.9	458.9	458.9	458.9
2.5°	458.9	458.9	461.8	463.3	466.3	467.8	470.7	473.7	482.5	484.0	486.9
5°	447.1	453.0	472.2	479.5	500.2	528.3	540.1	559.2	599.1	610.9	618.3
7.5°	429.4	442.6	489.9	501.7	553.3	627.1	658.1	699.5	762.9	793.8	818.9
10°	401.3	429.4	513.5	541.5	625.6	737.7	795.3	852.8	948.8	991.6	1007.8
12.5°	370.4	416.1	538.6	576.9	698.0	861.7	931.1	994.6	1103.7	1161.3	1170.1
15°	334.9	396.9	562.2	618.3	774.6	965.0	1041.7	1120.0	1221.8	1263.1	1273.4
17.5°	304.0	382.2	584.3	643.4	833.7	1058.0	1136.2	1201.1	1283.7	1311.8	1319.1
20°	265.6	358.6	599.1	675.8	895.7	1125.9	1201.1	1251.3	1307.4	1325.1	1328.0
22.5°	237.5	333.5	607.9	687.6	937.0	1167.1	1230.6	1270.5	1308.8	1314.8	1316.2
25°	214.0	305.5	606.5	700.9	972.4	1192.2	1241.0	1270.5	1292.6	1295.6	1295.6
27.5°	191.8	274.4	600.6	703.8	998.9	1198.2	1236.5	1257.2	1267.5	1273.4	1273.4
30°	172.7	245.0	585.8	698.0	1010.8	1192.2	1223.2	1233.6	1243.9	1252.8	1257.2
32.5°	157.9	216.9	563.7	686.1	1012.3	1177.5	1199.7	1205.5	1220.3	1241.0	1248.3
35°	144.6	188.9	538.6	669.9	1003.4	1153.9	1168.6	1174.5	1204.0	1235.1	1245.4
37.5°	131.3	168.2	506.1	641.9	990.1	1125.9	1136.2	1146.6	1192.2	1229.1	1241.0
40°	118.1	150.5	467.8	610.9	969.4	1091.9	1100.8	1117.0	1177.5	1220.3	1232.1
42.5°	107.7	135.8	426.4	578.4	942.8	1053.6	1066.8	1090.5	1159.8	1205.5	1218.8
45°	98.9	121.0	382.2	534.1	908.9	1013.7	1032.9	1065.4	1139.1	1183.4	1195.2
47.5°	90.0	110.7	336.4	488.4	872.0	973.9	998.9	1035.9	1111.1	1153.9	1164.3
50°	82.7	100.4	290.6	439.7	832.2	931.1	960.6	998.9	1075.7	1115.5	1128.8
52.5°	76.7	91.5	247.9	391.0	786.5	886.8	920.8	960.6	1032.9	1071.3	1080.1
55°	70.8	84.1	211.0	339.4	739.2	839.6	876.5	914.9	985.7	1018.1	1024.0
57.5°	67.8	78.2	180.0	290.6	689.1	786.5	827.8	863.2	929.6	954.7	960.6
60°	63.5	73.8	156.4	249.4	634.5	736.3	771.8	807.2	863.2	883.9	888.3
62.5°	59.0	70.8	138.7	209.5	578.4	677.3	712.7	745.2	792.4	807.2	813.0
65°	56.1	67.8	125.4	180.0	520.9	615.3	650.7	678.8	717.2	731.9	734.9
67.5°	53.1	65.0	115.1	155.0	463.3	553.3	579.9	606.5	636.0	650.7	652.2
70°	48.7	62.0	106.2	137.3	404.3	482.5	504.6	532.6	556.3	563.7	568.1
72.5°	45.8	57.6	100.4	123.9	343.8	414.7	435.3	451.5	472.2	479.5	479.5
75°	41.3	51.6	94.4	110.7	281.8	339.4	357.1	373.3	389.5	392.5	388.1
77.5°	36.9	45.8	81.2	93.0	219.8	268.6	283.3	292.1	305.5	308.4	309.8
80°	31.0	39.9	63.5	72.3	159.3	197.7	208.1	215.4	227.3	227.3	230.2
82.5°	23.6	31.0	45.8	51.6	107.7	135.8	144.6	149.0	156.4	156.4	156.4
85°	14.7	19.2	29.5	33.9	65.0	82.7	88.5	90.0	95.9	97.4	97.4
87.5°	7.4	10.3	19.2	20.7	33.9	42.8	42.8	45.8	45.8	44.3	42.8
90°	5.4	9.8	14.1	15.3	24.0	35.6	41.3	36.7	27.6	20.7	20.7
92.5°	21.7	58.7	95.7	105.0	147.5	204.3	232.7	204.0	146.5	103.3	99.2
95°	52.2	119.9	187.6	204.5	363.1	574.7	680.4	607.2	460.7	350.8	338.3
97.5°	90.3	150.0	209.7	224.6	489.1	841.9	1018.2	971.9	879.3	809.9	786.1
100°	119.6	173.8	227.9	241.5	535.0	926.4	1122.0	1125.4	1132.2	1137.3	1109.1
102.5°	144.7	195.2	245.7	258.4	556.1	953.0	1151.4	1210.4	1328.4	1416.9	1392.7
105°	187.1	230.0	272.7	283.4	571.6	955.9	1148.1	1280.3	1544.8	1743.2	1730.2
107.5°	230.7	270.5	310.4	320.4	574.6	913.5	1082.9	1267.3	1636.2	1912.9	1916.0
110°	260.0	296.0	332.1	341.1	570.2	875.7	1028.5	1234.7	1647.1	1956.4	1969.9



TEST NUMBER: P938532

CATALOG NUMBER: SQ4-FB-150U-125D-92765-1D-UNV-STD-W-4-3000K

CANDELA DISTRIBUTION (continued):

	0°	10°	20°	22.5°	30°	40°	45°	50°	60°	67.5°	70°
112.5°	288.8	323.2	357.5	366.1	570.4	842.8	979.0	1190.1	1612.1	1928.7	1949.4
115°	332.3	364.0	395.6	403.6	575.6	805.1	919.7	1123.0	1529.6	1834.6	1863.4
117.5°	375.3	404.1	432.9	440.0	586.4	781.4	878.9	1062.4	1429.4	1704.6	1736.6
120°	400.3	427.4	454.4	461.2	595.0	773.4	862.6	1030.2	1365.5	1617.0	1648.1
122.5°	424.8	452.1	479.4	486.2	607.5	769.3	850.1	1001.1	1303.0	1529.5	1560.1
125°	462.4	487.2	512.1	518.3	624.4	765.8	836.5	964.7	1221.2	1413.6	1441.8
127.5°	492.8	517.9	543.0	549.3	641.2	763.8	825.1	935.3	1155.4	1320.6	1344.4
130°	509.1	536.1	563.2	570.0	653.6	765.0	820.8	918.8	1114.8	1261.8	1283.8
132.5°	525.9	553.0	580.1	586.9	663.5	765.8	816.9	904.6	1080.2	1211.8	1231.5
135°	551.0	575.6	600.2	606.4	674.4	765.0	810.4	883.9	1030.8	1141.1	1158.1
137.5°	576.5	600.9	625.3	631.4	690.7	769.8	809.3	871.4	995.7	1088.9	1102.8
140°	597.8	620.3	642.8	648.4	700.8	770.6	805.5	859.1	966.5	1047.0	1060.0
142.5°	614.1	634.8	655.6	660.8	709.1	773.3	805.5	852.7	946.9	1017.7	1028.8
145°	639.1	657.3	675.3	679.8	720.0	773.4	800.1	838.6	915.7	973.5	982.0
147.5°	664.1	681.8	699.4	703.8	735.9	778.7	800.1	830.4	891.0	936.6	943.5
150°	680.4	696.4	712.3	716.3	744.2	781.4	800.1	825.7	876.9	915.4	921.0
152.5°	697.3	709.4	721.4	724.5	749.7	783.3	800.1	822.0	865.8	898.5	902.8
155°	722.3	731.3	740.2	742.4	761.6	787.3	800.1	817.5	852.3	878.4	881.3
157.5°	740.8	749.5	758.1	760.3	773.6	791.3	800.1	813.6	840.6	861.0	863.0
160°	753.3	760.1	766.9	768.5	779.1	793.1	800.1	811.7	834.9	852.2	853.4
162.5°	765.8	770.9	775.9	777.2	784.8	795.0	800.1	809.9	829.5	844.1	845.2
165°	779.4	784.0	788.6	789.7	793.2	797.8	800.1	807.1	821.1	831.6	832.7
167.5°	791.9	794.1	796.3	796.8	799.7	803.6	805.5	810.1	819.3	826.2	826.7
170°	800.1	802.3	804.5	805.0	805.1	805.4	805.5	810.1	819.3	826.2	826.2
172.5°	804.5	804.9	805.4	805.5	805.5	805.5	805.5	809.2	816.4	821.8	821.4
175°	810.4	810.4	810.4	810.4	808.7	806.5	805.5	807.8	812.4	815.9	815.9
177.5°	810.4	810.4	810.4	810.4	809.2	807.5	806.6	808.5	812.0	814.7	814.2
180°	810.4	810.4	810.4	810.4	810.4	810.4	810.4	810.4	810.4	810.4	810.4



TEST NUMBER: P938532
 CATALOG NUMBER: SQ4-FB-150U-125D-92765-1D-UNV-STD-W-4-3000K

CANDELA DISTRIBUTION (continued):

	80°	90°
0°	458.9	458.9
2.5°	489.9	486.9
5°	630.0	633.0
7.5°	848.5	847.0
10°	1055.0	1068.3
12.5°	1205.5	1208.5
15°	1297.1	1302.9
17.5°	1332.5	1334.0
20°	1334.0	1331.0
22.5°	1317.6	1314.8
25°	1298.5	1297.1
27.5°	1280.8	1282.2
30°	1273.4	1277.9
32.5°	1273.4	1280.8
35°	1276.4	1283.7
37.5°	1274.9	1283.7
40°	1269.0	1279.3
42.5°	1252.8	1260.1
45°	1227.6	1236.5
47.5°	1195.2	1201.1
50°	1153.9	1159.8
52.5°	1102.3	1103.7
55°	1040.2	1046.2
57.5°	973.9	975.4
60°	900.1	904.6
62.5°	821.9	821.9
65°	739.2	742.2
67.5°	653.7	661.1
70°	566.6	568.1
72.5°	481.0	481.0
75°	392.5	394.0
77.5°	308.4	308.4
80°	228.7	230.2
82.5°	157.9	160.8
85°	98.9	98.9
87.5°	45.8	41.3
90°	20.7	20.7
92.5°	82.8	66.4
95°	288.6	238.8
97.5°	691.4	596.6
100°	996.2	883.3
102.5°	1296.0	1199.3
105°	1678.2	1626.3
107.5°	1928.6	1941.1
110°	2024.1	2078.2



TEST NUMBER: P938532

CATALOG NUMBER: SQ4-FB-150U-125D-92765-1D-UNV-STD-W-4-3000K

CANDELA DISTRIBUTION (continued):

	80°	90°
112.5°	2032.6	2115.7
115°	1978.7	2094.0
117.5°	1864.4	1992.2
120°	1772.3	1896.6
122.5°	1682.7	1805.2
125°	1554.7	1667.6
127.5°	1439.6	1534.9
130°	1371.8	1459.8
132.5°	1310.2	1389.1
135°	1226.0	1293.9
137.5°	1158.4	1214.0
140°	1111.9	1163.9
142.5°	1073.6	1118.2
145°	1015.9	1049.8
147.5°	971.6	999.7
150°	943.8	966.5
152.5°	920.0	937.1
155°	892.6	904.0
157.5°	870.9	878.9
160°	858.0	862.6
162.5°	849.5	853.9
165°	837.3	841.9
167.5°	828.6	830.5
170°	826.2	826.2
172.5°	819.7	818.1
175°	815.9	815.9
177.5°	812.3	810.4
180°	810.4	810.4



TEST NUMBER: P938532
 CATALOG NUMBER: SQ4-FB-150U-125D-92765-1D-UNV-STD-W-4-3000K

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	5.07	5.88	6.10	6.92	8.32	18.21	19.02	19.24	20.06	21.46
	3H	5.78	6.50	6.81	7.55	8.97	20.03	20.76	21.07	21.81	23.23
	4H	6.07	6.76	7.12	7.81	9.24	20.66	21.35	21.71	22.41	23.83
	6H	6.32	6.96	7.38	8.01	9.45	21.08	21.72	22.14	22.77	24.21
	8H	6.39	6.99	7.45	8.07	9.50	21.19	21.80	22.26	22.87	24.30
	12H	6.40	6.98	7.47	8.05	9.50	21.25	21.83	22.32	22.89	24.35
4H	2H	12.26	12.95	13.31	14.00	15.42	18.48	19.17	19.54	20.22	21.65
	3H	13.82	14.40	14.89	15.48	16.92	20.51	21.08	21.57	22.16	23.60
	4H	13.92	14.45	14.99	15.52	16.98	21.26	21.79	22.33	22.86	24.32
	6H	13.92	14.38	15.00	15.47	16.93	21.78	22.24	22.87	23.33	24.79
	8H	13.90	14.33	14.98	15.41	16.88	21.94	22.36	23.02	23.45	24.92
	12H	13.85	14.24	14.95	15.34	16.82	22.02	22.41	23.12	23.51	24.98
8H	4H	15.35	15.77	16.43	16.86	18.33	21.32	21.74	22.40	22.83	24.30
	6H	15.59	15.94	16.69	17.07	18.53	21.93	22.29	23.04	23.41	24.88
	8H	15.60	15.91	16.71	17.02	18.51	22.14	22.45	23.26	23.56	25.05
	12H	15.57	15.84	16.68	16.95	18.47	22.28	22.55	23.39	23.66	25.18
12H	4H	15.48	15.87	16.58	16.97	18.45	21.27	21.65	22.37	22.75	24.23
	6H	15.84	16.15	16.95	17.26	18.75	21.91	22.23	23.03	23.33	24.82
	8H	15.91	16.18	17.02	17.28	18.81	22.13	22.41	23.25	23.51	25.04