

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: CORELITE

Report Number: P521850

Luminaire Tested: **SQ4-WB-075U-125D-92765-1D-UNV-STD-W-4 (4000K)**

Issue Date: 5/5/2021



**Test Information**

Test Method: LM-79-08  
Report Number: P521850  
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2101-105-51,  
Test Lab: INNOVATION CENTER  
Issue Date: 5/5/2021  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: CORELITE  
Catalog Number: SQ4-WB-075U-125D-92765-1D-UNV-STD-W-4 (4000K)  
Description: CORELITE SQ4 SUSPENDED LED LUMINAIRE WITH WHITE BAFFLE  
DOWNLIGHT 1250 LUMENS PER FOOT  
UPLIGHT 750 LUMENS PER FOOT  
Light Source: 2700K/65000K CCT, 90 CRI LEDS, TUNED TO 4000K CCT  
Ballast/Driver: ELECTRONIC DRIVER


**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 7751.3 lumens  
Efficiency: N/A  
Efficacy: 97.5 lumens/watt  
Spacing Criteria (0/90/45): 0.89 / 1 / 1.02  
Luminous Opening: Rectangular (W 0.29' x L: 4' x H: 0')  
CIE Type: General Diffuse

Input Watts (W): 79.5  
Input Voltage (V): 120  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P521850  
CATALOG NUMBER: SQ4-WB-075U-125D-92765-1D-UNV-STD-W-4 (4000K)

### Luminous Intensity Polar Plot





TEST NUMBER: P521850

CATALOG NUMBER: SQ4-WB-075U-125D-92765-1D-UNV-STD-W-4 (4000K)

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	109	109	109	109	101	101	101	101	87	87	87	74	74	74	63	63	63	57
1	101	97	93	90	94	90	87	85	78	76	74	67	66	65	57	56	55	51
2	93	86	81	76	86	81	76	72	70	67	64	61	58	56	52	50	49	45
3	86	77	70	65	80	72	66	62	63	59	55	55	52	49	47	45	43	39
4	79	69	62	56	74	65	59	54	57	52	48	50	46	43	43	41	38	35
5	73	62	55	49	68	59	52	47	52	47	43	46	42	39	40	37	34	32
6	68	57	49	44	63	54	47	42	48	42	38	42	38	35	37	34	31	28
7	63	52	44	39	59	49	42	37	44	38	34	39	34	31	34	31	28	26
8	59	47	40	35	55	45	38	34	40	35	31	36	32	28	32	28	26	24
9	55	44	37	32	52	41	35	31	37	32	28	33	29	26	29	26	24	22
10	52	40	34	29	49	38	32	28	35	29	26	31	27	24	28	24	22	20

**AVERAGE LUMINANCE (cd/sqm):**

	0°	45°	90°
0°	28012	28012	28012
5°	27662	27564	27724
10°	26135	26372	26984
15°	24127	24686	25793
20°	21910	22733	24238
25°	19651	20722	22580
30°	17571	18720	20864
35°	15365	16476	18831
40°	12933	13959	16301
45°	10673	11594	13610
50°	8911	9714	11339
55°	7565	8335	9365
60°	6466	7228	7473
65°	5148	6078	4827
70°	4564	4745	2946
75°	4228	3846	1804
80°	3895	3539	1557
85°	3525	3239	1270



TEST NUMBER: P521850

CATALOG NUMBER: SQ4-WB-075U-125D-92765-1D-UNV-STD-W-4 (4000K)

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	278.5	3.6
10°-20°	724.4	9.3
20°-30°	938.2	12.1
30°-40°	918.8	11.9
40°-50°	703.3	9.1
50°-60°	468.6	6.0
60°-70°	255.7	3.3
70°-80°	106.6	1.4
80°-90°	30.2	0.4
90°-100°	244.1	3.1
100°-110°	694.5	9.0
110°-120°	665.4	8.6
120°-130°	526.6	6.8
130°-140°	422.7	5.5
140°-150°	330.9	4.3
150°-160°	242.1	3.1
160°-170°	150.0	1.9
170°-180°	50.9	0.7
0°-30°	1941.1	25.0
0°-40°	2859.9	36.9
0°-60°	4031.7	52.0
0°-90°	4424.2	57.1
90°-120°	1603.9	20.7
90°-150°	2884.1	37.2
90°-180°	3327.0	42.9
0°-180°	7751.3	100.0

**CANDELA DISTRIBUTION:**

	0°	22.5°	45°	67.5°	90°	Flux
0°	3036	3036	3036	3036	3036	
5°	2987	2957	2976	2983	2994	278
15°	2526	2517	2584	2655	2700	705
25°	1930	1936	2036	2124	2218	888
35°	1364	1371	1463	1561	1672	848
45°	818	834	889	956	1043	638
55°	470	490	518	538	582	426
65°	236	255	278	243	221	245
75°	119	119	108	74	51	127
85°	33	33	31	20	12	36
90°	0	0	0	0	0	3
95°	26	105	472	164	101	30
105°	108	164	708	1250	1188	114
115°	201	242	537	1137	1335	198
125°	283	314	512	850	1016	253
135°	346	375	506	718	812	267
145°	408	429	510	621	677	255
155°	466	477	522	562	584	216
165°	515	517	528	540	548	145
175°	540	537	535	532	528	51
180°	536	536	536	536	536	

TEST NUMBER: P521850

CATALOG NUMBER: SQ4-WB-075U-125D-92765-1D-UNV-STD-W-4 (4000K)

**CANDELA DISTRIBUTION (FULL):**

	0°	22.5°	45°	67.5°	90°
0°	3036.1	3036.1	3036.1	3036.1	3036.1
2.5°	3043.6	3016.5	3023.3	3023.2	3014.8
5°	2986.8	2956.9	2976.2	2983.1	2993.5
7.5°	2876.0	2853.3	2888.5	2914.6	2935.7
10°	2789.7	2770.1	2815.0	2852.9	2880.3
12.5°	2689.5	2673.1	2728.7	2779.6	2815.2
15°	2525.9	2516.8	2584.5	2654.8	2700.4
17.5°	2350.8	2346.4	2424.1	2506.2	2564.5
20°	2231.5	2230.2	2315.4	2400.9	2468.6
22.5°	2111.0	2113.9	2203.5	2292.4	2369.5
25°	1930.4	1935.6	2035.6	2124.4	2218.1
27.5°	1763.3	1765.7	1869.1	1962.8	2062.8
30°	1649.3	1655.8	1757.2	1854.2	1958.4
32.5°	1535.3	1542.8	1642.1	1742.3	1848.6
35°	1364.2	1370.7	1462.8	1561.2	1671.9
37.5°	1187.8	1196.7	1278.4	1371.5	1480.4
40°	1073.8	1086.8	1159.0	1246.7	1353.5
42.5°	964.0	980.1	1047.1	1130.3	1226.7
45°	818.0	833.6	888.6	955.9	1043.1
47.5°	692.2	710.2	752.4	810.4	884.9
50°	620.8	637.7	676.8	719.7	790.0
52.5°	557.9	574.9	609.6	642.7	702.6
55°	470.3	489.8	518.2	537.9	582.2
57.5°	398.3	417.1	439.6	448.5	475.3
60°	350.4	371.2	391.7	390.7	405.0
62.5°	306.7	324.4	344.8	330.7	331.5
65°	235.8	255.3	278.4	243.3	221.1
67.5°	190.5	194.7	218.5	169.7	143.3
70°	169.2	169.2	175.9	131.4	109.2
72.5°	148.9	148.9	142.8	106.8	83.7
75°	118.6	118.6	107.9	74.1	50.6
77.5°	91.4	90.3	82.6	55.3	36.8
80°	73.3	73.3	66.6	43.6	29.3
82.5°	57.3	57.3	51.7	34.1	21.8
85°	33.3	33.3	30.6	19.8	12.0
87.5°	11.7	11.7	10.7	6.4	5.3
90°	0.0	0.0	0.0	0.0	0.0
92.5°	8.1	43.2	100.2	29.2	22.0
95°	26.5	105.1	472.5	163.5	100.8
97.5°	48.7	123.2	727.7	520.7	356.8
100°	64.2	133.8	783.1	793.2	611.0
102.5°	81.3	145.4	770.8	1015.3	856.2
105°	107.9	163.7	707.7	1250.1	1188.4
107.5°	135.0	185.0	634.0	1316.3	1371.2
110°	153.8	200.6	591.6	1290.9	1414.4

TEST NUMBER: P521850

CATALOG NUMBER: SQ4-WB-075U-125D-92765-1D-UNV-STD-W-4 (4000K)

**CANDELA DISTRIBUTION (continued):**

	0°	22.5°	45°	67.5°	90°
112.5°	171.7	216.1	563.1	1231.0	1407.1
115°	200.6	242.4	536.6	1136.8	1335.0
117.5°	226.1	265.3	521.0	1033.9	1243.7
120°	246.4	279.3	519.3	975.0	1176.1
122.5°	262.7	295.6	515.3	923.4	1110.1
125°	283.1	314.0	512.2	850.0	1016.3
127.5°	305.3	334.2	510.6	806.1	943.1
130°	316.7	345.6	508.1	775.6	895.1
132.5°	328.9	357.0	508.1	751.8	861.7
135°	346.2	375.1	506.1	718.0	811.6
137.5°	362.5	390.6	505.9	689.4	770.2
140°	374.7	403.6	505.1	665.7	743.4
142.5°	388.6	412.7	507.5	646.8	716.5
145°	408.3	429.2	510.2	621.4	677.2
147.5°	425.2	445.6	514.6	595.8	644.0
150°	439.9	453.8	516.3	587.3	621.2
152.5°	451.3	466.0	517.9	575.8	607.3
155°	466.4	477.3	522.4	561.6	584.5
157.5°	485.1	491.7	523.4	555.1	571.5
160°	494.9	499.9	527.5	550.2	564.1
162.5°	500.6	506.4	528.3	546.1	556.8
165°	515.3	517.2	528.5	539.9	547.8
167.5°	525.2	523.4	533.2	538.3	541.5
170°	528.5	527.5	531.5	532.7	536.6
172.5°	535.8	532.4	534.0	531.0	534.2
175°	539.7	536.7	534.6	531.5	527.5
177.5°	541.3	536.5	534.0	530.8	531.5
180°	535.6	535.6	535.6	535.6	535.6

(END OF REPORT)