

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: CORELITE

Report Number: P521864

Luminaire Tested: **SQ4-WB-0U-050D-92765-1D-UNV-STD-W-4 (4500K)**

Issue Date: 5/5/2021

Test Information

Test Method: LM-79-08
Report Number: P521864
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2009-966-13)
Test Lab: INNOVATION CENTER
Issue Date: 5/5/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: CORELITE
Catalog Number: SQ4-WB-0U-050D-92765-1D-UNV-STD-W-4 (4500K)
Description: CORELITE SQ4 SUSPENDED LED LUMINAIRE WITH WHITE BAFFLE
DOWNLIGHT 500 LUMENS PER FOOT
DIRECT ONLY
Light Source: 2700K/65000K CCT, 90 CRI LEDS, TUNED TO 4500K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 1803.6 lumens
Efficiency: N/A
Efficacy: 87.1 lumens/watt
Spacing Criteria (0/90/45): 0.89 / 1 / 1.02
Luminous Opening: Rectangular (W 0.29' x L: 4' x H: 0')
CIE Type: Direct

Input Watts (W): 20.7
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P521864

CATALOG NUMBER: SQ4-WB-OU-050D-92765-1D-UNV-STD-W-4 (4500K)

Luminous Intensity Polar Plot





TEST NUMBER: P521864

CATALOG NUMBER: SQ4-WB-OU-050D-92765-1D-UNV-STD-W-4 (4500K)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	111	107	104	101	109	105	102	99	101	99	96		97	95	93		94	92	91	89
2	103	97	91	87	101	95	90	86	92	87	84		88	85	82		85	83	80	78
3	96	87	81	75	94	86	80	75	83	78	73		80	76	72		78	74	71	69
4	89	79	72	66	87	78	71	66	76	70	65		74	68	64		71	67	64	62
5	83	72	65	59	81	71	64	59	69	63	58		67	62	58		66	61	57	55
6	78	66	59	53	76	65	58	53	64	57	53		62	56	52		61	56	52	50
7	73	61	53	48	71	60	53	48	59	52	48		58	52	47		56	51	47	45
8	68	57	49	44	67	56	49	44	55	48	44		53	48	43		52	47	43	41
9	64	53	45	40	63	52	45	40	51	45	40		50	44	40		49	44	40	38
10	61	49	42	37	60	48	42	37	48	41	37		47	41	37		46	41	37	35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	11419	11419	11419
5°	11277	11237	11302
10°	10654	10751	11001
15°	9835	10064	10515
20°	8932	9268	9881
25°	8011	8448	9206
30°	7163	7631	8506
35°	6263	6716	7677
40°	5272	5691	6646
45°	4351	4726	5548
50°	3633	3960	4623
55°	3084	3399	3817
60°	2635	2947	3046
65°	2098	2478	1969
70°	1861	1934	1200
75°	1722	1568	734
80°	1589	1445	632
85°	1440	1323	519



TEST NUMBER: P521864

CATALOG NUMBER: SQ4-WB-OU-050D-92765-1D-UNV-STD-W-4 (4500K)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	113.5	6.3
10°-20°	295.3	16.4
20°-30°	382.5	21.2
30°-40°	374.5	20.8
40°-50°	286.7	15.9
50°-60°	191.0	10.6
60°-70°	104.3	5.8
70°-80°	43.4	2.4
80°-90°	12.3	0.7
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	791.3	43.9
0°-40°	1165.9	64.6
0°-60°	1643.6	91.1
0°-90°	1803.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1803.6	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1238	1238	1238	1238	1238	
5°	1218	1205	1213	1216	1220	113
15°	1030	1026	1054	1082	1101	288
25°	787	789	830	866	904	362
35°	556	559	596	636	682	346
45°	334	340	362	390	425	260
55°	192	200	211	219	237	174
65°	96	104	114	99	90	100
75°	48	48	44	30	21	52
85°	14	14	12	8	5	15
90°	0	0	0	0	0	



TEST NUMBER: P521864

CATALOG NUMBER: SQ4-WB-OU-050D-92765-1D-UNV-STD-W-4 (4500K)

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1237.7	1237.7	1237.7	1237.7	1237.7
2.5°	1240.8	1229.7	1232.5	1232.4	1229.0
5°	1217.6	1205.4	1213.3	1216.1	1220.3
7.5°	1172.4	1163.2	1177.5	1188.2	1196.8
10°	1137.2	1129.3	1147.6	1163.0	1174.2
12.5°	1096.4	1089.7	1112.4	1133.1	1147.7
15°	1029.7	1026.0	1053.6	1082.3	1100.9
17.5°	958.4	956.5	988.2	1021.7	1045.5
20°	909.7	909.2	943.9	978.7	1006.4
22.5°	860.6	861.8	898.3	934.5	966.0
25°	786.9	789.1	829.9	866.0	904.3
27.5°	718.8	719.8	762.0	800.2	840.9
30°	672.4	675.0	716.3	755.9	798.4
32.5°	625.9	628.9	669.4	710.3	753.6
35°	556.1	558.8	596.3	636.5	681.6
37.5°	484.2	487.8	521.2	559.1	603.5
40°	437.7	443.0	472.5	508.2	551.8
42.5°	393.0	399.6	426.9	460.8	500.1
45°	333.5	339.8	362.2	389.7	425.2
47.5°	282.2	289.5	306.7	330.4	360.7
50°	253.1	260.0	275.9	293.4	322.1
52.5°	227.4	234.4	248.5	262.0	286.4
55°	191.7	199.7	211.3	219.3	237.3
57.5°	162.4	170.0	179.2	182.8	193.8
60°	142.8	151.3	159.7	159.3	165.1
62.5°	125.0	132.2	140.6	134.8	135.1
65°	96.1	104.1	113.5	99.2	90.2
67.5°	77.7	79.4	89.1	69.2	58.4
70°	69.0	69.0	71.7	53.6	44.5
72.5°	60.7	60.7	58.2	43.6	34.1
75°	48.3	48.3	44.0	30.2	20.6
77.5°	37.3	36.8	33.7	22.5	15.0
80°	29.9	29.9	27.2	17.8	11.9
82.5°	23.4	23.4	21.1	13.9	8.9
85°	13.6	13.6	12.5	8.1	4.9
87.5°	4.8	4.8	4.3	2.6	2.2
90°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)