

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: CORELITE

Report Number: P521876

Luminaire Tested: **SQ4-WB-0U-075D-92765-1D-UNV-STD-W-4 (4000K)**

Issue Date: 5/5/2021

**Test Information**


Test Method: LM-79-08  
Report Number: P521876  
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2009-966-13)  
Test Lab: INNOVATION CENTER  
Issue Date: 5/5/2021  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: CORELITE  
Catalog Number: SQ4-WB-0U-075D-92765-1D-UNV-STD-W-4 (4000K)  
Description: CORELITE SQ4 SUSPENDED LED LUMINAIRE WITH WHITE BAFFLE  
DOWNLIGHT 750 LUMENS PER FOOT  
DIRECT ONLY  
Light Source: 2700K/65000K CCT, 90 CRI LEDS, TUNED TO 4000K CCT  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 2658.2 lumens  
Efficiency: N/A  
Efficacy: 83.3 lumens/watt  
Spacing Criteria (0/90/45): 0.89 / 1 / 1.02  
Luminous Opening: Rectangular (W 0.29' x L: 4' x H: 0')  
CIE Type: Direct  
  
Input Watts (W): 31.9  
Input Voltage (V): 120  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P521876  
CATALOG NUMBER: SQ4-WB-OU-075D-92765-1D-UNV-STD-W-4 (4000K)

### Luminous Intensity Polar Plot





TEST NUMBER: P521876

CATALOG NUMBER: SQ4-WB-OU-075D-92765-1D-UNV-STD-W-4 (4000K)

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20					20					20					20					20	
RC	80					70					50					30					10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100				100
1	111	107	104	101	109	105	102	99	101	99	96	97	95	93	94	92	91	89				89
2	103	97	91	87	101	95	90	86	92	87	84	88	85	82	85	83	80	78				78
3	96	87	81	75	94	86	80	75	83	78	73	80	76	72	78	74	71	69				69
4	89	79	72	66	87	78	71	66	76	70	65	74	68	64	71	67	64	62				62
5	83	72	65	59	81	71	64	59	69	63	58	67	62	58	66	61	57	55				55
6	78	66	59	53	76	65	58	53	64	57	53	62	56	52	61	56	52	50				50
7	73	61	53	48	71	60	53	48	59	52	48	58	52	47	56	51	47	45				45
8	68	57	49	44	67	56	49	44	55	48	44	53	48	43	52	47	43	41				41
9	64	53	45	40	63	52	45	40	51	45	40	50	44	40	49	44	40	38				38
10	61	49	42	37	60	48	42	37	48	41	37	47	41	37	46	41	37	35				35

**AVERAGE LUMINANCE (cd/sqm):**

	0°	45°	90°
0°	16830	16830	16830
5°	16621	16561	16658
10°	15703	15845	16213
15°	14497	14833	15498
20°	13164	13659	14563
25°	11808	12451	13567
30°	10558	11248	12536
35°	9232	9899	11315
40°	7771	8387	9795
45°	6413	6966	8178
50°	5354	5836	6814
55°	4546	5009	5627
60°	3884	4342	4489
65°	3093	3652	2901
70°	2743	2851	1770
75°	2538	2310	1084
80°	2338	2125	935
85°	2117	1948	762



TEST NUMBER: P521876

CATALOG NUMBER: SQ4-WB-OU-075D-92765-1D-UNV-STD-W-4 (4000K)

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	167.3	6.3
10°-20°	435.2	16.4
20°-30°	563.7	21.2
30°-40°	552.0	20.8
40°-50°	422.6	15.9
50°-60°	281.6	10.6
60°-70°	153.7	5.8
70°-80°	64.0	2.4
80°-90°	18.1	0.7
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1166.3	43.9
0°-40°	1718.3	64.6
0°-60°	2422.4	91.1
0°-90°	2658.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2658.2	100.0

**CANDELA DISTRIBUTION:**

	0°	22.5°	45°	67.5°	90°	Flux
0°	1824	1824	1824	1824	1824	
5°	1795	1777	1788	1792	1799	167
15°	1518	1512	1553	1595	1622	424
25°	1160	1163	1223	1276	1333	533
35°	820	824	879	938	1005	510
45°	492	501	534	574	627	383
55°	283	294	311	323	350	256
65°	142	153	167	146	133	147
75°	71	71	65	44	30	76
85°	20	20	18	12	7	23
90°	0	0	0	0	0	



TEST NUMBER: P521876

CATALOG NUMBER: SQ4-WB-OU-075D-92765-1D-UNV-STD-W-4 (4000K)

**CANDELA DISTRIBUTION (FULL):**

	0°	22.5°	45°	67.5°	90°
0°	1824.2	1824.2	1824.2	1824.2	1824.2
2.5°	1828.7	1812.4	1816.5	1816.4	1811.4
5°	1794.6	1776.6	1788.2	1792.3	1798.6
7.5°	1728.0	1714.4	1735.5	1751.2	1763.9
10°	1676.1	1664.4	1691.3	1714.1	1730.6
12.5°	1615.9	1606.1	1639.5	1670.1	1691.5
15°	1517.7	1512.2	1552.9	1595.1	1622.5
17.5°	1412.5	1409.8	1456.5	1505.8	1540.9
20°	1340.8	1340.0	1391.2	1442.5	1483.2
22.5°	1268.4	1270.1	1323.9	1377.3	1423.7
25°	1159.9	1163.0	1223.1	1276.4	1332.7
27.5°	1059.5	1060.9	1123.0	1179.3	1239.4
30°	991.0	994.9	1055.8	1114.0	1176.7
32.5°	922.4	927.0	986.6	1046.8	1110.7
35°	819.7	823.6	878.9	938.0	1004.6
37.5°	713.7	719.0	768.1	824.0	889.5
40°	645.2	653.0	696.4	749.1	813.3
42.5°	579.2	588.9	629.2	679.1	737.1
45°	491.5	500.9	533.9	574.3	626.8
47.5°	415.9	426.7	452.1	486.9	531.7
50°	373.0	383.2	406.6	432.4	474.7
52.5°	335.2	345.4	366.3	386.2	422.2
55°	282.6	294.3	311.4	323.2	349.8
57.5°	239.3	250.6	264.1	269.5	285.6
60°	210.5	223.0	235.3	234.7	243.3
62.5°	184.3	194.9	207.2	198.7	199.2
65°	141.7	153.4	167.3	146.2	132.9
67.5°	114.5	117.0	131.3	101.9	86.1
70°	101.7	101.7	105.7	78.9	65.6
72.5°	89.5	89.5	85.8	64.2	50.3
75°	71.2	71.2	64.8	44.5	30.4
77.5°	54.9	54.3	49.6	33.2	22.1
80°	44.0	44.0	40.0	26.2	17.6
82.5°	34.4	34.4	31.1	20.5	13.1
85°	20.0	20.0	18.4	11.9	7.2
87.5°	7.0	7.0	6.4	3.8	3.2
90°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)