

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: CORELITE

Report Number: P521878

Luminaire Tested: **SQ4-WB-0U-075D-92765-1D-UNV-STD-W-4 (5000K)**

Issue Date: 5/5/2021

Test Information

Test Method: LM-79-08
Report Number: P521878
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2009-966-13)
Test Lab: INNOVATION CENTER
Issue Date: 5/5/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: CORELITE
Catalog Number: SQ4-WB-0U-075D-92765-1D-UNV-STD-W-4 (5000K)
Description: CORELITE SQ4 SUSPENDED LED LUMINAIRE WITH WHITE BAFFLE
DOWNLIGHT 750 LUMENS PER FOOT
DIRECT ONLY
Light Source: 2700K/65000K CCT, 90 CRI LEDS, TUNED TO 5000K CCT
Ballast/Driver: ELECTRONIC DRIVER


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2731.0 lumens
Efficiency: N/A
Efficacy: 85.9 lumens/watt
Spacing Criteria (0/90/45): 0.89 / 1 / 1.02
Luminous Opening: Rectangular (W 0.29' x L: 4' x H: 0')
CIE Type: Direct

Input Watts (W): 31.8
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P521878
CATALOG NUMBER: SQ4-WB-0U-075D-92765-1D-UNV-STD-W-4 (5000K)

Luminous Intensity Polar Plot





TEST NUMBER: P521878

CATALOG NUMBER: SQ4-WB-OU-075D-92765-1D-UNV-STD-W-4 (5000K)

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	111	107	104	101	109	105	102	99	101	99	96		97	95	93		94	92	91	89
2	103	97	91	87	101	95	90	86	92	87	84		88	85	82		85	83	80	78
3	96	87	81	75	94	86	80	75	83	78	73		80	76	72		78	74	71	69
4	89	79	72	66	87	78	71	66	76	70	65		74	68	64		71	67	64	62
5	83	72	65	59	81	71	64	59	69	63	58		67	62	58		66	61	57	55
6	78	66	59	53	76	65	58	53	64	57	53		62	56	52		61	56	52	50
7	73	61	53	48	71	60	53	48	59	52	48		58	52	47		56	51	47	45
8	68	57	49	44	67	56	49	44	55	48	44		53	48	43		52	47	43	41
9	64	53	45	40	63	52	45	40	51	45	40		50	44	40		49	44	40	38
10	61	49	42	37	60	48	42	37	48	41	37		47	41	37		46	41	37	35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	17292	17292	17292
5°	17075	17015	17113
10°	16133	16279	16656
15°	14893	15239	15922
20°	13525	14033	14961
25°	12130	12792	13938
30°	10846	11556	12879
35°	9485	10171	11625
40°	7983	8617	10063
45°	6588	7157	8401
50°	5500	5997	7000
55°	4670	5146	5781
60°	3991	4462	4613
65°	3179	3753	2980
70°	2816	2930	1818
75°	2609	2374	1112
80°	2402	2184	962
85°	2181	2001	783



TEST NUMBER: P521878

CATALOG NUMBER: SQ4-WB-OU-075D-92765-1D-UNV-STD-W-4 (5000K)

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	171.9	6.3
10°-20°	447.1	16.4
20°-30°	579.2	21.2
30°-40°	567.1	20.8
40°-50°	434.1	15.9
50°-60°	289.3	10.6
60°-70°	157.9	5.8
70°-80°	65.8	2.4
80°-90°	18.6	0.7
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1198.2	43.9
0°-40°	1765.3	64.6
0°-60°	2488.8	91.1
0°-90°	2731.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2731.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1874	1874	1874	1874	1874	
5°	1844	1825	1837	1841	1848	172
15°	1559	1554	1595	1639	1667	435
25°	1192	1195	1257	1311	1369	548
35°	842	846	903	964	1032	524
45°	505	515	548	590	644	394
55°	290	302	320	332	359	263
65°	146	158	172	150	136	151
75°	73	73	67	46	31	78
85°	21	21	19	12	7	23
90°	0	0	0	0	0	



TEST NUMBER: P521878

CATALOG NUMBER: SQ4-WB-OU-075D-92765-1D-UNV-STD-W-4 (5000K)

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1874.2	1874.2	1874.2	1874.2	1874.2
2.5°	1878.8	1862.0	1866.3	1866.1	1861.0
5°	1843.7	1825.2	1837.2	1841.4	1847.8
7.5°	1775.3	1761.3	1783.0	1799.1	1812.2
10°	1722.0	1710.0	1737.6	1761.1	1777.9
12.5°	1660.2	1650.1	1684.4	1715.8	1737.8
15°	1559.2	1553.6	1595.4	1638.8	1666.9
17.5°	1451.1	1448.4	1496.4	1547.0	1583.0
20°	1377.5	1376.7	1429.3	1482.0	1523.8
22.5°	1303.1	1304.9	1360.2	1415.0	1462.7
25°	1191.6	1194.8	1256.6	1311.3	1369.2
27.5°	1088.5	1089.9	1153.8	1211.6	1273.3
30°	1018.1	1022.1	1084.7	1144.5	1208.9
32.5°	947.7	952.4	1013.6	1075.5	1141.1
35°	842.1	846.1	903.0	963.7	1032.1
37.5°	733.2	738.7	789.1	846.6	913.8
40°	662.8	670.9	715.5	769.6	835.5
42.5°	595.1	605.0	646.4	697.7	757.2
45°	504.9	514.6	548.5	590.0	643.9
47.5°	427.3	438.4	464.5	500.2	546.2
50°	383.2	393.7	417.8	444.2	487.7
52.5°	344.4	354.9	376.3	396.7	433.7
55°	290.3	302.4	319.9	332.0	359.4
57.5°	245.9	257.5	271.4	276.9	293.4
60°	216.3	229.1	241.8	241.2	250.0
62.5°	189.3	200.2	212.8	204.1	204.6
65°	145.6	157.6	171.9	150.2	136.5
67.5°	117.6	120.2	134.9	104.7	88.5
70°	104.4	104.4	108.6	81.1	67.4
72.5°	91.9	91.9	88.2	66.0	51.6
75°	73.2	73.2	66.6	45.7	31.2
77.5°	56.4	55.8	51.0	34.1	22.7
80°	45.2	45.2	41.1	26.9	18.1
82.5°	35.4	35.4	31.9	21.0	13.5
85°	20.6	20.6	18.9	12.2	7.4
87.5°	7.2	7.2	6.6	3.9	3.3
90°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)