

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: CORELITE

Report Number: P521886

Luminaire Tested: **SQ4-WB-0U-100D-92765-1D-UNV-STD-W-4 (2700K)**

Issue Date: 5/5/2021

**Test Information**

Test Method: LM-79-08  
Report Number: P521886  
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2009-966-13)  
Test Lab: INNOVATION CENTER  
Issue Date: 5/5/2021  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: CORELITE  
Catalog Number: SQ4-WB-0U-100D-92765-1D-UNV-STD-W-4 (2700K)  
Description: CORELITE SQ4 SUSPENDED LED LUMINAIRE WITH WHITE BAFFLE  
DOWNLIGHT 1000 LUMENS PER FOOT  
DIRECT ONLY  
Light Source: 2700K/65000K CCT, 90 CRI LEDS, TUNED TO 2700K CCT  
Ballast/Driver: ELECTRONIC DRIVER


**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 3283.2 lumens  
Efficiency: N/A  
Efficacy: 77.6 lumens/watt  
Spacing Criteria (0/90/45): 0.89 / 1 / 1.02  
Luminous Opening: Rectangular (W 0.29' x L: 4' x H: 0')  
CIE Type: Direct

Input Watts (W): 42.3  
Input Voltage (V): 120  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P521886  
CATALOG NUMBER: SQ4-WB-OU-100D-92765-1D-UNV-STD-W-4 (2700K)

### Luminous Intensity Polar Plot





TEST NUMBER: P521886

CATALOG NUMBER: SQ4-WB-OU-100D-92765-1D-UNV-STD-W-4 (2700K)

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	111	107	104	101	109	105	102	99	101	99	96	97	95	93	94	92	91	89
2	103	97	91	87	101	95	90	86	92	87	84	88	85	82	85	83	80	78
3	96	87	81	75	94	86	80	75	83	78	73	80	76	72	78	74	71	69
4	89	79	72	66	87	78	71	66	76	70	65	74	68	64	71	67	64	62
5	83	72	65	59	81	71	64	59	69	63	58	67	62	58	66	61	57	55
6	78	66	59	53	76	65	58	53	64	57	53	62	56	52	61	56	52	50
7	73	61	53	48	71	60	53	48	59	52	48	58	52	47	56	51	47	45
8	68	57	49	44	67	56	49	44	55	48	44	53	48	43	52	47	43	41
9	64	53	45	40	63	52	45	40	51	45	40	50	44	40	49	44	40	38
10	61	49	42	37	60	48	42	37	48	41	37	47	41	37	46	41	37	35

**AVERAGE LUMINANCE (cd/sqm):**

	0°	45°	90°
0°	20788	20788	20788
5°	20528	20455	20574
10°	19395	19571	20024
15°	17905	18320	19142
20°	16259	16871	17986
25°	14583	15378	16757
30°	13039	13892	15483
35°	11403	12226	13974
40°	9597	10359	12098
45°	7920	8604	10100
50°	6613	7208	8415
55°	5614	6186	6949
60°	4798	5364	5545
65°	3820	4510	3582
70°	3388	3520	2188
75°	3137	2855	1340
80°	2890	2625	1158
85°	2615	2403	942



TEST NUMBER: P521886

CATALOG NUMBER: SQ4-WB-OU-100D-92765-1D-UNV-STD-W-4 (2700K)

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	206.7	6.3
10°-20°	537.5	16.4
20°-30°	696.3	21.2
30°-40°	681.8	20.8
40°-50°	521.9	15.9
50°-60°	347.8	10.6
60°-70°	189.8	5.8
70°-80°	79.1	2.4
80°-90°	22.4	0.7
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1440.5	43.9
0°-40°	2122.3	64.6
0°-60°	2992.0	91.1
0°-90°	3283.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3283.2	100.0

**CANDELA DISTRIBUTION:**

	0°	22.5°	45°	67.5°	90°	Flux
0°	2253	2253	2253	2253	2253	
5°	2216	2194	2209	2214	2222	206
15°	1874	1868	1918	1970	2004	523
25°	1432	1436	1511	1576	1646	659
35°	1012	1017	1086	1159	1241	629
45°	607	619	659	709	774	473
55°	349	364	385	399	432	316
65°	175	190	207	180	164	182
75°	88	88	80	55	38	94
85°	25	25	23	15	9	28
90°	0	0	0	0	0	



TEST NUMBER: P521886

CATALOG NUMBER: SQ4-WB-OU-100D-92765-1D-UNV-STD-W-4 (2700K)

**CANDELA DISTRIBUTION (FULL):**

	0°	22.5°	45°	67.5°	90°
0°	2253.1	2253.1	2253.1	2253.1	2253.1
2.5°	2258.6	2238.5	2243.6	2243.5	2237.3
5°	2216.5	2194.3	2208.6	2213.7	2221.5
7.5°	2134.3	2117.5	2143.6	2162.9	2178.6
10°	2070.2	2055.7	2089.0	2117.1	2137.4
12.5°	1995.9	1983.7	2024.9	2062.7	2089.2
15°	1874.5	1867.7	1918.0	1970.1	2004.0
17.5°	1744.6	1741.3	1798.9	1859.8	1903.1
20°	1656.0	1655.0	1718.3	1781.7	1831.9
22.5°	1566.6	1568.7	1635.2	1701.2	1758.4
25°	1432.5	1436.4	1510.6	1576.5	1646.1
27.5°	1308.6	1310.3	1387.1	1456.6	1530.8
30°	1223.9	1228.8	1304.0	1376.0	1453.3
32.5°	1139.3	1144.9	1218.6	1293.0	1371.8
35°	1012.4	1017.2	1085.5	1158.6	1240.7
37.5°	881.5	888.0	948.7	1017.8	1098.6
40°	796.8	806.5	860.1	925.2	1004.5
42.5°	715.4	727.4	777.1	838.8	910.3
45°	607.0	618.6	659.4	709.3	774.1
47.5°	513.7	527.0	558.4	601.4	656.7
50°	460.7	473.3	502.2	534.1	586.3
52.5°	414.0	426.6	452.4	476.9	521.4
55°	349.0	363.5	384.6	399.2	432.0
57.5°	295.6	309.5	326.3	332.8	352.7
60°	260.0	275.5	290.7	289.9	300.5
62.5°	227.6	240.7	255.9	245.4	246.0
65°	175.0	189.5	206.6	180.5	164.1
67.5°	141.4	144.5	162.1	125.9	106.4
70°	125.6	125.6	130.5	97.5	81.1
72.5°	110.5	110.5	106.0	79.3	62.1
75°	88.0	88.0	80.1	55.0	37.6
77.5°	67.8	67.0	61.3	41.0	27.3
80°	54.4	54.4	49.4	32.4	21.8
82.5°	42.5	42.5	38.4	25.3	16.2
85°	24.7	24.7	22.7	14.7	8.9
87.5°	8.7	8.7	7.9	4.7	4.0
90°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)