

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: CORELITE

Report Number: P521991

Luminaire Tested: **SQ4-WB-125U-100D-92765-1D-UNV-STD-W-4 (3000K)**

Issue Date: 5/5/2021

**Test Information**

Test Method: LM-79-08  
Report Number: P521991  
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2101-105-51,  
Test Lab: INNOVATION CENTER  
Issue Date: 5/5/2021  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: CORELITE  
Catalog Number: SQ4-WB-125U-100D-92765-1D-UNV-STD-W-4 (3000K)  
Description: CORELITE SQ4 SUSPENDED LED LUMINAIRE WITH WHITE BAFFLE  
DOWNLIGHT 1000 LUMENS PER FOOT  
UPLIGHT 1250 LUMENS PER FOOT  
Light Source: 2700K/65000K CCT, 90 CRI LEDS, TUNED TO 3000K CCT  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 8714.4 lumens  
Efficiency: N/A  
Efficacy: 103.9 lumens/watt  
Spacing Criteria (0/90/45): 0.89 / 1 / 1.02  
Luminous Opening: Rectangular (W 0.29' x L: 4' x H: 0')  
CIE Type: Semi-Indirect

Input Watts (W): 83.9  
Input Voltage (V): 120  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P521991

CATALOG NUMBER: SQ4-WB-125U-100D-92765-1D-UNV-STD-W-4 (3000K)

### Luminous Intensity Polar Plot





TEST NUMBER: P521991

CATALOG NUMBER: SQ4-WB-125U-100D-92765-1D-UNV-STD-W-4 (3000K)

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	104	104	104	104	95	95	95	95	77	77	77	61	61	61	46	46	46	38
1	96	92	89	86	87	84	81	78	69	67	65	55	53	52	42	41	40	34
2	88	82	76	71	80	74	70	66	61	58	55	49	47	45	38	36	35	30
3	81	72	66	61	74	66	61	56	55	51	47	44	41	39	34	33	31	27
4	75	65	57	52	68	59	53	48	49	45	41	40	37	34	31	29	28	24
5	69	58	51	45	63	53	47	42	45	40	36	36	33	30	29	26	25	21
6	64	52	45	40	58	48	42	37	41	36	32	33	30	27	26	24	22	19
7	59	48	40	35	54	44	37	33	37	32	29	30	27	24	24	22	20	17
8	55	43	36	31	50	40	34	29	34	29	26	28	25	22	23	20	18	16
9	51	40	33	28	47	37	31	26	31	27	23	26	23	20	21	19	17	15
10	48	37	30	25	44	34	28	24	29	24	21	24	21	18	20	17	15	14

**AVERAGE LUMINANCE (cd/sqm):**

	0°	45°	90°
0°	21218	21218	21218
5°	20954	20879	21000
10°	19797	19977	20439
15°	18275	18699	19538
20°	16596	17220	18359
25°	14885	15697	17104
30°	13309	14180	15803
35°	11638	12480	14265
40°	9797	10573	12349
45°	8084	8782	10309
50°	6750	7358	8589
55°	5730	6315	7094
60°	4897	5475	5661
65°	3899	4604	3657
70°	3458	3593	2231
75°	3201	2912	1365
80°	2949	2683	1180
85°	2668	2456	963



TEST NUMBER: P521991

CATALOG NUMBER: SQ4-WB-125U-100D-92765-1D-UNV-STD-W-4 (3000K)

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	210.9	2.4
10°-20°	548.7	6.3
20°-30°	710.7	8.2
30°-40°	696.0	8.0
40°-50°	532.7	6.1
50°-60°	355.0	4.1
60°-70°	193.7	2.2
70°-80°	80.7	0.9
80°-90°	22.9	0.3
90°-100°	393.4	4.5
100°-110°	1119.5	12.8
110°-120°	1072.5	12.3
120°-130°	848.9	9.7
130°-140°	681.4	7.8
140°-150°	533.4	6.1
150°-160°	390.3	4.5
160°-170°	241.8	2.8
170°-180°	82.0	0.9
0°-30°	1470.3	16.9
0°-40°	2166.3	24.9
0°-60°	3054.0	35.0
0°-90°	3351.2	38.5
90°-120°	2585.4	29.7
90°-150°	4649.1	53.3
90°-180°	5363.0	61.5
0°-180°	8714.4	100.0

**CANDELA DISTRIBUTION:**

	0°	22.5°	45°	67.5°	90°	Flux
0°	2300	2300	2300	2300	2300	
5°	2262	2240	2254	2260	2268	210
15°	1913	1906	1958	2011	2046	534
25°	1462	1466	1542	1609	1680	672
35°	1033	1038	1108	1183	1266	642
45°	620	631	673	724	790	483
55°	356	371	393	407	441	323
65°	179	193	211	184	168	186
75°	90	90	82	56	38	96
85°	25	25	23	15	9	27
90°	0	0	0	0	0	3
95°	43	170	762	264	162	49
105°	174	264	1141	2015	1916	184
115°	323	391	865	1832	2152	318
125°	456	506	826	1370	1638	408
135°	558	605	816	1157	1308	431
145°	658	692	822	1002	1092	411
155°	752	769	842	905	942	348
165°	831	834	852	870	883	234
175°	870	865	862	857	850	82
180°	863	863	863	863	863	

TEST NUMBER: P521991

CATALOG NUMBER: SQ4-WB-125U-100D-92765-1D-UNV-STD-W-4 (3000K)

**CANDELA DISTRIBUTION (FULL):**

	0°	22.5°	45°	67.5°	90°
0°	2299.8	2299.8	2299.8	2299.8	2299.8
2.5°	2305.5	2284.9	2290.1	2290.0	2283.7
5°	2262.5	2239.8	2254.4	2259.6	2267.5
7.5°	2178.5	2161.3	2188.0	2207.7	2223.7
10°	2113.1	2098.3	2132.3	2161.0	2181.7
12.5°	2037.2	2024.8	2066.9	2105.5	2132.5
15°	1913.3	1906.4	1957.7	2011.0	2045.5
17.5°	1780.7	1777.4	1836.2	1898.4	1942.6
20°	1690.3	1689.3	1753.9	1818.6	1869.9
22.5°	1599.1	1601.2	1669.1	1736.4	1794.8
25°	1462.2	1466.2	1541.9	1609.2	1680.2
27.5°	1335.7	1337.5	1415.8	1486.8	1562.5
30°	1249.3	1254.2	1331.0	1404.5	1483.4
32.5°	1162.9	1168.6	1243.9	1319.8	1400.3
35°	1033.3	1038.3	1108.0	1182.6	1266.5
37.5°	899.7	906.4	968.4	1038.9	1121.3
40°	813.4	823.2	877.9	944.4	1025.3
42.5°	730.2	742.4	793.2	856.2	929.2
45°	619.6	631.4	673.1	724.0	790.1
47.5°	524.3	538.0	570.0	613.8	670.3
50°	470.3	483.1	512.6	545.1	598.4
52.5°	422.6	435.4	461.8	486.8	532.2
55°	356.2	371.0	392.6	407.4	441.0
57.5°	301.7	315.9	333.0	339.7	360.1
60°	265.4	281.2	296.7	295.9	306.8
62.5°	232.3	245.7	261.2	250.5	251.1
65°	178.6	193.4	210.9	184.3	167.5
67.5°	144.3	147.5	165.5	128.5	108.6
70°	128.2	128.2	133.2	99.5	82.7
72.5°	112.8	112.8	108.2	80.9	63.4
75°	89.8	89.8	81.7	56.1	38.3
77.5°	69.2	68.4	62.6	41.9	27.9
80°	55.5	55.5	50.5	33.1	22.2
82.5°	43.4	43.4	39.2	25.8	16.5
85°	25.2	25.2	23.2	15.0	9.1
87.5°	8.9	8.9	8.1	4.8	4.0
90°	0.0	0.0	0.0	0.0	0.0
92.5°	13.1	69.6	161.5	47.0	35.5
95°	42.7	169.5	761.6	263.6	162.5
97.5°	78.5	198.5	1173.0	839.3	575.2
100°	103.4	215.8	1262.3	1278.6	984.9
102.5°	131.0	234.3	1242.6	1636.6	1380.1
105°	174.0	263.9	1140.8	2015.1	1915.6
107.5°	217.7	298.2	1022.0	2121.8	2210.4
110°	247.9	323.3	953.7	2080.9	2279.9

TEST NUMBER: P521991

CATALOG NUMBER: SQ4-WB-125U-100D-92765-1D-UNV-STD-W-4 (3000K)

**CANDELA DISTRIBUTION (continued):**

	0°	22.5°	45°	67.5°	90°
112.5°	276.7	348.3	907.7	1984.4	2268.1
115°	323.4	390.8	865.0	1832.5	2151.9
117.5°	364.4	427.6	839.8	1666.5	2004.8
120°	397.2	450.2	837.1	1571.7	1895.9
122.5°	423.5	476.5	830.6	1488.4	1789.5
125°	456.3	506.1	825.6	1370.1	1638.1
127.5°	492.1	538.6	823.0	1299.5	1520.3
130°	510.5	557.0	819.1	1250.2	1442.8
132.5°	530.2	575.4	819.1	1211.8	1389.0
135°	558.1	604.6	815.8	1157.4	1308.2
137.5°	584.3	629.6	815.5	1111.3	1241.6
140°	604.0	650.6	814.2	1073.1	1198.2
142.5°	626.4	665.2	818.1	1042.6	1154.9
145°	658.2	691.9	822.4	1001.7	1091.6
147.5°	685.5	718.2	829.6	960.4	1038.0
150°	709.1	731.6	832.2	946.7	1001.3
152.5°	727.5	751.2	834.8	928.2	978.9
155°	751.8	769.4	842.1	905.3	942.2
157.5°	782.0	792.6	843.7	894.9	921.2
160°	797.7	805.8	850.3	886.9	909.4
162.5°	806.9	816.2	851.6	880.2	897.5
165°	830.6	833.8	851.9	870.3	883.1
167.5°	846.7	843.8	859.5	867.8	872.9
170°	851.9	850.3	856.8	858.6	865.0
172.5°	863.7	858.3	860.8	856.0	861.1
175°	870.0	865.1	861.8	856.7	850.3
177.5°	872.6	864.9	860.8	855.5	856.8
180°	863.4	863.4	863.4	863.4	863.4

(END OF REPORT)