

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: CORELITE

Report Number: P845356

Luminaire Tested: **SQ4P-WB-0U-100D-B50-1D-UNV**

Issue Date: 8/14/2023



Test Information

Test Method: LM-79-08
Report Number: P845356
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P519276)
Test Lab: INNOVATION CENTER
Issue Date: 8/14/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: CORELITE
Catalog Number: SQ4P-WB-0U-100D-B50-1D-UNV
Description: CORELITE SQ4 SUSPENDED LED LUMINAIRE WITH, DIRECT ONLY 1000 LUMENS PER FOOT DOWNLIGHT

Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3089.3 lumens
Efficiency: N/A
Efficacy: 88.5 lumens/watt
Spacing Criteria (0/90/45): 0.89 / 1 / 1.02
Luminous Opening: Rectangular (W 0.29' x L: 4' x H: 0')
CIE Type: Direct

Input Watts (W): 34.9
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P845356

CATALOG NUMBER: SQ4P-WB-0U-100D-B50-1D-UNV

Luminous Intensity Polar Plot





TEST NUMBER: P845356

CATALOG NUMBER: SQ4P-WB-0U-100D-B50-1D-UNV

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	111	107	104	101	109	105	102	99	101	99	96	97	95	93	94	92	91	89																			
2	103	97	91	87	101	95	90	86	92	87	84	88	85	82	85	83	80	78																			
3	96	87	81	75	94	86	80	75	83	78	73	80	76	72	78	74	71	69																			
4	89	79	72	66	87	78	71	66	76	70	65	74	68	64	71	67	64	62																			
5	83	72	65	59	81	71	64	59	69	63	58	67	62	58	66	61	57	55																			
6	78	66	59	53	76	65	58	53	64	57	53	62	56	52	61	56	52	50																			
7	73	61	53	48	71	60	53	48	59	52	48	58	52	47	56	51	47	45																			
8	68	57	49	44	67	56	49	44	55	48	44	53	48	43	52	47	43	41																			
9	64	53	45	40	63	52	45	40	51	45	40	50	44	40	49	44	40	38																			
10	61	49	42	37	60	48	42	37	48	41	37	47	41	37	46	41	37	35																			

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	19560	19560	19560
5°	19317	19247	19360
10°	18249	18415	18842
15°	16846	17239	18012
20°	15299	15873	16924
25°	13723	14471	15768
30°	12271	13071	14568
35°	10728	11503	13151
40°	9029	9747	11384
45°	7452	8095	9504
50°	6221	6783	7916
55°	5282	5820	6537
60°	4515	5047	5218
65°	3596	4244	3369
70°	3186	3313	2058
75°	2948	2688	1262
80°	2720	2476	1089
85°	2445	2276	889



TEST NUMBER: P845356

CATALOG NUMBER: SQ4P-WB-0U-100D-B50-1D-UNV

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	194.5	6.3
10°-20°	505.8	16.4
20°-30°	655.2	21.2
30°-40°	641.6	20.8
40°-50°	491.1	15.9
50°-60°	327.2	10.6
60°-70°	178.6	5.8
70°-80°	74.4	2.4
80°-90°	21.1	0.7
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1355.4	43.9
0°-40°	1997.0	64.6
0°-60°	2815.3	91.1
0°-90°	3089.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3089.3	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2120	2120	2120	2120	2120	
5°	2086	2065	2078	2083	2090	194
15°	1764	1757	1805	1854	1886	493
25°	1348	1352	1422	1483	1549	620
35°	952	957	1021	1090	1168	592
45°	571	582	620	667	728	445
55°	328	342	362	376	406	298
65°	165	178	194	170	154	171
75°	83	83	75	52	35	88
85°	23	23	22	14	8	26
90°	0	0	0	0	0	



TEST NUMBER: P845356

CATALOG NUMBER: SQ4P-WB-OU-100D-B50-1D-UNV

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2120.1	2120.1	2120.1	2120.1	2120.1
2.5°	2125.3	2106.4	2111.2	2111.0	2105.1
5°	2085.7	2064.7	2078.2	2082.9	2090.4
7.5°	2008.2	1992.4	2017.1	2035.1	2049.9
10°	1947.9	1934.3	1965.6	1992.2	2011.2
12.5°	1878.1	1866.4	1905.5	1940.8	1965.9
15°	1763.7	1757.4	1804.8	1853.9	1885.7
17.5°	1641.6	1638.4	1692.7	1750.0	1790.7
20°	1558.2	1557.3	1616.7	1676.5	1723.7
22.5°	1474.1	1476.0	1538.6	1600.7	1654.6
25°	1348.0	1351.6	1421.5	1483.4	1548.9
27.5°	1231.3	1233.1	1305.0	1370.5	1440.4
30°	1151.8	1156.1	1226.9	1294.8	1367.4
32.5°	1072.2	1077.4	1146.7	1216.6	1290.8
35°	952.5	957.2	1021.3	1090.3	1167.6
37.5°	829.3	835.6	892.7	957.5	1033.8
40°	749.7	759.0	809.3	870.6	945.2
42.5°	673.1	684.4	731.2	789.3	856.4
45°	571.1	582.1	620.4	667.4	728.4
47.5°	483.3	495.9	525.4	565.9	617.9
50°	433.4	445.4	472.6	502.5	551.5
52.5°	389.6	401.4	425.7	448.8	490.7
55°	328.4	342.0	361.8	375.7	406.4
57.5°	278.2	291.2	307.0	313.1	331.9
60°	244.7	259.2	273.5	272.8	282.8
62.5°	214.2	226.6	240.7	230.8	231.4
65°	164.7	178.4	194.4	169.9	154.3
67.5°	133.1	135.9	152.5	118.5	100.1
70°	118.1	118.1	122.8	91.8	76.3
72.5°	104.1	104.1	99.9	74.5	58.4
75°	82.7	82.7	75.4	51.8	35.4
77.5°	63.8	63.2	57.7	38.6	25.7
80°	51.2	51.2	46.6	30.6	20.5
82.5°	40.0	40.0	36.0	23.8	15.1
85°	23.1	23.1	21.5	13.9	8.4
87.5°	8.2	8.2	7.3	4.4	3.8
90°	0.0	0.0	0.0	0.0	0.0



Report Generated By 670246072 / DESKTOP-50001EG





— 0°-180° - - 45°-225° - - - - 90°-270°







(END OF REPORT)