

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: CORELITE

Report Number: P937194

Luminaire Tested: SQ4-FB-075U-075D-B2750-1D-UNV-STD-W-8-3500K

Issue Date: 12/17/2024

Test Information

Test Method: LM-79-2019
Report Number: P937194
REPORT IS A COMBINATION OF REPORTS P933518 AND P933786
Test Lab: INNOVATION CENTER
Issue Date: 12/17/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: CORELITE
Catalog Number: SQ4-FB-075U-075D-B2750-1D-UNV-STD-W-8-3500K
Description: CORELITE SQ4 SUSPENDED INDIRECT LED LUMINAIRE WITH Batwing Frosted Continuous Roll L
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 10469.1 lumens
Efficiency: N/A
Efficacy: 123.5 lumens/watt
Spacing Criteria (0/90/45): 0.71 / 2.69 / 2.33
Luminous Opening: Rectangular w/ Sides (W: 0.29' x L: 8' x H: 0.1')
CIE Type: General Diffuse

Input Watts (W): 84.8
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P937194

CATALOG NUMBER: SQ4-FB-075U-075D-B2750-1D-UNV-STD-W-8-3500K

Luminous Intensity Polar Plot



TEST NUMBER: P937194

CATALOG NUMBER: SQ4-FB-075U-075D-B2750-1D-UNV-STD-W-8-3500K

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	106	106	106	106	97	97	97	97	80	80	80	65	65	65	51	51	51			45
1	96	92	88	84	88	84	80	77	70	67	65	57	55	53	44	43	42			37
2	87	79	73	68	79	73	67	63	60	56	53	49	46	44	38	36	35			30
3	79	69	62	56	72	64	57	52	53	48	44	43	39	36	34	31	29			25
4	72	61	53	47	65	56	49	43	46	41	37	38	34	31	30	27	24			21
5	66	54	46	39	60	50	42	37	41	36	31	34	29	26	26	23	21			17
6	60	48	40	34	55	44	37	31	37	31	27	30	26	22	24	21	18			15
7	56	43	35	29	51	40	32	27	33	28	23	27	23	20	21	18	16			13
8	51	39	31	26	47	36	29	24	30	24	21	25	20	17	20	16	14			11
9	48	35	28	23	44	33	26	21	27	22	18	22	18	15	18	15	12			10
10	44	32	25	20	41	30	23	19	25	20	16	21	17	14	16	13	11			9

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2796	2796	2796
5°	2732	3232	3759
10°	2478	4711	6232
15°	2106	6156	7525
20°	1714	7133	7669
25°	1430	7465	7513
30°	1206	7512	7499
35°	1066	7387	7693
40°	929	7225	7893
45°	841	7106	7924
50°	772	6999	7793
55°	739	6843	7447
60°	757	6542	6902
65°	787	6086	6152
70°	839	5307	5197
75°	930	4327	4056
80°	1015	3001	2733
85°	904	1592	1398

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 7924 cd/sqm

TEST NUMBER: P937194

CATALOG NUMBER: SQ4-FB-075U-075D-B2750-1D-UNV-STD-W-8-3500K

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	78.0	0.7
10°-20°	345.6	3.3
20°-30°	604.4	5.8
30°-40°	778.1	7.4
40°-50°	869.1	8.3
50°-60°	832.4	8.0
60°-70°	659.6	6.3
70°-80°	387.9	3.7
80°-90°	111.2	1.1
90°-100°	436.4	4.2
100°-110°	1147.2	11.0
110°-120°	1189.5	11.4
120°-130°	954.1	9.1
130°-140°	748.6	7.2
140°-150°	574.6	5.5
150°-160°	413.8	4.0
160°-170°	253.2	2.4
170°-180°	85.5	0.8
0°-30°	1028.0	9.8
0°-40°	1806.0	17.3
0°-60°	3507.5	33.5
0°-90°	4666.2	44.6
90°-120°	2773.0	26.5
90°-150°	5050.3	48.2
90°-180°	5803.0	55.4
0°-180°	10469.1	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	603	603	603	603	603	
5°	587	630	709	802	831	54
15°	440	812	1368	1659	1711	122
25°	281	921	1630	1702	1704	129
35°	190	880	1535	1622	1686	119
45°	130	702	1357	1554	1624	100
55°	93	446	1151	1337	1374	85
65°	74	236	855	961	975	73
75°	54	145	469	516	517	57
85°	19	45	116	128	130	21
90°	6	17	46	23	23	6
95°	58	226	752	388	264	64
105°	207	313	1268	1925	1796	219
115°	367	446	1016	2026	2313	363
125°	511	572	924	1561	1842	453
135°	608	670	895	1260	1429	471
145°	706	751	884	1075	1160	442
155°	798	820	884	970	998	367
165°	861	872	884	919	930	243
175°	895	895	890	901	901	85
180°	895	895	895	895	895	

TEST NUMBER: P937194

CATALOG NUMBER: SQ4-FB-075U-075D-B2750-1D-UNV-STD-W-8-3500K

CANDELA DISTRIBUTION (FULL):

	0°	10°	20°	22.5°	30°	40°	45°	50°	60°	67.5°	70°
0°	602.7	602.7	602.7	602.7	602.7	602.7	602.7	602.7	602.7	602.7	602.7
2.5°	602.7	602.7	606.6	608.5	612.4	614.3	618.2	622.1	633.7	635.7	639.5
5°	587.2	595.0	620.2	629.8	657.0	693.8	709.3	734.5	786.8	802.3	812.0
7.5°	564.0	581.4	643.4	658.9	726.8	823.6	864.3	918.6	1001.9	1042.6	1075.6
10°	527.1	564.0	674.4	711.2	821.7	969.0	1044.6	1120.3	1246.2	1302.4	1323.8
12.5°	486.4	546.5	707.4	757.8	916.7	1131.9	1223.0	1306.3	1449.7	1525.3	1536.9
15°	439.9	521.3	738.4	812.0	1017.4	1267.5	1368.3	1471.0	1604.8	1659.0	1672.6
17.5°	399.2	501.9	767.4	845.0	1095.0	1389.6	1492.4	1577.6	1686.2	1723.0	1732.7
20°	348.8	470.9	786.8	887.6	1176.5	1478.8	1577.6	1643.5	1717.2	1740.4	1744.3
22.5°	312.0	438.0	798.5	903.1	1230.7	1533.1	1616.4	1668.7	1719.1	1726.9	1728.8
25°	281.0	401.2	796.5	920.6	1277.2	1566.0	1630.0	1668.7	1697.8	1701.7	1701.7
27.5°	251.9	360.5	788.8	924.4	1312.1	1573.8	1624.1	1651.3	1664.8	1672.6	1672.6
30°	226.7	321.7	769.4	916.7	1327.6	1566.0	1606.7	1620.3	1633.8	1645.5	1651.3
32.5°	207.4	284.9	740.3	901.2	1329.6	1546.6	1575.7	1583.4	1602.8	1630.0	1639.6
35°	189.9	248.1	707.4	879.9	1317.9	1515.6	1535.0	1542.7	1581.5	1622.2	1635.8
37.5°	172.5	220.9	664.7	843.0	1300.5	1478.8	1492.4	1505.9	1566.0	1614.5	1630.0
40°	155.0	197.7	614.3	802.3	1273.4	1434.2	1445.8	1467.2	1546.6	1602.8	1618.3
42.5°	141.5	178.3	560.1	759.7	1238.5	1383.8	1401.3	1432.3	1523.4	1583.4	1600.9
45°	129.8	158.9	501.9	701.6	1193.9	1331.5	1356.7	1399.3	1496.2	1554.4	1569.9
47.5°	118.2	145.4	441.9	641.5	1145.5	1279.2	1312.1	1360.6	1459.4	1515.6	1529.2
50°	108.5	131.8	381.8	577.5	1093.0	1223.0	1261.7	1312.1	1412.9	1465.2	1482.7
52.5°	100.8	120.2	325.6	513.6	1033.0	1164.8	1209.4	1261.7	1356.7	1407.1	1418.7
55°	93.0	110.5	277.1	445.7	970.9	1102.8	1151.3	1201.7	1294.7	1337.3	1345.1
57.5°	89.1	102.7	236.4	381.8	905.0	1033.0	1087.2	1133.8	1221.0	1254.0	1261.7
60°	83.3	96.9	205.4	327.5	833.3	967.1	1013.6	1060.1	1133.8	1161.0	1166.8
62.5°	77.5	93.0	182.2	275.2	759.7	889.5	936.1	978.7	1040.7	1060.1	1067.8
65°	73.6	89.1	164.7	236.4	684.1	808.1	854.7	891.5	941.9	961.2	965.1
67.5°	69.8	85.3	151.2	203.5	608.5	726.8	761.6	796.5	835.3	854.7	856.6
70°	64.0	81.4	139.5	180.2	531.0	633.7	662.8	699.6	730.6	740.3	746.1
72.5°	60.1	75.6	131.8	162.8	451.6	544.6	571.7	593.0	620.2	629.8	629.8
75°	54.3	67.8	124.0	145.4	370.2	445.7	469.0	490.3	511.6	515.5	509.7
77.5°	48.4	60.1	106.6	122.1	288.8	352.7	372.1	383.7	401.2	405.0	407.0
80°	40.7	52.3	83.3	95.0	209.3	259.7	273.3	282.9	298.5	298.5	302.3
82.5°	31.0	40.7	60.1	67.8	141.5	178.3	189.9	195.7	205.4	205.4	205.4
85°	19.4	25.2	38.8	44.6	85.3	108.5	116.3	118.2	126.0	127.9	127.9
87.5°	9.7	13.6	25.2	27.1	44.6	56.2	56.2	60.1	60.1	58.1	56.2
90°	6.0	10.9	15.7	16.9	26.5	39.2	45.6	40.6	30.4	22.9	22.9
92.5°	24.0	64.9	105.8	116.0	163.1	225.8	257.2	225.4	161.8	114.1	109.6
95°	57.7	132.5	207.2	225.9	401.1	634.7	751.6	670.6	508.8	387.5	373.7
97.5°	99.7	165.7	231.7	248.2	540.3	929.9	1124.6	1073.5	971.2	894.6	868.4
100°	132.2	192.0	251.8	266.8	591.0	1023.3	1239.4	1243.1	1250.6	1256.2	1225.0
102.5°	159.8	215.6	271.4	285.4	614.2	1052.6	1271.8	1336.9	1467.3	1565.0	1538.3
105°	206.7	254.0	301.2	313.0	631.4	1055.9	1268.2	1414.3	1706.3	1925.4	1911.1
107.5°	254.8	298.8	342.8	353.9	634.6	1008.9	1196.1	1399.8	1807.3	2112.9	2116.4
110°	287.2	326.9	366.7	376.7	629.8	967.3	1136.1	1363.8	1819.3	2161.0	2175.9

TEST NUMBER: P937194

CATALOG NUMBER: SQ4-FB-075U-075D-B2750-1D-UNV-STD-W-8-3500K

CANDELA DISTRIBUTION (continued):

	0°	10°	20°	22.5°	30°	40°	45°	50°	60°	67.5°	70°
112.5°	319.0	356.9	394.8	404.3	629.9	930.9	1081.4	1314.5	1780.7	2130.3	2153.3
115°	367.1	402.0	437.0	445.7	635.8	889.2	1015.9	1240.4	1689.5	2026.4	2058.3
117.5°	414.5	446.3	478.1	486.1	647.7	863.1	970.8	1173.5	1578.8	1882.8	1918.0
120°	442.2	472.0	501.9	509.4	657.2	854.3	952.8	1138.0	1508.3	1786.1	1820.4
122.5°	469.2	499.4	529.6	537.1	671.0	849.6	939.0	1105.7	1439.3	1689.4	1723.2
125°	510.7	538.2	565.6	572.5	689.6	845.8	923.9	1065.6	1348.8	1561.3	1592.6
127.5°	544.3	572.1	599.8	606.8	708.3	843.7	911.3	1033.0	1276.2	1458.6	1484.9
130°	562.3	592.2	622.1	629.6	721.9	845.1	906.6	1014.8	1231.4	1393.8	1418.1
132.5°	580.9	610.9	640.8	648.3	733.0	845.8	902.3	999.2	1193.1	1338.5	1360.3
135°	608.5	635.8	663.1	669.9	745.0	845.1	895.2	976.4	1138.7	1260.4	1279.2
137.5°	636.8	663.8	690.7	697.5	763.0	850.3	893.9	962.5	1099.8	1202.7	1218.0
140°	660.3	685.1	709.9	716.1	773.9	851.2	889.7	949.0	1067.5	1156.5	1170.8
142.5°	678.3	701.3	724.2	729.9	783.2	854.3	889.7	941.8	1045.9	1124.0	1136.3
145°	705.9	726.0	745.9	751.0	795.3	854.3	883.7	926.4	1011.5	1075.4	1084.7
147.5°	733.5	753.0	772.6	777.4	812.9	860.1	883.7	917.3	984.2	1034.5	1042.3
150°	751.6	769.2	786.8	791.2	822.0	863.2	883.7	912.0	968.6	1011.1	1017.4
152.5°	770.2	783.5	796.9	800.2	828.0	865.1	883.7	907.9	956.2	992.4	997.2
155°	797.8	807.7	817.5	820.1	841.3	869.6	883.7	902.9	941.4	970.3	973.4
157.5°	818.2	827.8	837.4	839.8	854.5	873.9	883.7	898.7	928.6	951.0	953.2
160°	832.1	839.5	847.0	848.8	860.5	876.0	883.7	896.5	922.2	941.4	942.6
162.5°	845.8	851.5	857.1	858.5	867.0	878.1	883.7	894.6	916.2	932.4	933.5
165°	860.9	865.9	871.0	872.3	876.1	881.2	883.7	891.5	907.0	918.6	919.9
167.5°	874.7	877.1	879.6	880.1	883.3	887.6	889.7	894.8	904.9	912.6	913.1
170°	883.7	886.2	888.6	889.2	889.3	889.6	889.7	894.8	904.9	912.6	912.6
172.5°	888.6	889.1	889.6	889.7	889.7	889.7	889.7	893.7	901.8	907.8	907.3
175°	895.2	895.2	895.2	895.2	893.3	890.9	889.7	892.3	897.4	901.2	901.2
177.5°	895.2	895.2	895.2	895.2	893.7	891.9	890.9	892.9	896.9	899.9	899.4
180°	895.2	895.2	895.2	895.2	895.2	895.2	895.2	895.2	895.2	895.2	895.2

TEST NUMBER: P937194

CATALOG NUMBER: SQ4-FB-075U-075D-B2750-1D-UNV-STD-W-8-3500K

CANDELA DISTRIBUTION (continued):

	80°	90°
0°	602.7	602.7
2.5°	643.4	639.5
5°	827.5	831.4
7.5°	1114.4	1112.5
10°	1385.8	1403.2
12.5°	1583.4	1587.3
15°	1703.6	1711.4
17.5°	1750.1	1752.0
20°	1752.0	1748.2
22.5°	1730.7	1726.9
25°	1705.5	1703.6
27.5°	1682.3	1684.2
30°	1672.6	1678.4
32.5°	1672.6	1682.3
35°	1676.5	1686.2
37.5°	1674.5	1686.2
40°	1666.8	1680.3
42.5°	1645.5	1655.1
45°	1612.5	1624.1
47.5°	1569.9	1577.6
50°	1515.6	1523.4
52.5°	1447.8	1449.7
55°	1366.4	1374.1
57.5°	1279.2	1281.1
60°	1182.3	1188.1
62.5°	1079.5	1079.5
65°	970.9	974.8
67.5°	858.5	868.2
70°	744.2	746.1
72.5°	631.8	631.8
75°	515.5	517.4
77.5°	405.0	405.0
80°	300.4	302.3
82.5°	207.4	211.2
85°	129.8	129.8
87.5°	60.1	54.3
90°	22.9	22.9
92.5°	91.5	73.3
95°	318.8	263.8
97.5°	763.7	659.0
100°	1100.4	975.7
102.5°	1431.5	1324.7
105°	1853.6	1796.2
107.5°	2130.2	2144.1
110°	2235.8	2295.6



TEST NUMBER: P937194

CATALOG NUMBER: SQ4-FB-075U-075D-B2750-1D-UNV-STD-W-8-3500K

CANDELA DISTRIBUTION (continued):

	80°	90°
112.5°	2245.1	2336.9
115°	2185.6	2312.9
117.5°	2059.3	2200.6
120°	1957.7	2094.9
122.5°	1858.5	1993.9
125°	1717.3	1842.0
127.5°	1590.1	1695.4
130°	1515.2	1612.4
132.5°	1447.3	1534.3
135°	1354.2	1429.2
137.5°	1279.5	1340.9
140°	1228.3	1285.7
142.5°	1185.8	1235.2
145°	1122.1	1159.5
147.5°	1073.2	1104.2
150°	1042.5	1067.5
152.5°	1016.1	1035.1
155°	986.0	998.5
157.5°	962.0	970.8
160°	947.8	952.8
162.5°	938.4	943.2
165°	924.9	929.9
167.5°	915.2	917.4
170°	912.6	912.6
172.5°	905.4	903.6
175°	901.2	901.2
177.5°	897.3	895.2
180°	895.2	895.2

TEST NUMBER: P937194

CATALOG NUMBER: SQ4-FB-075U-075D-B2750-1D-UNV-STD-W-8-3500K

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	4.06	4.91	5.05	5.92	7.26	17.24	18.09	18.23	19.10	20.44
	3H	4.77	5.53	5.77	6.55	7.91	19.08	19.84	20.08	20.86	22.22
	4H	5.06	5.78	6.08	6.81	8.18	19.72	20.44	20.74	21.47	22.84
	6H	5.31	5.98	6.34	7.01	8.39	20.15	20.82	21.18	21.85	23.23
	8H	5.38	6.01	6.41	7.06	8.44	20.27	20.91	21.31	21.95	23.33
	12H	5.40	6.00	6.44	7.04	8.44	20.34	20.94	21.38	21.98	23.39
4H	2H	11.27	12.00	12.30	13.02	14.39	17.51	18.23	18.54	19.26	20.63
	3H	12.84	13.45	13.87	14.50	15.88	19.56	20.16	20.59	21.21	22.60
	4H	12.94	13.49	13.98	14.53	15.94	20.32	20.88	21.36	21.92	23.33
	6H	12.95	13.42	14.00	14.49	15.89	20.86	21.34	21.91	22.41	23.81
	8H	12.92	13.37	13.97	14.43	15.85	21.02	21.47	22.08	22.53	23.95
	12H	12.88	13.28	13.95	14.36	15.78	21.12	21.52	22.19	22.59	24.02
8H	4H	14.38	14.83	15.43	15.88	17.30	20.38	20.83	21.43	21.89	23.31
	6H	14.62	14.99	15.70	16.09	17.51	21.01	21.38	22.09	22.48	23.90
	8H	14.64	14.96	15.72	16.05	17.48	21.23	21.56	22.31	22.64	24.08
	12H	14.61	14.89	15.69	15.97	17.45	21.37	21.66	22.46	22.74	24.22
12H	4H	14.52	14.93	15.59	16.00	17.42	20.33	20.74	21.40	21.81	23.24
	6H	14.88	15.20	15.96	16.29	17.72	20.99	21.32	22.08	22.40	23.84
	8H	14.95	15.23	16.04	16.31	17.79	21.22	21.51	22.31	22.59	24.07

END OF REPORT