

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: CORELITE

Report Number: P621430

Luminaire Tested: VLT-F-025U-125D-930-UNV-STD-W-4

Issue Date: 9/2/2020

Test Information

Test Method: LM-79-2019
Report Number: P621430
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2203-563-26, G2-2203-563-1)
Test Lab: INNOVATION CENTER
Issue Date: 9/2/2020
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: CORELITE
Catalog Number: VLT-F-025U-125D-930-UNV-STD-W-4
Description: CORELITE VAULT SUSPENDED LED LUMINAIRE
FROSTED LENS
DOWNLIGHT 1250 LUMENS PER FOOT
UPLIGHT 250 LUMENS PER FOOT
Light Source: 3000K CCT, 90 CRI LEDS
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 5099.7 lumens
Efficiency: N/A
Efficacy: 108.5 lumens/watt
Spacing Criteria (0/90/45): 1.19 / 1.12 / 1.23
Luminous Opening: Rectangular (W 0.38' x L: 4' x H: 0')
CIE Type: Semi-Direct

Input Watts (W): 47
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



TEST NUMBER: P621430
CATALOG NUMBER: VLT-F-025U-125D-930-UNV-STD-W-4

Luminous Intensity Polar Plot





TEST NUMBER: P621430

CATALOG NUMBER: VLT-F-025U-125D-930-UNV-STD-W-4

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	115	115	115	115	110	110	110	110	102	102	102	94	94	94	86	86	86	83
1	106	102	99	95	102	98	95	92	91	89	86	84	82	81	78	77	75	72
2	98	91	85	80	94	87	82	78	81	77	73	76	72	69	70	68	65	62
3	90	81	74	68	86	78	72	66	73	68	63	68	64	60	63	60	57	54
4	83	73	65	59	80	70	63	58	66	60	55	61	57	53	58	54	50	48
5	77	65	57	52	74	63	56	51	59	53	48	56	51	46	52	48	45	42
6	71	59	51	46	68	58	50	45	54	48	43	51	46	41	48	43	40	38
7	66	54	46	41	64	53	45	40	50	43	39	47	41	37	44	39	36	34
8	62	50	42	37	60	48	41	36	46	39	35	43	38	34	41	36	32	31
9	58	46	38	33	56	45	37	33	42	36	32	40	35	31	38	33	30	28
10	54	42	35	30	52	41	34	30	39	33	29	37	32	28	35	31	27	25

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	14896	14896	14896
5°	14737	14845	14969
10°	14657	14720	14798
15°	14498	14513	14513
20°	14263	14198	14067
25°	13991	13753	13516
30°	13665	13273	12741
35°	13301	12699	11177
40°	12917	11892	8999
45°	12514	10533	6528
50°	12089	8810	4525
55°	11670	6707	3380
60°	11233	4647	2555
65°	10741	3313	2622
70°	10033	2790	2700
75°	9274	2853	2734
80°	8062	3013	2835
85°	6529	3351	2824

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 12514 cd/sqm



TEST NUMBER: P621430

CATALOG NUMBER: VLT-F-025U-125D-930-UNV-STD-W-4

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	195.6	3.8
10°-20°	550.1	10.8
20°-30°	800.1	15.7
30°-40°	885.2	17.4
40°-50°	760.0	14.9
50°-60°	526.2	10.3
60°-70°	313.6	6.1
70°-80°	154.5	3.0
80°-90°	48.1	0.9
90°-100°	19.8	0.4
100°-110°	141.3	2.8
110°-120°	191.9	3.8
120°-130°	156.1	3.1
130°-140°	125.6	2.5
140°-150°	99.0	1.9
150°-160°	72.4	1.4
160°-170°	45.0	0.9
170°-180°	15.3	0.3
0°-30°	1545.8	30.3
0°-40°	2431.0	47.7
0°-60°	3717.1	72.9
0°-90°	4233.2	83.0
90°-120°	353.0	6.9
90°-150°	733.8	14.4
90°-180°	866.0	17.0
0°-180°	5099.7	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2076	2076	2076	2076	2076	
5°	2046	2077	2061	2059	2078	194
15°	1952	1977	1954	1943	1954	549
25°	1767	1780	1737	1707	1707	813
35°	1518	1514	1450	1333	1276	949
45°	1233	1212	1038	750	643	951
55°	933	893	536	308	270	834
65°	633	509	195	156	154	626
75°	334	146	103	101	99	353
85°	79	40	41	36	34	92
90°	0	1	2	3	3	4
95°	8	15	8	9	11	9
105°	31	48	184	235	155	33
115°	56	68	158	329	384	55
125°	80	91	149	261	308	71
135°	99	110	150	215	246	76
145°	118	128	151	187	207	74
155°	138	143	154	170	178	63
165°	153	155	158	162	165	43
175°	161	162	161	160	159	15
180°	161	161	161	161	161	

TEST NUMBER: P621430

CATALOG NUMBER: VLT-F-025U-125D-930-UNV-STD-W-4

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2075.8	2075.8	2075.8	2075.8	2075.8
2.5°	2058.7	2082.2	2070.7	2070.9	2079.3
5°	2045.8	2077.3	2060.8	2059.1	2078.0
7.5°	2026.9	2055.9	2038.9	2036.7	2053.1
10°	2011.5	2038.8	2020.1	2016.1	2030.8
12.5°	1989.2	2016.5	1996.1	1988.7	2003.3
15°	1951.5	1976.6	1953.6	1943.1	1953.6
17.5°	1903.8	1924.8	1898.7	1882.1	1888.4
20°	1867.8	1888.8	1859.2	1835.8	1842.1
22.5°	1828.4	1846.0	1812.9	1786.0	1790.6
25°	1767.0	1779.6	1737.0	1707.0	1707.0
27.5°	1698.8	1706.4	1656.8	1625.3	1616.5
30°	1649.1	1653.3	1601.9	1564.8	1537.6
32.5°	1597.6	1600.1	1541.9	1482.1	1439.8
35°	1518.3	1514.1	1449.6	1332.6	1275.9
37.5°	1433.8	1424.6	1348.4	1170.2	1085.9
40°	1378.9	1366.3	1269.5	1055.1	960.7
42.5°	1322.3	1304.7	1182.0	936.5	832.0
45°	1233.1	1212.1	1037.9	750.3	643.3
47.5°	1144.7	1117.0	890.4	581.2	489.4
50°	1082.9	1053.6	789.2	478.7	405.3
52.5°	1021.2	991.8	686.2	401.8	343.5
55°	932.8	893.0	536.1	307.9	270.2
57.5°	842.8	785.7	399.3	239.9	210.6
60°	782.7	707.2	323.8	199.0	178.0
62.5°	724.4	628.8	265.5	173.6	169.4
65°	632.6	508.9	195.1	156.5	154.4
67.5°	545.1	388.3	145.0	141.1	139.0
70°	478.2	306.3	133.0	130.8	128.7
72.5°	418.2	234.5	120.9	118.8	116.7
75°	334.5	145.8	102.9	100.7	98.6
77.5°	250.0	91.9	84.9	82.7	80.6
80°	195.1	75.6	72.9	70.7	68.6
82.5°	147.1	61.1	59.2	57.0	54.9
85°	79.3	39.5	40.7	36.4	34.3
87.5°	27.4	19.3	19.3	16.0	14.3
90°	0.0	1.0	2.0	3.0	3.0
92.5°	2.4	3.4	4.5	6.3	7.1
95°	8.1	15.1	8.1	9.2	11.2
97.5°	14.4	28.9	59.7	17.6	15.2
100°	19.3	36.1	119.7	35.2	23.3
102.5°	24.1	41.8	161.9	93.0	50.9
105°	31.4	48.3	183.6	234.6	155.2
107.5°	38.8	51.5	175.3	341.4	319.8
110°	43.6	55.5	170.4	358.7	385.5



TEST NUMBER: P621430

CATALOG NUMBER: VLT-F-025U-125D-930-UNV-STD-W-4

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	48.5	60.4	165.6	348.6	393.6
115°	55.8	67.7	158.3	328.9	384.5
117.5°	63.3	75.0	156.4	307.7	364.8
120°	69.0	79.9	153.2	291.5	351.0
122.5°	73.0	84.7	149.1	277.6	332.3
125°	80.1	91.1	149.1	260.8	308.4
127.5°	86.0	97.1	149.3	241.3	288.3
130°	89.3	101.2	150.1	228.3	272.9
132.5°	93.3	105.2	150.1	222.4	259.1
135°	99.4	110.3	150.1	214.8	246.5
137.5°	104.5	116.2	150.1	206.4	233.5
140°	108.6	119.5	150.1	201.4	226.2
142.5°	112.6	122.7	151.0	195.7	218.9
145°	117.7	127.6	151.2	187.1	207.0
147.5°	123.8	132.5	152.4	180.9	196.2
150°	127.8	135.8	153.2	176.8	189.7
152.5°	131.9	139.0	153.2	173.5	184.0
155°	138.0	142.9	154.2	169.6	177.5
157.5°	142.8	147.6	155.4	167.1	172.9
160°	146.1	150.1	156.2	165.5	170.4
162.5°	148.5	152.5	157.0	164.6	168.0
165°	153.2	155.2	158.3	162.4	165.4
167.5°	155.8	157.6	159.3	161.3	163.1
170°	158.3	159.3	159.3	161.3	162.3
172.5°	159.1	160.9	160.1	160.5	161.5
175°	161.3	162.3	161.3	160.3	159.3
177.5°	161.3	162.1	161.3	161.3	160.5
180°	161.3	161.3	161.3	161.3	161.3



TEST NUMBER: P621430

CATALOG NUMBER: VLT-F-025U-125D-930-UNV-STD-W-4

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	19.70	20.86	20.32	21.49	22.20	11.94	13.10	12.56	13.72	14.43
	3H	21.22	22.26	21.85	22.89	23.64	13.31	14.35	13.95	14.99	15.73
	4H	21.75	22.72	22.40	23.37	24.13	13.98	14.95	14.63	15.60	16.36
	6H	22.16	23.06	22.82	23.71	24.49	14.58	15.48	15.25	16.14	16.91
	8H	22.30	23.15	22.98	23.83	24.61	14.82	15.67	15.50	16.35	17.13
	12H	22.39	23.20	23.07	23.87	24.68	14.99	15.81	15.68	16.48	17.28
4H	2H	19.57	20.54	20.23	21.19	21.95	12.59	13.56	13.25	14.21	14.97
	3H	21.23	22.04	21.90	22.72	23.50	14.17	14.97	14.84	15.66	16.44
	4H	21.83	22.56	22.52	23.25	24.06	14.97	15.70	15.66	16.39	17.20
	6H	22.34	22.97	23.05	23.69	24.51	15.73	16.36	16.43	17.07	17.89
	8H	22.53	23.12	23.24	23.83	24.66	16.02	16.61	16.74	17.33	18.16
	12H	22.67	23.20	23.41	23.94	24.78	16.25	16.78	16.98	17.52	18.35
8H	4H	21.77	22.36	22.48	23.07	23.90	15.45	16.04	16.16	16.75	17.58
	6H	22.31	22.80	23.05	23.56	24.39	16.34	16.82	17.08	17.58	18.42
	8H	22.55	22.98	23.30	23.74	24.59	16.73	17.17	17.49	17.93	18.78
	12H	22.75	23.13	23.50	23.88	24.79	17.06	17.45	17.82	18.19	19.11
12H	4H	21.73	22.26	22.46	23.00	23.83	15.51	16.04	16.24	16.77	17.61
	6H	22.29	22.72	23.04	23.48	24.33	16.45	16.89	17.21	17.65	18.50
	8H	22.54	22.92	23.29	23.67	24.58	16.91	17.29	17.66	18.04	18.95