

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P554117

Luminaire Tested: **FUSL-12-2-LD4-1LO-30-UNV-81-86-EDD**

Issue Date: 7/16/2021

This test was performed under the Supervised Manufacturer's Testing Program. The results of this test have not been influenced by sources from within Cooper Lighting Solutions or from external interests.



Test Information

Test Method: LM-79-08
Report Number: P554117
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2105-257-2)
Test Lab: INNOVATION CENTER
Issue Date: 7/16/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FUSL-12-2-LD4-1LO-30-UNV-81-86-EDD
Description: 2FT FUSL SURFACE MOUNT WITH .156 CLEAR PC FIXTURE SIDE AND .250 CLEAR PC ENVIRONMENTAL SIDE LENSES WITH, 80 CRI AND 3000K CCT LEDS
Light Source: -
Ballast/Driver: -

Luminaire Equipment: Sample No. Condition Description

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 1081.0 lumens
Efficiency: N/A
Efficacy: 92.4 lumens/watt
Spacing Criteria (0/90/45): 1.13 / 1.16 / 1.26
Luminous Opening: Rectangular (W 1' x L: 2' x H: 0')
CIE Type: Direct

Input Watts (W): 11.7
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P554117

CATALOG NUMBER: FUSL-12-2-LD4-1LO-30-UNV-81-86-EDD

Luminous Intensity Polar Plot





TEST NUMBER: P554117

CATALOG NUMBER: FUSL-12-2-LD4-1LO-30-UNV-81-86-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	110	106	102	98	107	103	100	97	99	96	94	95	93	91	92	90	88	86																			
2	101	93	87	82	98	91	86	81	88	83	79	85	81	77	82	78	75	73																			
3	92	83	75	69	90	81	74	68	78	72	67	75	70	66	73	69	65	63																			
4	85	74	65	59	83	72	65	59	70	63	58	68	62	57	65	61	56	54																			
5	78	66	58	51	76	65	57	51	63	56	51	61	55	50	59	54	50	47																			
6	73	60	51	45	71	59	51	45	57	50	45	56	49	44	54	48	44	42																			
7	68	55	46	40	66	54	46	40	52	45	40	51	44	40	49	44	39	37																			
8	63	50	42	36	61	49	41	36	48	41	36	47	40	36	46	40	35	34																			
9	59	46	38	33	58	45	38	33	44	37	32	43	37	32	42	36	32	30																			
10	55	43	35	30	54	42	35	30	41	34	30	40	34	29	39	33	29	28																			

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	2516	2516	2516
5°	2523	2512	2491
10°	2496	2489	2461
15°	2452	2452	2424
20°	2400	2403	2372
25°	2321	2350	2312
30°	2186	2284	2256
35°	2065	2189	2192
40°	1964	2070	2125
45°	1853	1945	2045
50°	1734	1833	1958
55°	1599	1706	1852
60°	1440	1556	1722
65°	1272	1384	1566
70°	1061	1179	1331
75°	834	942	1042
80°	595	663	735
85°	389	389	364



TEST NUMBER: P554117

CATALOG NUMBER: FUSL-12-2-LD4-1LO-30-UNV-81-86-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	44.0	4.1
10°-20°	123.7	11.4
20°-30°	180.7	16.7
30°-40°	205.1	19.0
40°-50°	198.0	18.3
50°-60°	163.3	15.1
60°-70°	108.8	10.1
70°-80°	48.7	4.5
80°-90°	8.7	0.8
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	348.4	32.2
0°-40°	553.5	51.2
0°-60°	914.9	84.6
0°-90°	1081.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1081.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	468	468	468	468	468	
5°	467	467	465	462	461	44
15°	440	441	440	438	435	124
25°	391	394	396	393	389	179
35°	314	319	333	335	334	197
45°	243	248	256	267	269	188
55°	170	173	182	192	197	152
65°	100	103	109	116	123	99
75°	40	42	45	47	50	44
85°	6	6	6	6	6	8
90°	0	0	0	0	0	



TEST NUMBER: P554117

CATALOG NUMBER: FUSL-12-2-LD4-1LO-30-UNV-81-86-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	467.5	467.5	467.5	467.5	467.5
2.5°	468.8	468.9	467.9	465.0	463.2
5°	467.0	466.8	465.0	462.5	461.0
7.5°	461.8	462.1	461.6	458.0	456.0
10°	456.7	456.9	455.5	452.6	450.3
12.5°	450.3	450.1	448.1	446.7	442.9
15°	440.0	441.1	440.0	438.0	435.0
17.5°	430.1	430.1	430.9	427.5	425.1
20°	419.0	419.6	419.6	416.9	414.2
22.5°	406.1	407.7	408.2	405.4	402.1
25°	390.8	393.9	395.7	392.8	389.4
27.5°	372.3	377.0	382.4	380.2	376.4
30°	351.7	358.5	367.5	365.7	363.0
32.5°	332.1	338.9	351.3	350.6	349.1
35°	314.3	318.6	333.2	335.0	333.7
37.5°	297.4	301.4	315.0	319.2	318.1
40°	279.6	284.0	294.7	302.1	302.5
42.5°	262.0	266.2	275.0	285.6	285.6
45°	243.4	247.5	255.6	267.2	268.7
47.5°	225.0	229.4	237.3	248.9	251.3
50°	207.1	211.0	218.9	230.3	233.8
52.5°	188.4	192.7	200.4	210.9	216.1
55°	170.4	173.3	181.8	191.8	197.4
57.5°	151.8	154.5	164.0	172.6	178.3
60°	133.8	137.2	144.6	153.4	160.0
62.5°	116.6	120.2	126.4	134.2	141.7
65°	99.9	102.6	108.7	116.4	123.0
67.5°	83.7	86.0	92.1	97.5	104.5
70°	67.4	70.4	74.9	80.1	84.6
72.5°	54.2	55.5	59.3	63.0	67.7
75°	40.1	42.2	45.3	47.4	50.1
77.5°	28.7	30.0	31.8	33.6	36.1
80°	19.2	19.8	21.4	21.7	23.7
82.5°	11.7	12.0	12.4	12.6	13.3
85°	6.3	6.3	6.3	5.9	5.9
87.5°	3.6	3.6	3.1	2.5	1.8
90°	0.0	0.0	0.0	0.0	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180° - - 45°-225° - - - - 90°-270°







(END OF REPORT)