

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P572832

Luminaire Tested: **FLD4C-25-D010 FEU4C-X-90-40 F4X-M-X-H**

Issue Date: 3/1/2023



Test Information

Test Method: LM-79-08
Report Number: P572832
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P207151)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/1/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD4C-25-D010 FEU4C-X-90-40 F4X-M-X-H
Description: 4 INCH FAIL-SAFE LED DOWNLIGHT WITH 4000K, 90 CRI LEDS, 4LBMH TRIM

Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 1911.0 lumens
Efficiency: N/A
Efficacy: 60.7 lumens/watt
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.93
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 31.5
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P572832

CATALOG NUMBER: FLD4C-25-D010 FEU4C-X-90-40 F4X-M-X-H

Luminous Intensity Polar Plot





TEST NUMBER: P572832

CATALOG NUMBER: FLD4C-25-D010 FEU4C-X-90-40 F4X-M-X-H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				20	
RC	80				70				50				30				10				0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100				100
1	113	110	108	105	111	108	106	104	104	102	100	100	99	97	97	96	95	93				93
2	107	102	98	94	105	100	96	93	97	94	91	94	91	89	91	89	87	85				85
3	101	94	89	85	99	93	88	84	90	86	83	88	84	82	86	83	80	79				79
4	96	88	82	77	94	86	81	77	84	80	76	82	78	75	80	77	74	73				73
5	90	82	75	71	89	81	75	70	79	74	70	77	73	69	75	72	69	67				67
6	86	76	70	65	84	75	69	65	74	68	64	72	68	64	71	67	64	62				62
7	81	71	65	60	80	70	64	60	69	64	60	68	63	59	67	62	59	58				58
8	77	67	60	56	75	66	60	56	65	59	56	64	59	55	63	58	55	54				54
9	73	63	56	52	72	62	56	52	61	56	52	60	55	52	59	55	52	50				50
10	69	59	53	49	68	59	53	49	58	52	49	57	52	48	56	52	48	47				47

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	232795
5°	229417
10°	219820
15°	207621
20°	193806
25°	175935
30°	146881
35°	106408
40°	66619
45°	38084
50°	19858
55°	11116
60°	7101
65°	4186
70°	3125
75°	1377
80°	2052
85°	0



TEST NUMBER: P572832

CATALOG NUMBER: FLD4C-25-D010 FEU4C-X-90-40 F4X-M-X-H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	174.4	9.1
10°-20°	457.4	23.9
20°-30°	587.9	30.8
30°-40°	442.3	23.1
40°-50°	177.6	9.3
50°-60°	50.5	2.6
60°-70°	16.0	0.8
70°-80°	4.6	0.2
80°-90°	0.4	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1219.6	63.8
0°-40°	1661.9	87.0
0°-60°	1890.0	98.9
0°-90°	1911.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1911.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1895	
5°	1860	174
15°	1632	457
25°	1298	588
35°	710	442
45°	219	178
55°	52	50
65°	14	16
75°	3	5
85°	0	0
90°	0	



TEST NUMBER: P572832

CATALOG NUMBER: FLD4C-25-D010 FEU4C-X-90-40 F4X-M-X-H

CANDELA DISTRIBUTION (FULL):

	0°
0°	1894.9
2.5°	1883.3
5°	1860.3
7.5°	1817.0
10°	1762.1
12.5°	1695.9
15°	1632.4
17.5°	1560.3
20°	1482.4
22.5°	1398.9
25°	1297.9
27.5°	1176.7
30°	1035.4
32.5°	876.7
35°	709.5
37.5°	553.7
40°	415.4
42.5°	305.7
45°	219.2
47.5°	150.0
50°	103.9
52.5°	72.1
55°	51.9
57.5°	37.5
60°	28.9
62.5°	20.2
65°	14.4
67.5°	11.5
70°	8.7
72.5°	5.8
75°	2.9
77.5°	2.9
80°	2.9
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180°







(END OF REPORT)