

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P573138

Luminaire Tested: **FLD4C-35-D010 FEU4C-X-90-30 F4X-N-X-LI**

Issue Date: 3/1/2023



Test Information

Test Method: LM-79-08
Report Number: P573138
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P208279)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/1/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD4C-35-D010 FEU4C-X-90-30 F4X-N-X-LI
Description: 4 INCH FAIL-SAFE LED DOWNLIGHT WITH 3000K, 90 CRI LEDS, 4LBNLI TRIM

Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 2552.0 lumens
Efficiency: N/A
Efficacy: 63.2 lumens/watt
Spacing Criteria (0/90/45): 0.48 / 0.48 / 0.54
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 40.4
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P573138

CATALOG NUMBER: FLD4C-35-D010 FEU4C-X-90-30 F4X-N-X-LI

Luminous Intensity Polar Plot





TEST NUMBER: P573138

CATALOG NUMBER: FLD4C-35-D010 FEU4C-X-90-30 F4X-N-X-LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	114	112	110	108	112	110	108	106	106	104	103	102	101	100	99	98	97	95	95	95	95
2	109	105	102	99	107	103	100	98	100	98	95	97	95	93	95	93	92	90	90	90	90
3	105	99	95	92	103	98	94	91	95	92	89	93	90	88	91	89	87	85	85	85	85
4	101	94	89	86	99	93	88	85	91	87	84	89	86	83	87	84	82	81	81	81	81
5	96	89	84	80	95	88	84	80	87	82	79	85	81	79	83	80	78	77	77	77	77
6	92	85	80	76	91	84	79	76	83	78	75	81	78	75	80	77	74	73	73	73	73
7	89	81	76	72	88	80	75	72	79	75	71	78	74	71	77	73	71	69	69	69	69
8	85	77	72	68	84	77	72	68	76	71	68	75	71	68	74	70	67	66	66	66	66
9	82	74	69	65	81	73	68	65	72	68	65	72	68	65	71	67	64	63	63	63	63
10	79	71	66	62	78	70	65	62	69	65	62	69	65	62	68	64	62	61	61	61	61

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	806828
5°	726063
10°	562854
15°	407394
20°	282080
25°	205649
30°	149420
35°	88426
40°	37191
45°	11589
50°	1510
55°	835
60°	958
65°	1134
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P573138

CATALOG NUMBER: FLD4C-35-D010 FEU4C-X-90-30 F4X-N-X-LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	517.6	20.3
10°-20°	886.0	34.7
20°-30°	704.2	27.6
30°-40°	372.8	14.6
40°-50°	64.2	2.5
50°-60°	4.8	0.2
60°-70°	2.4	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2107.8	82.6
0°-40°	2480.6	97.2
0°-60°	2549.6	99.9
0°-90°	2552.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2552.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	6567	
5°	5888	518
15°	3203	886
25°	1517	704
35°	590	373
45°	67	64
55°	4	5
65°	4	2
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P573138

CATALOG NUMBER: FLD4C-35-D010 FEU4C-X-90-30 F4X-N-X-LI

CANDELA DISTRIBUTION (FULL):

	0°
0°	6567.4
2.5°	6398.3
5°	5887.5
7.5°	5219.4
10°	4511.9
12.5°	3828.1
15°	3203.1
17.5°	2621.4
20°	2157.6
22.5°	1803.9
25°	1517.1
27.5°	1285.2
30°	1053.3
32.5°	817.5
35°	589.6
37.5°	389.2
40°	231.9
42.5°	133.7
45°	66.7
47.5°	23.6
50°	7.9
52.5°	7.9
55°	3.9
57.5°	3.9
60°	3.9
62.5°	3.9
65°	3.9
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180°







(END OF REPORT)