

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P365223

Luminaire Tested: **FLD6BX10D010-FEU6B12-8040-F6LBXVM1-MW-BTR84**

Issue Date: 3/3/2020

Test Information

Test Method: LM-79-08
Report Number: P365223
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1910-544-15)
Test Lab: INNOVATION CENTER
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD6BX10D010-FEU6B12-8040-F6LBXVM1-MW-BTR84
Description: VANDAL RESISTANT ENCLOSED BOTTOM TRIM RING, MATTE WHITE REFLECTOR,
BOTTOM TRIM POLYCARBONATE, CLEAR 0.125", 1000LM
Light Source: -
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 658.0 lumens
Efficiency: N/A
Efficacy: 65.8 lumens/watt
Spacing Criteria (0/90/45): 0.87 / 0.87 / 0.84
Luminous Opening: Circular (Dia: 0.44' x H: 0')
CIE Type: Direct


Input Watts (W): 10
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P365223

CATALOG NUMBER: FLD6BX10D010-FEU6B12-8040-F6LBXVM1-MW-BTR84

Luminous Intensity Polar Plot





TEST NUMBER: P365223

CATALOG NUMBER: FLD6BX10D010-FEU6B12-8040-F6LBXVM1-MW-BTR84

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	112	109	106	103	110	107	104	101	102	100	98		99	97	95		95	94	93	91
2	105	99	94	90	103	97	93	89	94	90	87		91	88	85		88	86	84	82
3	99	91	85	80	96	89	84	80	87	82	78		84	80	77		82	79	76	74
4	93	84	77	72	91	82	76	72	80	75	71		78	74	70		76	72	69	67
5	87	77	71	65	85	76	70	65	74	69	65		73	68	64		71	67	63	62
6	82	72	65	60	81	71	64	60	69	64	59		68	63	59		67	62	58	57
7	78	67	60	55	76	66	60	55	65	59	55		64	58	54		62	58	54	53
8	73	63	56	51	72	62	56	51	61	55	51		60	55	51		59	54	50	49
9	70	59	52	48	68	58	52	48	57	52	47		56	51	47		55	51	47	46
10	66	55	49	45	65	55	49	45	54	48	44		53	48	44		52	48	44	43

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	46212
5°	45382
10°	42919
15°	40133
20°	36483
25°	30369
30°	21918
35°	15148
40°	11076
45°	9002
50°	7842
55°	6891
60°	5986
65°	5083
70°	4103
75°	2877
80°	1814
85°	2136



TEST NUMBER: P365223

CATALOG NUMBER: FLD6BX10D010-FEU6B12-8040-F6LBXVM1-MW-BTR84

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	58.9	9.0
10°-20°	151.3	23.0
20°-30°	172.8	26.3
30°-40°	111.4	16.9
40°-50°	70.0	10.6
50°-60°	49.6	7.5
60°-70°	29.9	4.5
70°-80°	11.5	1.8
80°-90°	2.5	0.4
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	383.0	58.2
0°-40°	494.4	75.1
0°-60°	614.0	93.3
0°-90°	658.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	658.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	645	
5°	631	59
15°	541	151
25°	384	173
35°	173	111
45°	89	70
55°	55	50
65°	30	30
75°	10	12
85°	3	3
90°	0	



TEST NUMBER: P365223

CATALOG NUMBER: FLD6BX10D010-FEU6B12-8040-F6LBXVM1-MW-BTR84

CANDELA DISTRIBUTION (FULL):

0°	
0°	645.4
2.5°	641.7
5°	631.4
7.5°	613.6
10°	590.3
12.5°	567.3
15°	541.4
17.5°	513.6
20°	478.8
22.5°	436.6
25°	384.4
27.5°	325.5
30°	265.1
32.5°	214.4
35°	173.3
37.5°	141.5
40°	118.5
42.5°	101.8
45°	88.9
47.5°	78.9
50°	70.4
52.5°	62.6
55°	55.2
57.5°	48.5
60°	41.8
62.5°	35.9
65°	30.0
67.5°	24.4
70°	19.6
72.5°	14.4
75°	10.4
77.5°	7.0
80°	4.4
82.5°	3.0
85°	2.6
87.5°	1.5
90°	0.0

(END OF REPORT)