

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P364594

Luminaire Tested: **FLD6BX15D010-FEU6B12-8040-F6LBXVM1-LI-BTR85**

Issue Date: 3/3/2020

Test Information

Test Method: LM-79-08
Report Number: P364594
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1910-544-24)
Test Lab: INNOVATION CENTER
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD6BX15D010-FEU6B12-8040-F6LBXVM1-LI-BTR85
Description: VANDAL RESISTANT ENCLOSED BOTTOM TRIM RING, SPECULAR CLEAR REFLECTOR, BOTTOM TRIM POLYCARBONATE, CLEAR 0.187", 1500LM
Light Source: -
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1132.0 lumens
Efficiency: N/A
Efficacy: 79.7 lumens/watt
Spacing Criteria (0/90/45): 0.76 / 0.76 / 0.77
Luminous Opening: Circular (Dia: 0.44' x H: 0')
CIE Type: Direct


Input Watts (W): 14.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P364594

CATALOG NUMBER: FLD6BX15D010-FEU6B12-8040-F6LBXVM1-LI-BTR85

Luminous Intensity Polar Plot





TEST NUMBER: P364594

CATALOG NUMBER: FLD6BX15D010-FEU6B12-8040-F6LBXVM1-LI-BTR85

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	109	107	111	109	107	105	105	103	102	101	100	99	98	97	96	94
2	109	104	100	97	107	102	99	96	99	96	94	96	94	92	94	92	90	89
3	104	98	93	90	102	97	92	89	94	90	87	92	89	86	89	87	85	83
4	99	92	87	83	97	91	86	83	89	85	82	87	84	81	85	82	80	78
5	95	87	82	78	93	86	81	77	84	80	77	83	79	76	81	78	75	74
6	91	82	77	73	89	82	76	73	80	76	72	79	75	72	78	74	71	70
7	87	78	73	69	85	77	72	69	76	72	68	75	71	68	74	70	68	66
8	83	74	69	65	82	74	68	65	73	68	65	72	67	64	71	67	64	63
9	79	71	65	62	78	70	65	61	69	65	61	68	64	61	68	64	61	60
10	76	67	62	58	75	67	62	58	66	61	58	65	61	58	65	61	58	57

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	127050
5°	124157
10°	114462
15°	101377
20°	85828
25°	67999
30°	47788
35°	19903
40°	6833
45°	1823
50°	1003
55°	936
60°	859
65°	847
70°	837
75°	968
80°	1237
85°	2054



TEST NUMBER: P364594

CATALOG NUMBER: FLD6BX15D010-FEU6B12-8040-F6LBXVM1-LI-BTR85

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	160.1	14.1
10°-20°	379.4	33.5
20°-30°	389.5	34.4
30°-40°	164.9	14.6
40°-50°	20.3	1.8
50°-60°	6.7	0.6
60°-70°	5.0	0.4
70°-80°	3.8	0.3
80°-90°	2.3	0.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	929.0	82.1
0°-40°	1093.9	96.6
0°-60°	1120.9	99.0
0°-90°	1132.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1132.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1774	
5°	1727	160
15°	1368	379
25°	861	389
35°	228	165
45°	18	20
55°	8	7
65°	5	5
75°	4	4
85°	2	2
90°	0	



TEST NUMBER: P364594

CATALOG NUMBER: FLD6BX15D010-FEU6B12-8040-F6LBXVM1-LI-BTR85

CANDELA DISTRIBUTION (FULL):

	0°
0°	1774.4
2.5°	1762.9
5°	1727.4
7.5°	1666.3
10°	1574.3
12.5°	1476.2
15°	1367.6
17.5°	1251.0
20°	1126.4
22.5°	993.8
25°	860.7
27.5°	723.1
30°	578.0
32.5°	407.3
35°	227.7
37.5°	130.6
40°	73.1
42.5°	38.5
45°	18.0
47.5°	10.5
50°	9.0
52.5°	8.0
55°	7.5
57.5°	7.0
60°	6.0
62.5°	5.5
65°	5.0
67.5°	4.5
70°	4.0
72.5°	4.0
75°	3.5
77.5°	3.5
80°	3.0
82.5°	3.0
85°	2.5
87.5°	1.5
90°	0.0

(END OF REPORT)