

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions  
(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P365322

Luminaire Tested: **FLD6BX15D010-FEU6B12-8050-F6LBXVM1-MW-BL85**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-79-08  
Report Number: P365322  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1910-544-37)  
Test Lab: INNOVATION CENTER  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: FAIL-SAFE  
Catalog Number: FLD6BX15D010-FEU6B12-8050-F6LBXVM1-MW-BL85  
Description: VANDAL RESISTANT ENCLOSED BOTTOM LENS, MATTE WHITE REFLECTOR, BOTTOM LENS POLYCARBONATE, CLEAR 0.187", 1500LM  
Light Source: -  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 1184.0 lumens  
Efficiency: N/A  
Efficacy: 83.4 lumens/watt  
Spacing Criteria (0/90/45): 0.94 / 0.94 / 0.95  
Luminous Opening: Circular (Dia: 0.71' x H: 0')  
CIE Type: Direct


Input Watts (W): 14.2  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P365322

CATALOG NUMBER: FLD6BX15D010-FEU6B12-8050-F6LBXVM1-MW-BL85

### Luminous Intensity Polar Plot





TEST NUMBER: P365322

CATALOG NUMBER: FLD6BX15D010-FEU6B12-8050-F6LBXVM1-MW-BL85

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	112	108	105	102	109	106	103	101	102	100	97		98	96	94		95	93	92	90
2	104	98	93	89	102	96	92	88	93	89	86		90	87	84		87	84	82	80
3	97	89	83	78	95	88	82	77	85	80	76		82	78	75		80	77	74	72
4	91	82	75	69	89	80	74	69	78	73	68		76	71	67		74	70	67	65
5	85	75	68	63	83	74	67	62	72	66	62		70	65	61		69	64	60	59
6	80	69	62	57	78	68	62	57	67	61	56		65	60	56		64	59	55	54
7	75	64	57	52	74	63	57	52	62	56	51		61	55	51		60	55	51	49
8	71	60	53	48	70	59	52	48	58	52	47		57	51	47		56	51	47	45
9	67	56	49	44	66	55	49	44	54	48	44		53	48	44		52	47	44	42
10	64	52	46	41	62	52	45	41	51	45	41		50	45	41		49	44	41	39

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	26212
5°	25632
10°	24311
15°	22784
20°	21261
25°	19554
30°	16751
35°	12755
40°	9367
45°	7100
50°	5813
55°	5115
60°	4567
65°	4001
70°	3418
75°	2670
80°	1793
85°	815



TEST NUMBER: P365322

CATALOG NUMBER: FLD6BX15D010-FEU6B12-8050-F6LBXVM1-MW-BL85

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	87.4	7.4
10°-20°	226.2	19.1
20°-30°	294.8	24.9
30°-40°	240.3	20.3
40°-50°	145.5	12.3
50°-60°	96.6	8.2
60°-70°	61.8	5.2
70°-80°	27.4	2.3
80°-90°	4.1	0.3
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	608.3	51.4
0°-40°	848.6	71.7
0°-60°	1090.8	92.1
0°-90°	1184.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1184.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	960	
5°	935	87
15°	806	226
25°	649	295
35°	382	240
45°	184	145
55°	107	97
65°	62	62
75°	25	27
85°	3	4
90°	0	



TEST NUMBER: P365322

CATALOG NUMBER: FLD6BX15D010-FEU6B12-8050-F6LBXVM1-MW-BL85

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	959.6
2.5°	952.3
5°	934.8
7.5°	908.5
10°	876.5
12.5°	841.4
15°	805.7
17.5°	770.1
20°	731.4
22.5°	694.2
25°	648.8
27.5°	596.2
30°	531.1
32.5°	456.8
35°	382.5
37.5°	315.4
40°	262.7
42.5°	217.8
45°	183.8
47.5°	156.9
50°	136.8
52.5°	120.3
55°	107.4
57.5°	95.0
60°	83.6
62.5°	72.8
65°	61.9
67.5°	52.1
70°	42.8
72.5°	33.6
75°	25.3
77.5°	18.1
80°	11.4
82.5°	6.2
85°	2.6
87.5°	0.5
90°	0.0

(END OF REPORT)