

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P364726

Luminaire Tested: **FLD6BX30D010-FEU6B35-8027-F6LBXVM1-LI**

Issue Date: 3/3/2020

Test Information

Test Method: LM-79-08
Report Number: P364726
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1910-544-10)
Test Lab: INNOVATION CENTER
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD6BX30D010-FEU6B35-8027-F6LBXVM1-LI
Description: VANDAL RESISTANT OPEN, SPECULAR CLEAR REFLECTOR, 3000LM
Light Source: -
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2749.0 lumens
Efficiency: N/A
Efficacy: 101.8 lumens/watt
Spacing Criteria (0/90/45): 0.77 / 0.77 / 0.81
Luminous Opening: Circular (Dia: 0.71' x H: 0')
CIE Type: Direct


Input Watts (W): 27
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P364726

CATALOG NUMBER: FLD6BX30D010-FEU6B35-8027-F6LBXVM1-LI

Luminous Intensity Polar Plot





TEST NUMBER: P364726

CATALOG NUMBER: FLD6BX30D010-FEU6B35-8027-F6LBXVM1-LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	109	107	111	109	107	105	105	103	102	101	100	99	98	97	96	94
2	109	104	100	97	106	102	99	96	99	96	94	96	94	92	93	92	90	88
3	104	98	93	89	102	96	92	88	94	90	87	91	88	86	89	87	84	83
4	99	92	87	83	97	91	86	82	88	84	81	87	83	80	85	82	79	78
5	94	86	81	77	93	85	80	77	84	79	76	82	78	75	81	77	75	73
6	90	81	76	72	88	81	75	72	79	75	71	78	74	71	77	73	70	69
7	86	77	71	67	84	76	71	67	75	70	67	74	70	66	73	69	66	65
8	82	73	67	63	81	72	67	63	71	66	63	70	66	63	69	65	62	61
9	78	69	64	60	77	69	63	60	68	63	60	67	62	59	66	62	59	58
10	75	66	60	57	74	65	60	56	64	60	56	64	59	56	63	59	56	55

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	108548
5°	106059
10°	98049
15°	86703
20°	73912
25°	61484
30°	47687
35°	24769
40°	11503
45°	4346
50°	956
55°	133
60°	49
65°	58
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P364726

CATALOG NUMBER: FLD6BX30D010-FEU6B35-8027-F6LBXVM1-LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	358.4	13.0
10°-20°	852.3	31.0
20°-30°	928.9	33.8
30°-40°	502.3	18.3
40°-50°	101.5	3.7
50°-60°	4.8	0.2
60°-70°	0.8	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2139.6	77.8
0°-40°	2641.9	96.1
0°-60°	2748.2	100.0
0°-90°	2749.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2749.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3974	
5°	3868	358
15°	3066	852
25°	2040	929
35°	743	502
45°	112	101
55°	3	5
65°	1	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P364726

CATALOG NUMBER: FLD6BX30D010-FEU6B35-8027-F6LBXVM1-LI

CANDELA DISTRIBUTION (FULL):

	0°
0°	3973.9
2.5°	3947.7
5°	3868.0
7.5°	3724.5
10°	3535.0
12.5°	3309.0
15°	3066.0
17.5°	2814.7
20°	2542.7
22.5°	2286.6
25°	2040.0
27.5°	1792.4
30°	1511.9
32.5°	1137.7
35°	742.8
37.5°	496.2
40°	322.6
42.5°	198.8
45°	112.5
47.5°	56.3
50°	22.5
52.5°	5.6
55°	2.8
57.5°	1.9
60°	0.9
62.5°	0.9
65°	0.9
67.5°	0.9
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)