

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P366201

Luminaire Tested: **FLD6BX30D010-FEU6B35-8035-F6LBXVM1-WMH-BTR94**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-79-08  
Report Number: P366201  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1910-544-33)  
Test Lab: INNOVATION CENTER  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: FAIL-SAFE  
Catalog Number: FLD6BX30D010-FEU6B35-8035-F6LBXVM1-WMH-BTR94  
Description: VANDAL RESISTANT ENCLOSED BOTTOM TRIM RING, WARM HAZE REFLECTOR,  
BOTTOM TRIM GLASS, TEMPERED CLEAR 0.187", 3000LM  
Light Source: -  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 2264.0 lumens  
Efficiency: N/A  
Efficacy: 83.9 lumens/watt  
Spacing Criteria (0/90/45): 0.81 / 0.81 / 0.8  
Luminous Opening: Circular (Dia: 0.44' x H: 0')  
CIE Type: Direct


Input Watts (W): 27  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P366201

CATALOG NUMBER: FLD6BX30D010-FEU6B35-8035-F6LBXVM1-WMH-BTR94

### Luminous Intensity Polar Plot





TEST NUMBER: P366201

CATALOG NUMBER: FLD6BX30D010-FEU6B35-8035-F6LBXVM1-WMH-BTR94

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	109	107	111	109	107	105	105	103	102	101	100	99	98	97	96	94
2	109	104	100	97	106	102	99	96	99	96	94	96	94	92	93	92	90	88
3	104	98	93	89	102	96	92	88	94	90	87	91	88	86	89	87	84	83
4	99	92	87	83	97	91	86	82	89	85	81	87	83	80	85	82	79	78
5	94	87	81	77	93	86	81	77	84	80	76	82	78	75	81	77	75	73
6	90	82	76	72	89	81	76	72	80	75	72	78	74	71	77	73	71	69
7	86	78	72	68	85	77	72	68	76	71	67	74	70	67	73	70	67	65
8	82	74	68	64	81	73	68	64	72	67	64	71	67	63	70	66	63	62
9	79	70	64	61	78	69	64	61	68	64	60	68	63	60	67	63	60	59
10	76	66	61	57	75	66	61	57	65	61	57	65	60	57	64	60	57	56

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	232828
5°	230195
10°	218534
15°	199011
20°	171276
25°	137214
30°	96808
35°	44841
40°	14581
45°	4658
50°	2228
55°	1997
60°	1862
65°	1694
70°	1675
75°	2213
80°	2474
85°	4108



TEST NUMBER: P366201

CATALOG NUMBER: FLD6BX30D010-FEU6B35-8035-F6LBXVM1-WMH-BTR94

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	299.3	13.2
10°-20°	744.6	32.9
20°-30°	785.8	34.7
30°-40°	351.6	15.5
40°-50°	46.0	2.0
50°-60°	14.2	0.6
60°-70°	10.0	0.4
70°-80°	7.9	0.4
80°-90°	4.6	0.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1829.6	80.8
0°-40°	2181.2	96.3
0°-60°	2241.4	99.0
0°-90°	2264.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2264.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	3252	
5°	3203	299
15°	2685	745
25°	1737	786
35°	513	352
45°	46	46
55°	16	14
65°	10	10
75°	8	8
85°	5	5
90°	0	



TEST NUMBER: P366201

CATALOG NUMBER: FLD6BX30D010-FEU6B35-8035-F6LBXVM1-WMH-BTR94

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	3251.7
2.5°	3230.7
5°	3202.7
7.5°	3123.7
10°	3005.7
12.5°	2864.7
15°	2684.7
17.5°	2484.8
20°	2247.8
22.5°	2006.8
25°	1736.8
27.5°	1463.9
30°	1170.9
32.5°	867.9
35°	513.0
37.5°	279.0
40°	156.0
42.5°	87.0
45°	46.0
47.5°	24.0
50°	20.0
52.5°	17.0
55°	16.0
57.5°	14.0
60°	13.0
62.5°	11.0
65°	10.0
67.5°	9.0
70°	8.0
72.5°	8.0
75°	8.0
77.5°	7.0
80°	6.0
82.5°	6.0
85°	5.0
87.5°	3.0
90°	0.0

(END OF REPORT)