

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P364781

Luminaire Tested: **FLD6BX30D010-FEU6B35-8050-F6LBXVM1-LI-BL84**

Issue Date: 3/3/2020

Test Information

Test Method: LM-79-08
Report Number: P364781
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1910-544-43)
Test Lab: INNOVATION CENTER
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD6BX30D010-FEU6B35-8050-F6LBXVM1-LI-BL84
Description: VANDAL RESISTANT ENCLOSED BOTTOM LENS, SPECULAR CLEAR REFLECTOR,
BOTTOM LENS POLYCARBONATE, CLEAR 0.125", 3000LM
Light Source: -
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2745.9 lumens
Efficiency: N/A
Efficacy: 101.7 lumens/watt
Spacing Criteria (0/90/45): 0.78 / 0.78 / 0.82
Luminous Opening: Circular (Dia: 0.71' x H: 0')
CIE Type: Direct


Input Watts (W): 27
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P364781

CATALOG NUMBER: FLD6BX30D010-FEU6B35-8050-F6LBXVM1-LI-BL84

Luminous Intensity Polar Plot





TEST NUMBER: P364781

CATALOG NUMBER: FLD6BX30D010-FEU6B35-8050-F6LBXVM1-LI-BL84

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	114	111	109	107	111	109	107	105	105	103	102		101	100	99		98	97	96	94
2	109	104	100	97	106	102	99	96	99	96	94		96	94	92		93	91	90	88
3	103	97	93	89	101	96	92	88	93	90	87		91	88	85		89	86	84	83
4	99	91	86	82	97	90	85	82	88	84	81		86	83	80		84	81	79	77
5	94	86	80	76	92	85	80	76	83	79	75		82	78	75		80	77	74	73
6	90	81	75	71	88	80	75	71	79	74	71		77	73	70		76	73	70	68
7	85	77	71	67	84	76	71	67	75	70	66		74	69	66		72	69	66	64
8	82	72	67	63	80	72	67	63	71	66	63		70	65	62		69	65	62	61
9	78	69	63	59	77	68	63	59	67	62	59		66	62	59		66	62	59	57
10	74	65	60	56	74	65	60	56	64	59	56		63	59	56		63	58	56	54

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	105650
5°	103641
10°	95711
15°	85289
20°	72836
25°	61170
30°	48021
35°	24883
40°	11885
45°	4678
50°	1232
55°	343
60°	224
65°	200
70°	168
75°	222
80°	157
85°	313



TEST NUMBER: P364781

CATALOG NUMBER: FLD6BX30D010-FEU6B35-8050-F6LBXVM1-LI-BL84

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	350.5	12.8
10°-20°	838.2	30.5
20°-30°	925.5	33.7
30°-40°	509.2	18.5
40°-50°	107.6	3.9
50°-60°	9.1	0.3
60°-70°	2.8	0.1
70°-80°	2.0	0.1
80°-90°	1.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2114.2	77.0
0°-40°	2623.4	95.5
0°-60°	2740.1	99.8
0°-90°	2745.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2745.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3868	
5°	3780	350
15°	3016	838
25°	2030	925
35°	746	509
45°	121	108
55°	7	9
65°	3	3
75°	2	2
85°	1	1
90°	0	



TEST NUMBER: P364781

CATALOG NUMBER: FLD6BX30D010-FEU6B35-8050-F6LBXVM1-LI-BL84

CANDELA DISTRIBUTION (FULL):

	0°
0°	3867.8
2.5°	3865.7
5°	3779.8
7.5°	3647.3
10°	3450.7
12.5°	3255.1
15°	3016.0
17.5°	2772.8
20°	2505.7
22.5°	2271.8
25°	2029.6
27.5°	1795.7
30°	1522.5
32.5°	1162.3
35°	746.2
37.5°	503.0
40°	333.3
42.5°	208.0
45°	121.1
47.5°	62.1
50°	29.0
52.5°	12.4
55°	7.2
57.5°	5.2
60°	4.1
62.5°	3.1
65°	3.1
67.5°	2.1
70°	2.1
72.5°	3.1
75°	2.1
77.5°	1.0
80°	1.0
82.5°	1.0
85°	1.0
87.5°	1.0
90°	0.0

(END OF REPORT)