

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P364840

Luminaire Tested: **FLD6BX40D010-FEU6B35-8035-F6LBXVM1-LI-BL89BV**

Issue Date: 3/3/2020

Test Information

Test Method: LM-79-08
Report Number: P364840
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1910-544-41)
Test Lab: INNOVATION CENTER
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD6BX40D010-FEU6B35-8035-F6LBXVM1-LI-BL89BV
Description: VANDAL RESISTANT ENCLOSED BOTTOM LENS, SPECULAR CLEAR REFLECTOR,
BOTTOM LENS ACRYLIC, CLEAR 0.125", 4000LM
Light Source: -
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3916.0 lumens
Efficiency: N/A
Efficacy: 96.5 lumens/watt
Spacing Criteria (0/90/45): 0.77 / 0.77 / 0.82
Luminous Opening: Circular (Dia: 0.71' x H: 0')
CIE Type: Direct


Input Watts (W): 40.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P364840

CATALOG NUMBER: FLD6BX40D010-FEU6B35-8035-F6LBXVM1-LI-BL89BV

Luminous Intensity Polar Plot





TEST NUMBER: P364840

CATALOG NUMBER: FLD6BX40D010-FEU6B35-8035-F6LBXVM1-LI-BL89BV

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	114	111	109	107	111	109	107	105	105	103	102		101	100	99		98	97	96	94
2	109	104	100	97	106	102	99	96	99	96	94		96	94	92		93	91	90	88
3	103	97	93	89	101	96	92	88	93	90	87		91	88	85		89	86	84	83
4	99	91	86	82	97	90	85	82	88	84	81		86	83	80		84	81	79	77
5	94	86	81	76	92	85	80	76	83	79	75		82	78	75		80	77	74	73
6	90	81	75	71	88	80	75	71	79	74	71		77	73	70		76	73	70	68
7	85	77	71	67	84	76	71	67	75	70	66		74	69	66		72	69	66	64
8	82	73	67	63	80	72	67	63	71	66	63		70	65	62		69	65	62	61
9	78	69	63	59	77	68	63	59	67	62	59		66	62	59		66	62	59	57
10	74	65	60	56	74	65	60	56	64	59	56		63	59	56		63	59	56	54

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	151613
5°	148535
10°	137124
15°	121893
20°	104024
25°	87156
30°	68308
35°	36017
40°	16827
45°	6617
50°	1730
55°	467
60°	306
65°	271
70°	224
75°	296
80°	220
85°	439



TEST NUMBER: P364840

CATALOG NUMBER: FLD6BX40D010-FEU6B35-8035-F6LBXVM1-LI-BL89BV

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	501.3	12.8
10°-20°	1197.0	30.6
20°-30°	1316.7	33.6
30°-40°	726.8	18.6
40°-50°	153.3	3.9
50°-60°	12.5	0.3
60°-70°	3.8	0.1
70°-80°	3.1	0.1
80°-90°	1.3	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3015.0	77.0
0°-40°	3741.8	95.6
0°-60°	3907.7	99.8
0°-90°	3916.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3916.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	5550	
5°	5417	501
15°	4310	1197
25°	2892	1317
35°	1080	727
45°	171	153
55°	10	12
65°	4	4
75°	3	3
85°	1	1
90°	0	



TEST NUMBER: P364840

CATALOG NUMBER: FLD6BX40D010-FEU6B35-8035-F6LBXVM1-LI-BL89BV

CANDELA DISTRIBUTION (FULL):

0°	
0°	5550.5
2.5°	5508.4
5°	5417.1
7.5°	5210.7
10°	4943.8
12.5°	4637.6
15°	4310.4
17.5°	3959.3
20°	3578.6
22.5°	3233.1
25°	2891.8
27.5°	2544.9
30°	2165.7
32.5°	1648.9
35°	1080.1
37.5°	717.7
40°	471.9
42.5°	297.8
45°	171.3
47.5°	89.9
50°	40.7
52.5°	16.9
55°	9.8
57.5°	7.0
60°	5.6
62.5°	4.2
65°	4.2
67.5°	2.8
70°	2.8
72.5°	4.2
75°	2.8
77.5°	2.8
80°	1.4
82.5°	1.4
85°	1.4
87.5°	1.4
90°	0.0

(END OF REPORT)