

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P366288

Luminaire Tested: **FLD6BX40D010-FEU6B35-8035-F6LBXVM1-WMH-BTR87**

Issue Date: 3/3/2020

Test Information

Test Method: LM-79-08
Report Number: P366288
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1910-544-30)
Test Lab: INNOVATION CENTER
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD6BX40D010-FEU6B35-8035-F6LBXVM1-WMH-BTR87
Description: VANDAL RESISTANT ENCLOSED BOTTOM TRIM RING, WARM HAZE REFLECTOR,
BOTTOM TRIM POLYCARBONATE, CLEAR 0.375", 4000LM
Light Source: -
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3062.9 lumens
Efficiency: N/A
Efficacy: 75.4 lumens/watt
Spacing Criteria (0/90/45): 0.81 / 0.81 / 0.8
Luminous Opening: Circular (Dia: 0.44' x H: 0')
CIE Type: Direct


Input Watts (W): 40.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P366288

CATALOG NUMBER: FLD6BX40D010-FEU6B35-8035-F6LBXVM1-WMH-BTR87

Luminous Intensity Polar Plot





TEST NUMBER: P366288

CATALOG NUMBER: FLD6BX40D010-FEU6B35-8035-F6LBXVM1-WMH-BTR87

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	109	107	111	109	107	105	105	103	102	101	100	99	98	97	96	94
2	109	104	100	97	106	102	99	96	99	96	94	96	94	92	93	92	90	88
3	104	98	93	89	102	96	92	89	94	90	87	91	88	86	89	87	84	83
4	99	92	87	83	97	91	86	82	89	85	81	87	83	80	85	82	80	78
5	94	87	81	77	93	86	81	77	84	80	76	82	79	76	81	78	75	74
6	90	82	76	72	89	81	76	72	80	75	72	78	74	71	77	74	71	69
7	86	78	72	68	85	77	72	68	76	71	68	75	70	67	73	70	67	66
8	82	74	68	64	81	73	68	64	72	67	64	71	67	64	70	66	63	62
9	79	70	64	61	78	69	64	61	69	64	60	68	63	60	67	63	60	59
10	76	67	61	58	75	66	61	58	65	61	57	65	60	57	64	60	57	56

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	316681
5°	311465
10°	296780
15°	271189
20°	232561
25°	186599
30°	130831
35°	60444
40°	19404
45°	6268
50°	2907
55°	2572
60°	2563
65°	2321
70°	2303
75°	2656
80°	3381
85°	5669



TEST NUMBER: P366288

CATALOG NUMBER: FLD6BX40D010-FEU6B35-8035-F6LBXVM1-WMH-BTR87

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	406.4	13.3
10°-20°	1012.4	33.1
20°-30°	1063.2	34.7
30°-40°	471.8	15.4
40°-50°	61.0	2.0
50°-60°	19.0	0.6
60°-70°	13.4	0.4
70°-80°	9.8	0.3
80°-90°	6.0	0.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2482.0	81.0
0°-40°	2953.8	96.4
0°-60°	3033.8	99.0
0°-90°	3062.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3062.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	4423	
5°	4333	406
15°	3658	1012
25°	2362	1063
35°	692	472
45°	62	61
55°	21	19
65°	14	13
75°	10	10
85°	7	6
90°	0	



TEST NUMBER: P366288

CATALOG NUMBER: FLD6BX40D010-FEU6B35-8035-F6LBXVM1-WMH-BTR87

CANDELA DISTRIBUTION (FULL):

	0°
0°	4422.8
2.5°	4395.3
5°	4333.4
7.5°	4249.6
10°	4081.9
12.5°	3893.5
15°	3658.4
17.5°	3376.6
20°	3052.1
22.5°	2711.2
25°	2361.9
27.5°	1970.1
30°	1582.4
32.5°	1163.1
35°	691.5
37.5°	368.5
40°	207.6
42.5°	114.1
45°	61.9
47.5°	31.6
50°	26.1
52.5°	23.4
55°	20.6
57.5°	19.2
60°	17.9
62.5°	15.1
65°	13.7
67.5°	11.0
70°	11.0
72.5°	9.6
75°	9.6
77.5°	8.2
80°	8.2
82.5°	6.9
85°	6.9
87.5°	4.1
90°	0.0

(END OF REPORT)