

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P365633

Luminaire Tested: **FLD6BX50D010TE-FEU6B35-8030-F6LBXVM1-MW-BL89BW**

Issue Date: 3/3/2020

Test Information

Test Method: LM-79-08
Report Number: P365633
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1910-544-35)
Test Lab: INNOVATION CENTER
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD6BX50D010TE-FEU6B35-8030-F6LBXVM1-MW-BL89BW
Description: VANDAL RESISTANT ENCLOSED BOTTOM LENS, MATTE WHITE REFLECTOR, BOTTOM LENS ACRYLIC OPAL SMOOTH, CLEAR 0.125", 5000LM
Light Source: -
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3083.0 lumens
Efficiency: N/A
Efficacy: 56.0 lumens/watt
Spacing Criteria (0/90/45): 1.24 / 1.24 / 1.37
Luminous Opening: Circular (Dia: 0.71' x H: 0')
CIE Type: Direct


Input Watts (W): 55.1
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P365633

CATALOG NUMBER: FLD6BX50D010TE-FEU6B35-8030-F6LBXVM1-MW-BL89BW

Luminous Intensity Polar Plot





TEST NUMBER: P365633

CATALOG NUMBER: FLD6BX50D010TE-FEU6B35-8030-F6LBXVM1-MW-BL89BW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	109	104	100	96	106	102	98	95	98	94	92		94	91	89		90	88	86	84
2	99	91	84	78	96	89	83	77	85	80	75		82	78	74		79	75	72	70
3	90	80	71	65	88	78	70	64	75	69	63		72	67	62		70	65	61	59
4	83	71	62	55	80	69	61	55	67	60	54		64	58	53		62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	47		58	51	46		56	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41		52	45	40		51	45	40	38
7	65	51	43	36	63	51	42	36	49	41	36		48	41	36		46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32		44	37	32		42	36	32	30
9	56	43	35	29	55	42	35	29	41	34	29		40	34	29		39	33	29	27
10	53	40	32	26	52	39	32	26	38	31	26		37	31	26		36	30	26	24

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	30014
5°	30035
10°	29861
15°	29721
20°	29408
25°	29256
30°	28945
35°	28607
40°	28273
45°	27925
50°	27452
55°	26935
60°	26048
65°	25071
70°	23472
75°	20918
80°	16941
85°	10186



TEST NUMBER: P365633

CATALOG NUMBER: FLD6BX50D010TE-FEU6B35-8030-F6LBXVM1-MW-BL89BW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	103.9	3.4
10°-20°	296.4	9.6
20°-30°	446.6	14.5
30°-40°	537.0	17.4
40°-50°	557.3	18.1
50°-60°	505.1	16.4
60°-70°	383.3	12.4
70°-80°	209.7	6.8
80°-90°	43.9	1.4
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	846.8	27.5
0°-40°	1383.8	44.9
0°-60°	2446.2	79.3
0°-90°	3083.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3083.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1099	
5°	1095	104
15°	1051	296
25°	971	447
35°	858	537
45°	723	557
55°	566	505
65°	388	383
75°	198	210
85°	32	44
90°	0	



TEST NUMBER: P365633

CATALOG NUMBER: FLD6BX50D010TE-FEU6B35-8030-F6LBXVM1-MW-BL89BW

CANDELA DISTRIBUTION (FULL):

	0°
0°	1098.8
2.5°	1097.1
5°	1095.4
7.5°	1086.9
10°	1076.6
12.5°	1066.4
15°	1051.0
17.5°	1033.9
20°	1011.7
22.5°	989.5
25°	970.7
27.5°	945.0
30°	917.7
32.5°	888.6
35°	857.9
37.5°	827.1
40°	792.9
42.5°	758.8
45°	722.9
47.5°	685.3
50°	646.0
52.5°	606.7
55°	565.6
57.5°	524.6
60°	476.8
62.5°	434.1
65°	387.9
67.5°	341.8
70°	293.9
72.5°	246.1
75°	198.2
77.5°	150.4
80°	107.7
82.5°	66.6
85°	32.5
87.5°	8.5
90°	0.0

(END OF REPORT)