

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions  
(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P365681

Luminaire Tested: **FLD6BX50D010TE-FEU6B35-8050-F6LBXVM1-MW-BL84**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-79-08  
Report Number: P365681  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1910-544-36)  
Test Lab: INNOVATION CENTER  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: FAIL-SAFE  
Catalog Number: FLD6BX50D010TE-FEU6B35-8050-F6LBXVM1-MW-BL84  
Description: VANDAL RESISTANT ENCLOSED BOTTOM LENS, MATTE WHITE REFLECTOR, BOTTOM LENS POLYCARBONATE, CLEAR 0.125", 5000LM  
Light Source: -  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 4157.0 lumens  
Efficiency: N/A  
Efficacy: 75.4 lumens/watt  
Spacing Criteria (0/90/45): 0.94 / 0.94 / 0.95  
Luminous Opening: Circular (Dia: 0.71' x H: 0')  
CIE Type: Direct


Input Watts (W): 55.1  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P365681

CATALOG NUMBER: FLD6BX50D010TE-FEU6B35-8050-F6LBXVM1-MW-BL84

### Luminous Intensity Polar Plot





TEST NUMBER: P365681

CATALOG NUMBER: FLD6BX50D010TE-FEU6B35-8050-F6LBXVM1-MW-BL84

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	112	108	105	102	109	106	103	101	102	100	97		98	96	95		95	93	92	90
2	104	98	93	89	102	96	92	88	93	89	86		90	87	84		87	84	82	80
3	97	89	83	78	95	88	82	77	85	80	76		82	78	75		80	77	74	72
4	91	82	75	70	89	80	74	69	78	73	68		76	71	67		74	70	67	65
5	85	75	68	63	84	74	67	62	72	66	62		70	65	61		69	64	61	59
6	80	69	62	57	78	68	62	57	67	61	56		65	60	56		64	59	55	54
7	75	64	57	52	74	64	57	52	62	56	52		61	55	51		60	55	51	49
8	71	60	53	48	70	59	52	48	58	52	47		57	51	47		56	51	47	45
9	67	56	49	44	66	55	49	44	54	48	44		53	48	44		52	47	44	42
10	64	52	46	41	62	52	45	41	51	45	41		50	45	41		49	44	41	39

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	92096
5°	90221
10°	85703
15°	80179
20°	74804
25°	68636
30°	58613
35°	44683
40°	32905
45°	24974
50°	20338
55°	17887
60°	15985
65°	14122
70°	11972
75°	9340
80°	6245
85°	2821



TEST NUMBER: P365681

CATALOG NUMBER: FLD6BX50D010TE-FEU6B35-8050-F6LBXVM1-MW-BL84

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	307.6	7.4
10°-20°	795.6	19.1
20°-30°	1034.1	24.9
30°-40°	842.6	20.3
40°-50°	511.4	12.3
50°-60°	338.5	8.1
60°-70°	217.1	5.2
70°-80°	95.8	2.3
80°-90°	14.2	0.3
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2137.3	51.4
0°-40°	2979.9	71.7
0°-60°	3829.8	92.1
0°-90°	4157.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4157.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	3372	
5°	3290	308
15°	2835	796
25°	2277	1034
35°	1340	843
45°	646	511
55°	376	338
65°	218	217
75°	88	96
85°	9	14
90°	0	



TEST NUMBER: P365681

CATALOG NUMBER: FLD6BX50D010TE-FEU6B35-8050-F6LBXVM1-MW-BL84

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	3371.6
2.5°	3350.0
5°	3290.4
7.5°	3200.1
10°	3089.9
12.5°	2967.1
15°	2835.3
17.5°	2699.8
20°	2573.4
22.5°	2436.2
25°	2277.3
27.5°	2089.4
30°	1858.3
32.5°	1598.2
35°	1340.0
37.5°	1110.6
40°	922.8
42.5°	765.7
45°	646.5
47.5°	552.6
50°	478.6
52.5°	422.6
55°	375.6
57.5°	332.3
60°	292.6
62.5°	254.6
65°	218.5
67.5°	184.2
70°	149.9
72.5°	117.4
75°	88.5
77.5°	63.2
80°	39.7
82.5°	21.7
85°	9.0
87.5°	1.8
90°	0.0

(END OF REPORT)