

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P366437

Luminaire Tested: **FLD6BX60D010TE-FEU6B67-8030-F6LBXVM1-WMH-BL84**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-79-08  
Report Number: P366437  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-1910-544-47)  
Test Lab: INNOVATION CENTER  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: FAIL-SAFE  
Catalog Number: FLD6BX60D010TE-FEU6B67-8030-F6LBXVM1-WMH-BL84  
Description: VANDAL RESISTANT ENCLOSED BOTTOM LENS, WARM HAZE REFLECTOR, BOTTOM LENS POLYCARBONATE, CLEAR 0.125", 6000LM  
Light Source: -  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 5235.0 lumens  
Efficiency: N/A  
Efficacy: 90.1 lumens/watt  
Spacing Criteria (0/90/45): 0.83 / 0.83 / 0.85  
Luminous Opening: Circular (Dia: 0.71' x H: 0')  
CIE Type: Direct


Input Watts (W): 58.1  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P366437

CATALOG NUMBER: FLD6BX60D010TE-FEU6B67-8030-F6LBXVM1-WMH-BL84

### Luminous Intensity Polar Plot





TEST NUMBER: P366437

CATALOG NUMBER: FLD6BX60D010TE-FEU6B67-8030-F6LBXVM1-WMH-BL84

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	114	111	109	106	111	109	107	105	105	103	102		101	100	99		98	97	96	94
2	108	104	100	97	106	102	98	95	99	96	93		96	93	91		93	91	89	88
3	103	97	92	88	101	96	91	88	93	89	86		91	88	85		88	86	84	82
4	98	91	86	82	96	90	85	81	88	83	80		86	82	79		84	81	78	77
5	93	85	80	76	92	85	79	75	83	78	75		81	77	74		80	76	73	72
6	89	80	75	71	88	80	74	70	78	73	70		77	73	69		76	72	69	68
7	85	76	70	66	83	75	70	66	74	69	65		73	68	65		72	68	65	63
8	81	72	66	62	80	71	66	62	70	65	62		69	65	61		68	64	61	60
9	77	68	62	58	76	67	62	58	66	62	58		66	61	58		65	61	58	56
10	74	64	59	55	73	64	59	55	63	58	55		62	58	55		62	58	55	53

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	184162
5°	183388
10°	174208
15°	158243
20°	137699
25°	117069
30°	92090
35°	52543
40°	23641
45°	9951
50°	3140
55°	952
60°	656
65°	517
70°	479
75°	633
80°	315
85°	627



TEST NUMBER: P366437

CATALOG NUMBER: FLD6BX60D010TE-FEU6B67-8030-F6LBXVM1-WMH-BL84

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	625.6	12.0
10°-20°	1556.6	29.7
20°-30°	1763.9	33.7
30°-40°	1022.5	19.5
40°-50°	226.8	4.3
50°-60°	24.9	0.5
60°-70°	8.1	0.2
70°-80°	5.3	0.1
80°-90°	1.4	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3946.1	75.4
0°-40°	4968.6	94.9
0°-60°	5220.3	99.7
0°-90°	5235.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5235.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	6742	
5°	6688	626
15°	5596	1557
25°	3884	1764
35°	1576	1023
45°	258	227
55°	20	25
65°	8	8
75°	6	5
85°	2	1
90°	0	



TEST NUMBER: P366437

CATALOG NUMBER: FLD6BX60D010TE-FEU6B67-8030-F6LBXVM1-WMH-BL84

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	6742.1
2.5°	6748.1
5°	6688.2
7.5°	6542.4
10°	6280.8
12.5°	5963.3
15°	5595.8
17.5°	5208.4
20°	4737.1
22.5°	4311.7
25°	3884.3
27.5°	3429.0
30°	2919.7
32.5°	2318.6
35°	1575.7
37.5°	1012.5
40°	663.0
42.5°	433.4
45°	257.6
47.5°	143.8
50°	73.9
52.5°	34.0
55°	20.0
57.5°	16.0
60°	12.0
62.5°	10.0
65°	8.0
67.5°	6.0
70°	6.0
72.5°	6.0
75°	6.0
77.5°	4.0
80°	2.0
82.5°	2.0
85°	2.0
87.5°	0.0
90°	0.0

(END OF REPORT)