

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P574908

Luminaire Tested: **FLD6C-10-D010 FEU6C-X-90-40 F6X-N-X-H**

Issue Date: 3/1/2023



Test Information

Test Method: LM-79-08
Report Number: P574908
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P203666)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/1/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD6C-10-D010 FEU6C-X-90-40 F6X-N-X-H
Description: 6 INCH FAIL-SAFE LED DOWNLIGHT WITH 4000K, 90 CRI LEDS, 6LBNH TRIM

Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 658.0 lumens
Efficiency: N/A
Efficacy: 67.5 lumens/watt
Spacing Criteria (0/90/45): 0.78 / 0.78 / 0.84
Luminous Opening: Circular (Dia: 0.5' x H: 0')
CIE Type: Direct

Input Watts (W): 9.75
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P574908

CATALOG NUMBER: FLD6C-10-D010 FEU6C-X-90-40 F6X-N-X-H

Luminous Intensity Polar Plot





TEST NUMBER: P574908

CATALOG NUMBER: FLD6C-10-D010 FEU6C-X-90-40 F6X-N-X-H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	113	111	108	106	111	109	106	104	104	103	101	101	99	98	97	96	95	93
2	108	103	99	96	106	101	98	94	98	95	92	95	93	90	92	90	89	87
3	102	96	91	87	100	95	90	86	92	88	85	90	86	84	87	85	82	81
4	97	90	84	80	95	89	83	79	86	82	78	84	81	78	83	79	77	75
5	92	84	78	74	91	83	78	73	81	76	73	80	75	72	78	74	72	70
6	88	79	73	69	86	78	72	68	77	72	68	75	71	67	74	70	67	65
7	83	74	68	64	82	73	68	64	72	67	63	71	66	63	70	66	63	61
8	79	70	64	60	78	69	64	60	68	63	59	67	63	59	66	62	59	58
9	76	66	60	56	75	66	60	56	65	59	56	64	59	56	63	59	55	54
10	72	62	57	53	71	62	57	53	61	56	53	60	56	52	60	55	52	51

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	46241
5°	45097
10°	41610
15°	36839
20°	31987
25°	27358
30°	22554
35°	14857
40°	7986
45°	3535
50°	1433
55°	1032
60°	658
65°	467
70°	385
75°	254
80°	379
85°	0



TEST NUMBER: P574908

CATALOG NUMBER: FLD6C-10-D010 FEU6C-X-90-40 F6X-N-X-H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	75.9	11.5
10°-20°	180.9	27.5
20°-30°	207.2	31.5
30°-40°	139.2	21.2
40°-50°	39.8	6.0
50°-60°	9.7	1.5
60°-70°	3.7	0.6
70°-80°	1.4	0.2
80°-90°	0.2	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	463.9	70.5
0°-40°	603.2	91.7
0°-60°	652.7	99.2
0°-90°	658.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	658.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	844	
5°	820	76
15°	649	181
25°	452	207
35°	222	139
45°	46	40
55°	11	10
65°	4	4
75°	1	1
85°	0	0
90°	0	



TEST NUMBER: P574908

CATALOG NUMBER: FLD6C-10-D010 FEU6C-X-90-40 F6X-N-X-H

CANDELA DISTRIBUTION (FULL):

	0°
0°	843.5
2.5°	837.5
5°	819.5
7.5°	787.1
10°	747.5
12.5°	697.1
15°	649.1
17.5°	598.7
20°	548.3
22.5°	500.3
25°	452.3
27.5°	407.9
30°	356.3
32.5°	287.9
35°	222.0
37.5°	162.0
40°	111.6
42.5°	73.2
45°	45.6
47.5°	27.6
50°	16.8
52.5°	13.2
55°	10.8
57.5°	8.4
60°	6.0
62.5°	4.8
65°	3.6
67.5°	2.4
70°	2.4
72.5°	1.2
75°	1.2
77.5°	1.2
80°	1.2
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180°







(END OF REPORT)