

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P574998

Luminaire Tested: **FLD6C-10-D010 FEU6C-X-90-50 F6X-W-X-LI**

Issue Date: 3/1/2023



**Test Information**

Test Method: LM-79-08  
Report Number: P574998  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P205209)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/1/2023  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: FAIL-SAFE  
Catalog Number: FLD6C-10-D010 FEU6C-X-90-50 F6X-W-X-LI  
Description: 6 INCH FAIL-SAFE LED DOWNLIGHT WITH 5000K, 90 CRI LEDS, 6LBWLI TRIM

Light Source: -  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 1079.0 lumens  
Efficiency: N/A  
Efficacy: 110.7 lumens/watt  
Spacing Criteria (0/90/45): 1.24 / 1.24 / 1.18  
Luminous Opening: Circular (Dia: 0.5' x H: 0')  
CIE Type: Direct

Input Watts (W): 9.75  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT

TEST NUMBER: P574998

CATALOG NUMBER: FLD6C-10-D010 FEU6C-X-90-50 F6X-W-X-LI

### Luminous Intensity Polar Plot





TEST NUMBER: P574998

CATALOG NUMBER: FLD6C-10-D010 FEU6C-X-90-50 F6X-W-X-LI

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	113	110	107	104	110	107	105	103	103	101	99	100	98	97	96	95	94	92			
2	106	101	96	92	104	99	95	91	95	92	89	92	90	87	90	87	85	83			
3	100	92	87	82	97	91	86	81	88	84	80	86	82	79	83	80	77	76			
4	93	85	78	73	92	84	78	73	81	76	72	79	75	71	77	74	70	69			
5	88	78	71	66	86	77	71	66	75	70	65	73	69	65	72	68	64	63			
6	82	72	65	60	81	71	65	60	70	64	59	68	63	59	67	62	59	57			
7	77	67	60	55	76	66	59	55	65	59	54	63	58	54	62	57	54	52			
8	73	62	55	50	71	61	55	50	60	54	50	59	54	50	58	53	49	48			
9	69	57	51	46	67	57	50	46	56	50	46	55	50	46	54	49	46	44			
10	65	54	47	43	64	53	47	42	52	46	42	51	46	42	51	46	42	41			

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	36954
5°	37294
10°	38337
15°	39296
20°	39892
25°	39069
30°	36632
35°	32752
40°	26528
45°	17544
50°	8870
55°	3747
60°	1206
65°	480
70°	401
75°	254
80°	0
85°	0



TEST NUMBER: P574998

CATALOG NUMBER: FLD6C-10-D010 FEU6C-X-90-50 F6X-W-X-LI

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	65.0	6.0
10°-20°	195.5	18.1
20°-30°	294.6	27.3
30°-40°	301.6	28.0
40°-50°	175.7	16.3
50°-60°	40.4	3.7
60°-70°	5.0	0.5
70°-80°	1.3	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	555.1	51.4
0°-40°	856.7	79.4
0°-60°	1072.8	99.4
0°-90°	1079.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1079.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	674	
5°	678	65
15°	692	195
25°	646	295
35°	489	302
45°	226	176
55°	39	40
65°	4	5
75°	1	1
85°	0	0
90°	0	



TEST NUMBER: P574998

CATALOG NUMBER: FLD6C-10-D010 FEU6C-X-90-50 F6X-W-X-LI

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	674.1
2.5°	672.8
5°	677.7
7.5°	682.6
10°	688.7
12.5°	690.0
15°	692.4
17.5°	690.0
20°	683.8
22.5°	664.3
25°	645.9
27.5°	616.6
30°	578.7
32.5°	539.5
35°	489.4
37.5°	433.1
40°	370.7
42.5°	300.9
45°	226.3
47.5°	157.8
50°	104.0
52.5°	66.1
55°	39.2
57.5°	20.8
60°	11.0
62.5°	6.1
65°	3.7
67.5°	3.7
70°	2.5
72.5°	1.2
75°	1.2
77.5°	1.2
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC







— 0°-180°







(END OF REPORT)