

LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P#

Luminaire Tested: **FLDSQ4C30D010 FEU4C309027 F4LC-CSSQ-MW**

Issue Date: 12/13/2022

Tested By:

Approved By:



Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.



Test Information

Test Method: LM-79-08
 Report Number: P#
 Test Lab: INNOVATION CENTER
 Issue Date: 12/13/2022
 Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
 Product Line: FAIL-SAFE
 Catalog Number: FLDSQ4C30D010 FEU4C309027 F4LC-CSSQ-MW
 Description: 4 INCH 3000 LUMEN FAIL-SAFE LED DOWNLIGHT WITH, 2700K, 90CRI LEDS AND F4LC-CSSQ TRIM WITH MW FINISH
 Light Source: -
 Ballast/Driver: -

Summary


Lumens per Lamp: N/A
 Luminaire Lumens: 2773.0 lumens
 Efficiency: N/A
 Efficacy: 87.8 lumens/watt
 Spacing Criteria (0/90/45): 1.19 / 1.2 / 1.29
 Luminous Opening: Rectangular (W 0.33' x L: 0.33' x H: 0')
 CIE Type: Direct

Input Watts (W): 31.6
 Input Voltage (V):
 Input Current (Ain): NR
 Voltage Rise (V): NR
 Power Factor: NR
 Total Harmonic Distortion (THDi): NR
 Frequency (hertz): 60
 Stabilization Time: NR
 Operation Time: NR
 Ambient Temperature (°C): NR
 Test Distance: 25 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	GONIO 1 IN0055	4/22/2021	10/22/2021
Power Meter	XITRON 2801 IN0197	12/1/2020	12/1/2021
AC Power Source	CHROMA 61505 IN0196	12/1/2020	12/1/2021
DC Power Supply	AGILENT E3634A IN0198	11/30/2020	11/30/2021
Room Thermometer	ONSET IN0143	12/1/2020	12/1/2021

TEST NUMBER: P#
CATALOG NUMBER: FLDSQ4C30D010 FEU4C309027 F4LC-CSSQ-MW

Luminous Intensity Polar Plot



TEST NUMBER: P#

CATALOG NUMBER: FLDSQ4C30D010 FEU4C309027 F4LC-CSSQ-MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	111	108	104	101	109	105	102	100	101	99	96		97	95	94		94	92	91	89
2	103	96	91	86	100	94	89	85	91	87	83		88	84	81		85	82	79	77
3	95	86	79	74	93	85	78	73	82	76	72		79	74	71		77	73	69	67
4	88	77	70	64	86	76	69	63	74	67	63		71	66	62		69	65	61	59
5	81	70	62	56	79	69	61	56	67	60	55		65	59	54		63	58	54	52
6	75	63	55	49	73	62	55	49	61	54	49		59	53	48		57	52	48	46
7	70	58	50	44	68	57	49	44	55	49	44		54	48	43		53	47	43	41
8	65	53	45	40	64	52	45	39	51	44	39		50	44	39		49	43	39	37
9	61	49	41	36	60	48	41	36	47	40	36		46	40	35		45	39	35	33
10	57	45	38	33	56	44	37	33	44	37	32		43	37	32		42	36	32	31

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	125252	125252	125252
5°	123232	124840	125198
10°	124294	123932	124470
15°	122119	122299	122668
20°	119285	121174	120609
25°	118760	118760	119548
30°	115449	116274	116485
35°	111855	112938	110983
40°	106610	108689	107756
45°	100895	103161	99886
50°	88850	96596	88295
55°	71966	88401	72269
60°	52664	73293	51602
65°	32009	52192	31165
70°	12469	28099	11962
75°	1379	7568	1379
80°	1056	1056	1056
85°	0	0	0

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C30D010 FEU4C309027 F4LC-CSSQ-MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	122.5	4.4
10°-20°	346.7	12.5
20°-30°	514.5	18.6
30°-40°	596.1	21.5
40°-50°	571.5	20.6
50°-60°	420.2	15.2
60°-70°	181.5	6.5
70°-80°	19.6	0.7
80°-90°	0.3	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	983.7	35.5
0°-40°	1579.9	57.0
0°-60°	2571.6	92.7
0°-90°	2773.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2773.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1298	1298	1298	1298	1298	
5°	1272	1285	1289	1291	1293	121
15°	1222	1230	1224	1226	1228	345
25°	1116	1114	1116	1117	1123	511
35°	950	955	959	957	942	594
45°	739	741	756	745	732	562
55°	428	472	526	470	430	385
65°	140	175	229	173	136	144
75°	4	6	20	4	4	11
85°	0	0	0	0	0	0
90°	0	0	0	0	0	



TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C30D010 FEU4C309027 F4LC-CSSQ-MW

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	22.5°	25°	30°	35°	40°	45°
0°	1298.1	1298.1	1298.1	1298.1	1298.1	1298.1	1298.1	1298.1	1298.1	1298.1	1298.1
2.5°	1288.9	1303.6	1305.5	1296.2	1292.6	1287.1	1299.9	1290.8	1294.4	1290.8	1288.9
5°	1272.3	1288.9	1290.8	1290.8	1287.1	1285.2	1290.8	1288.9	1287.1	1283.4	1288.9
7.5°	1264.9	1274.1	1283.4	1272.3	1277.8	1276.0	1288.9	1283.4	1281.5	1281.5	1277.8
10°	1268.6	1266.8	1274.1	1263.1	1266.8	1263.1	1274.1	1274.1	1270.4	1266.8	1264.9
12.5°	1239.1	1253.8	1253.8	1252.0	1248.3	1242.8	1253.8	1261.3	1250.1	1250.1	1248.3
15°	1222.5	1226.2	1228.0	1228.0	1226.2	1229.9	1235.4	1228.0	1229.9	1220.6	1224.3
17.5°	1204.1	1196.7	1202.2	1198.5	1200.4	1204.1	1211.5	1211.5	1200.4	1198.5	1202.2
20°	1161.7	1183.8	1185.7	1174.6	1176.4	1176.4	1189.3	1178.3	1185.7	1176.4	1180.1
22.5°	1141.3	1156.1	1158.0	1143.2	1152.4	1141.3	1154.3	1137.7	1156.1	1143.2	1148.7
25°	1115.5	1113.7	1119.2	1111.9	1113.7	1113.7	1122.9	1115.5	1121.1	1113.7	1115.5
27.5°	1073.2	1087.9	1086.0	1078.7	1082.4	1080.6	1099.0	1078.7	1089.7	1080.6	1084.2
30°	1036.2	1049.2	1045.5	1038.1	1038.1	1032.6	1052.9	1047.3	1045.5	1045.5	1043.6
32.5°	999.4	1001.3	997.6	999.4	1001.3	993.9	1010.4	1003.1	1001.3	1003.1	1004.9
35°	949.6	949.6	953.3	947.8	955.1	955.1	969.9	960.6	958.8	953.3	958.8
37.5°	905.3	899.8	901.7	901.7	905.3	909.0	916.4	912.7	912.7	907.2	910.9
40°	846.4	842.7	848.2	848.2	853.7	853.7	861.1	857.4	862.9	862.9	862.9
42.5°	794.7	794.7	791.1	796.6	798.4	796.6	809.5	807.6	809.5	805.8	807.6
45°	739.4	739.4	735.7	733.9	743.1	741.3	756.0	750.4	757.8	754.1	756.0
47.5°	663.8	673.0	667.5	673.0	684.1	686.0	695.1	691.5	698.8	693.3	700.7
50°	591.9	591.9	597.4	604.8	615.8	617.7	628.8	636.2	639.8	641.7	643.5
52.5°	516.3	514.4	520.0	529.2	538.4	545.8	556.9	567.9	575.3	586.4	580.8
55°	427.8	431.5	437.0	448.1	462.8	472.0	481.3	496.0	508.9	514.4	525.5
57.5°	352.2	348.5	352.2	366.9	383.5	390.9	403.8	418.6	437.0	448.1	451.8
60°	272.9	274.7	278.4	291.4	304.2	315.3	320.9	344.8	361.4	372.5	379.8
62.5°	201.0	204.7	208.4	219.5	232.3	241.6	250.7	271.1	285.8	296.9	304.2
65°	140.2	142.0	147.5	153.0	166.0	175.1	182.5	199.1	213.9	223.1	228.6
67.5°	86.7	88.5	92.2	99.6	108.8	116.2	123.5	134.6	147.5	156.7	158.6
70°	44.2	46.1	47.9	53.5	60.9	64.5	70.0	79.3	88.5	95.8	99.6
72.5°	14.7	14.7	16.6	20.3	24.0	27.7	29.5	38.7	46.1	49.8	51.6
75°	3.7	3.7	3.7	3.7	3.7	5.6	5.6	11.1	14.7	18.4	20.3
77.5°	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	3.7	3.7
80°	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0



TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C30D010 FEU4C309027 F4LC-CSSQ-MW

CANDELA DISTRIBUTION (continued):

	50°	55°	60°	65°	67.5°	70°	75°	80°	85°	90°
0°	1298.1	1298.1	1298.1	1298.1	1298.1	1298.1	1298.1	1298.1	1298.1	1298.1
2.5°	1298.1	1294.4	1292.6	1294.4	1294.4	1292.6	1298.1	1305.5	1314.7	1290.8
5°	1296.2	1292.6	1296.2	1285.2	1290.8	1287.1	1294.4	1292.6	1299.9	1292.6
7.5°	1290.8	1283.4	1285.2	1279.7	1287.1	1277.8	1283.4	1294.4	1287.1	1276.0
10°	1272.3	1268.6	1281.5	1263.1	1259.4	1266.8	1281.5	1270.4	1266.8	1270.4
12.5°	1253.8	1253.8	1259.4	1244.6	1246.4	1250.1	1257.5	1250.1	1253.8	1263.1
15°	1233.6	1229.9	1239.1	1228.0	1226.2	1222.5	1229.9	1229.9	1233.6	1228.0
17.5°	1209.6	1204.1	1204.1	1200.4	1198.5	1207.8	1211.5	1213.3	1215.1	1207.8
20°	1180.1	1178.3	1183.8	1178.3	1180.1	1182.0	1182.0	1178.3	1194.8	1174.6
22.5°	1148.7	1154.3	1146.9	1143.2	1146.9	1150.6	1150.6	1152.4	1148.7	1145.0
25°	1117.4	1121.1	1122.9	1111.9	1117.4	1111.9	1124.8	1126.6	1119.2	1122.9
27.5°	1089.7	1084.2	1082.4	1075.0	1078.7	1076.9	1078.7	1078.7	1089.7	1075.0
30°	1047.3	1041.8	1043.6	1038.1	1039.9	1038.1	1039.9	1039.9	1047.3	1045.5
32.5°	1006.8	1001.3	1003.1	997.6	997.6	999.4	995.7	995.7	1001.3	997.6
35°	968.0	955.1	957.0	955.1	957.0	949.6	949.6	947.8	951.5	942.2
37.5°	912.7	907.2	905.3	903.5	905.3	901.7	905.3	899.8	905.3	898.0
40°	862.9	859.2	861.1	850.0	850.0	851.9	848.2	846.4	848.2	855.5
42.5°	813.2	805.8	802.1	798.4	800.2	794.7	792.9	789.2	792.9	785.5
45°	754.1	754.1	752.3	743.1	744.9	744.9	737.6	730.2	732.0	732.0
47.5°	700.7	697.0	695.1	686.0	684.1	682.3	674.8	669.3	669.3	663.8
50°	641.7	638.0	632.5	623.2	619.5	608.5	603.0	595.6	588.2	588.2
52.5°	586.4	573.4	566.0	551.3	545.8	540.2	525.5	520.0	514.4	508.9
55°	520.0	508.9	494.2	477.6	470.2	460.9	446.2	435.1	427.8	429.6
57.5°	455.5	437.0	422.3	400.2	390.9	385.3	370.6	355.8	348.5	348.5
60°	376.2	361.4	343.0	322.7	315.3	306.1	287.6	278.4	272.9	267.4
62.5°	300.6	289.5	272.9	247.1	241.6	232.3	219.5	208.4	202.8	202.8
65°	224.9	213.9	199.1	180.7	173.3	166.0	154.9	143.8	138.3	136.5
67.5°	158.6	145.6	132.8	118.0	112.5	108.8	97.7	90.4	86.7	84.8
70°	95.8	88.5	79.3	68.2	62.7	59.0	51.6	46.1	44.2	42.4
72.5°	49.8	44.2	36.9	29.5	25.8	22.1	18.4	14.7	12.9	12.9
75°	18.4	14.7	9.3	5.6	3.7	3.7	3.7	3.7	3.7	3.7
77.5°	3.7	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
80°	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)