

LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P#

Luminaire Tested: **FLDSQ4C45D010 FEU4C459035 F4LC-DFSSQ-MW**

Issue Date: 12/13/2022

Tested By:

Approved By:



Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.



Test Information

Test Method: LM-79-08
 Report Number: P#
 Test Lab: INNOVATION CENTER
 Issue Date: 12/13/2022
 Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
 Product Line: FAIL-SAFE
 Catalog Number: FLDSQ4C45D010 FEU4C459035 F4LC-DFSSQ-MW
 Description: 4 INCH 4500 LUMEN FAIL-SAFE LED DOWNLIGHT WITH, 3500K, 90CRI LEDS AND F4LC-DFSSQ TRIM WITH MW FINISH
 Light Source: -
 Ballast/Driver: -

Summary


Lumens per Lamp: N/A
 Luminaire Lumens: 4636.0 lumens
 Efficiency: N/A
 Efficacy: 93.5 lumens/watt
 Spacing Criteria (0/90/45): 1.19 / 1.2 / 1.29
 Luminous Opening: Rectangular (W 0.33' x L: 0.33' x H: 0')
 CIE Type: Direct

Input Watts (W): 49.6
 Input Voltage (V):
 Input Current (Ain): NR
 Voltage Rise (V): NR
 Power Factor: NR
 Total Harmonic Distortion (THDi): NR
 Frequency (hertz): 60
 Stabilization Time: NR
 Operation Time: NR
 Ambient Temperature (°C): NR
 Test Distance: 25 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	GONIO 1 IN0055	4/22/2021	10/22/2021
Power Meter	XITRON 2801 IN0197	12/1/2020	12/1/2021
AC Power Source	CHROMA 61505 IN0196	12/1/2020	12/1/2021
DC Power Supply	AGILENT E3634A IN0198	11/30/2020	11/30/2021
Room Thermometer	ONSET IN0143	12/1/2020	12/1/2021

TEST NUMBER: P#
CATALOG NUMBER: FLDSQ4C45D010 FEU4C459035 F4LC-DFSSQ-MW

Luminous Intensity Polar Plot



TEST NUMBER: P#

CATALOG NUMBER: FLDSQ4C45D010 FEU4C459035 F4LC-DFSSQ-MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20	
RC	80					70					50					30					10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100				100
1	111	108	104	101	109	105	102	100	101	99	96	97	95	94	94	92	91	89				89
2	103	96	91	86	100	94	89	85	91	87	83	88	84	81	85	82	79	77				77
3	95	86	79	74	93	85	78	73	82	76	72	79	74	71	77	73	69	67				67
4	88	77	70	64	86	76	69	63	74	67	63	71	66	62	69	65	61	59				59
5	81	70	62	56	79	69	61	56	67	60	55	65	59	54	63	58	54	52				52
6	75	63	55	49	73	62	55	49	61	54	49	59	53	48	57	52	48	46				46
7	70	58	50	44	68	57	49	44	55	49	44	54	48	43	53	47	43	41				41
8	65	53	45	40	64	52	45	39	51	44	39	50	44	39	49	43	39	37				37
9	61	49	41	36	60	48	41	36	47	40	36	46	40	35	45	39	35	33				33
10	57	45	38	33	56	44	37	33	44	37	32	43	37	32	42	36	32	31				31

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	209410	209410	209410
5°	206026	208708	209299
10°	207810	207203	208104
15°	204171	204470	205080
20°	199417	202580	201635
25°	198555	198555	199864
30°	193017	194398	194744
35°	186994	188819	185545
40°	178230	181706	180157
45°	168673	172467	166995
50°	148549	161503	147618
55°	120313	147784	120835
60°	88036	122541	86261
65°	53494	87261	52101
70°	20876	46972	20002
75°	2311	12675	2311
80°	1723	1723	1723
85°	0	0	0

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C45D010 FEU4C459035 F4LC-DFSSQ-MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	204.9	4.4
10°-20°	579.7	12.5
20°-30°	860.1	18.6
30°-40°	996.6	21.5
40°-50°	955.5	20.6
50°-60°	702.6	15.2
60°-70°	303.4	6.5
70°-80°	32.8	0.7
80°-90°	0.4	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1644.6	35.5
0°-40°	2641.3	57.0
0°-60°	4299.4	92.7
0°-90°	4636.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4636.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2170	2170	2170	2170	2170	
5°	2127	2149	2155	2158	2161	203
15°	2044	2056	2047	2050	2053	576
25°	1865	1862	1865	1868	1877	854
35°	1588	1597	1603	1600	1575	993
45°	1236	1239	1264	1245	1224	940
55°	715	789	878	786	718	644
65°	234	293	382	290	228	241
75°	6	9	34	6	6	19
85°	0	0	0	0	0	0
90°	0	0	0	0	0	

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C45D010 FEU4C459035 F4LC-DFSSQ-MW

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	22.5°	25°	30°	35°	40°	45°
0°	2170.3	2170.3	2170.3	2170.3	2170.3	2170.3	2170.3	2170.3	2170.3	2170.3	2170.3
2.5°	2154.8	2179.4	2182.6	2167.1	2160.9	2151.8	2173.3	2157.9	2164.1	2157.9	2154.8
5°	2127.1	2154.8	2157.9	2157.9	2151.8	2148.6	2157.9	2154.8	2151.8	2145.6	2154.8
7.5°	2114.8	2130.1	2145.6	2127.1	2136.3	2133.3	2154.8	2145.6	2142.5	2142.5	2136.3
10°	2121.0	2117.8	2130.1	2111.6	2117.8	2111.6	2130.1	2130.1	2124.0	2117.8	2114.8
12.5°	2071.5	2096.2	2096.2	2093.2	2087.0	2077.7	2096.2	2108.6	2090.0	2090.0	2087.0
15°	2043.9	2050.0	2053.0	2053.0	2050.0	2056.2	2065.4	2053.0	2056.2	2040.7	2046.9
17.5°	2013.0	2000.7	2009.9	2003.7	2006.9	2013.0	2025.4	2025.4	2006.9	2003.7	2009.9
20°	1942.1	1979.1	1982.2	1963.7	1966.8	1966.8	1988.4	1969.9	1982.2	1966.8	1972.9
22.5°	1908.1	1932.8	1935.9	1911.3	1926.6	1908.1	1929.8	1902.0	1932.8	1911.3	1920.5
25°	1865.0	1862.0	1871.2	1858.8	1862.0	1862.0	1877.3	1865.0	1874.3	1862.0	1865.0
27.5°	1794.2	1818.8	1815.7	1803.4	1809.5	1806.5	1837.3	1803.4	1821.9	1806.5	1812.7
30°	1732.4	1754.1	1747.9	1735.6	1735.6	1726.3	1760.2	1750.9	1747.9	1747.9	1744.8
32.5°	1670.8	1673.9	1667.8	1670.8	1673.9	1661.6	1689.3	1677.0	1673.9	1677.0	1680.1
35°	1587.5	1587.5	1593.7	1584.5	1596.8	1596.8	1621.5	1606.0	1603.0	1593.7	1603.0
37.5°	1513.6	1504.4	1507.4	1507.4	1513.6	1519.7	1532.1	1525.9	1525.9	1516.7	1522.9
40°	1415.0	1408.8	1418.0	1418.0	1427.3	1427.3	1439.6	1433.5	1442.6	1442.6	1442.6
42.5°	1328.7	1328.7	1322.5	1331.7	1334.9	1331.7	1353.3	1350.2	1353.3	1347.2	1350.2
45°	1236.1	1236.1	1230.0	1226.9	1242.3	1239.3	1263.9	1254.6	1266.9	1260.8	1263.9
47.5°	1109.7	1125.2	1115.9	1125.2	1143.7	1146.8	1162.2	1156.0	1168.3	1159.1	1171.5
50°	989.6	989.6	998.8	1011.1	1029.6	1032.7	1051.2	1063.6	1069.7	1072.7	1075.9
52.5°	863.2	860.1	869.4	884.7	900.2	912.5	931.0	949.5	961.8	980.3	971.0
55°	715.2	721.3	730.6	749.1	773.8	789.1	804.6	829.2	850.9	860.1	878.5
57.5°	588.8	582.6	588.8	613.4	641.2	653.5	675.2	699.8	730.6	749.1	755.3
60°	456.2	459.3	465.5	487.1	508.6	527.1	536.4	576.4	604.2	622.7	635.0
62.5°	336.1	342.2	348.4	366.9	388.4	403.9	419.2	453.2	477.8	496.3	508.6
65°	234.3	237.3	246.6	255.8	277.5	292.8	305.1	332.9	357.6	373.0	382.2
67.5°	144.9	147.9	154.1	166.5	181.9	194.2	206.5	225.0	246.6	262.0	265.1
70°	74.0	77.1	80.1	89.4	101.8	107.9	117.1	132.6	147.9	160.2	166.5
72.5°	24.7	24.7	27.8	34.0	40.1	46.3	49.3	64.8	77.1	83.3	86.3
75°	6.2	6.2	6.2	6.2	6.2	9.3	9.3	18.5	24.7	30.8	34.0
77.5°	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	6.2	6.2
80°	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C45D010 FEU4C459035 F4LC-DFSSQ-MW

CANDELA DISTRIBUTION (continued):

	50°	55°	60°	65°	67.5°	70°	75°	80°	85°	90°
0°	2170.3	2170.3	2170.3	2170.3	2170.3	2170.3	2170.3	2170.3	2170.3	2170.3
2.5°	2170.3	2164.1	2160.9	2164.1	2164.1	2160.9	2170.3	2182.6	2197.9	2157.9
5°	2167.1	2160.9	2167.1	2148.6	2157.9	2151.8	2164.1	2160.9	2173.3	2160.9
7.5°	2157.9	2145.6	2148.6	2139.4	2151.8	2136.3	2145.6	2164.1	2151.8	2133.3
10°	2127.1	2121.0	2142.5	2111.6	2105.5	2117.8	2142.5	2124.0	2117.8	2124.0
12.5°	2096.2	2096.2	2105.5	2080.8	2083.9	2090.0	2102.3	2090.0	2096.2	2111.6
15°	2062.3	2056.2	2071.5	2053.0	2050.0	2043.9	2056.2	2056.2	2062.3	2053.0
17.5°	2022.2	2013.0	2013.0	2006.9	2003.7	2019.2	2025.4	2028.4	2031.5	2019.2
20°	1972.9	1969.9	1979.1	1969.9	1972.9	1976.1	1976.1	1969.9	1997.6	1963.7
22.5°	1920.5	1929.8	1917.4	1911.3	1917.4	1923.6	1923.6	1926.6	1920.5	1914.3
25°	1868.1	1874.3	1877.3	1858.8	1868.1	1858.8	1880.5	1883.5	1871.2	1877.3
27.5°	1821.9	1812.7	1809.5	1797.2	1803.4	1800.3	1803.4	1803.4	1821.9	1797.2
30°	1750.9	1741.7	1744.8	1735.6	1738.6	1735.6	1738.6	1738.6	1750.9	1747.9
32.5°	1683.1	1673.9	1677.0	1667.8	1667.8	1670.8	1664.6	1664.6	1673.9	1667.8
35°	1618.4	1596.8	1599.9	1596.8	1599.9	1587.5	1587.5	1584.5	1590.7	1575.2
37.5°	1525.9	1516.7	1513.6	1510.6	1513.6	1507.4	1513.6	1504.4	1513.6	1501.3
40°	1442.6	1436.5	1439.6	1421.1	1421.1	1424.2	1418.0	1415.0	1418.0	1430.3
42.5°	1359.5	1347.2	1341.0	1334.9	1337.9	1328.7	1325.5	1319.4	1325.5	1313.2
45°	1260.8	1260.8	1257.8	1242.3	1245.4	1245.4	1233.1	1220.8	1223.8	1223.8
47.5°	1171.5	1165.3	1162.2	1146.8	1143.7	1140.7	1128.2	1119.0	1119.0	1109.7
50°	1072.7	1066.6	1057.4	1041.9	1035.8	1017.3	1008.1	995.8	983.4	983.4
52.5°	980.3	958.7	946.3	921.7	912.5	903.2	878.5	869.4	860.1	850.9
55°	869.4	850.9	826.2	798.4	786.1	770.6	746.0	727.5	715.2	718.3
57.5°	761.4	730.6	706.0	669.0	653.5	644.2	619.6	594.9	582.6	582.6
60°	628.9	604.2	573.4	539.5	527.1	511.8	480.8	465.5	456.2	447.0
62.5°	502.5	484.0	456.2	413.0	403.9	388.4	366.9	348.4	339.1	339.1
65°	376.1	357.6	332.9	302.1	289.8	277.5	259.0	240.5	231.2	228.2
67.5°	265.1	243.5	222.0	197.3	188.0	181.9	163.4	151.1	144.9	141.8
70°	160.2	147.9	132.6	114.1	104.8	98.6	86.3	77.1	74.0	70.9
72.5°	83.3	74.0	61.6	49.3	43.1	37.0	30.8	24.7	21.6	21.6
75°	30.8	24.7	15.5	9.3	6.2	6.2	6.2	6.2	6.2	6.2
77.5°	6.2	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1
80°	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)