

LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P#

Luminaire Tested: **FLDSQ4C50D010 FEU4C509035 F4LC-DFSSQ-MW**

Issue Date: 12/13/2022

Tested By:

Approved By:



Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-08
 Report Number: P#
 Test Lab: INNOVATION CENTER
 Issue Date: 12/13/2022
 Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
 Product Line: FAIL-SAFE
 Catalog Number: FLDSQ4C50D010 FEU4C509035 F4LC-DFSSQ-MW
 Description: 4 INCH 5000 LUMEN FAIL-SAFE LED DOWNLIGHT WITH, 3500K, 90CRI LEDS AND F4LC-DFSSQ TRIM WITH MW FINISH
 Light Source: -
 Ballast/Driver: -

Summary


Lumens per Lamp: N/A
 Luminaire Lumens: 5251.0 lumens
 Efficiency: N/A
 Efficacy: 89.9 lumens/watt
 Spacing Criteria (0/90/45): 1.19 / 1.2 / 1.29
 Luminous Opening: Rectangular (W 0.33' x L: 0.33' x H: 0')
 CIE Type: Direct

Input Watts (W): 58.4
 Input Voltage (V):
 Input Current (Ain): NR
 Voltage Rise (V): NR
 Power Factor: NR
 Total Harmonic Distortion (THDi): NR
 Frequency (hertz): 60
 Stabilization Time: NR
 Operation Time: NR
 Ambient Temperature (°C): NR
 Test Distance: 25 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	GONIO 1 IN0055	4/22/2021	10/22/2021
Power Meter	XITRON 2801 IN0197	12/1/2020	12/1/2021
AC Power Source	CHROMA 61505 IN0196	12/1/2020	12/1/2021
DC Power Supply	AGILENT E3634A IN0198	11/30/2020	11/30/2021
Room Thermometer	ONSET IN0143	12/1/2020	12/1/2021

TEST NUMBER: P#
CATALOG NUMBER: FLDSQ4C50D010 FEU4C509035 F4LC-DFSSQ-MW

Luminous Intensity Polar Plot



TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C50D010 FEU4C509035 F4LC-DFSSQ-MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20	
RC	80					70					50					30					10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100				100
1	111	108	104	101	109	105	102	100	101	99	96	97	95	94	94	92	91	89				89
2	103	96	91	86	100	94	89	85	91	87	83	88	84	81	85	82	79	77				77
3	95	86	79	74	93	85	78	73	82	76	72	79	74	71	77	73	69	67				67
4	88	77	70	64	86	76	69	63	74	67	63	71	66	62	69	65	61	59				59
5	81	70	62	56	79	69	61	56	67	60	55	65	59	54	63	58	54	52				52
6	75	63	55	49	73	62	55	49	61	54	49	59	53	48	57	52	48	46				46
7	70	58	50	44	68	57	49	44	55	49	44	54	48	43	53	47	43	41				41
8	65	53	45	40	64	52	45	39	51	44	39	50	44	39	49	43	39	37				37
9	61	49	41	36	60	48	41	36	47	40	36	46	40	35	45	39	35	33				33
10	57	45	38	33	56	44	37	33	44	37	32	43	37	32	42	36	32	31				31

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	237189	237189	237189
5°	233359	236390	237068
10°	235371	234685	235704
15°	231251	231591	232290
20°	225868	229452	228384
25°	224894	224894	226384
30°	218631	220180	220581
35°	211800	213873	210163
40°	201872	205814	204063
45°	191052	195350	189142
50°	168258	182924	167208
55°	136261	167399	136866
60°	99712	138809	97705
65°	60594	98836	58996
70°	23641	53207	22654
75°	2610	14353	2610
80°	2000	2000	2000
85°	0	0	0



TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C50D010 FEU4C509035 F4LC-DFSSQ-MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	232.0	4.4
10°-20°	656.6	12.5
20°-30°	974.2	18.6
30°-40°	1128.8	21.5
40°-50°	1082.3	20.6
50°-60°	795.8	15.2
60°-70°	343.7	6.5
70°-80°	37.1	0.7
80°-90°	0.5	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1862.8	35.5
0°-40°	2991.6	57.0
0°-60°	4869.7	92.7
0°-90°	5251.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5251.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2458	2458	2458	2458	2458	
5°	2409	2434	2441	2444	2448	230
15°	2315	2329	2318	2322	2325	652
25°	2112	2109	2112	2116	2126	967
35°	1798	1809	1816	1812	1784	1124
45°	1400	1404	1432	1411	1386	1064
55°	810	894	995	890	814	729
65°	265	332	433	328	258	273
75°	7	10	38	7	7	21
85°	0	0	0	0	0	0
90°	0	0	0	0	0	

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C50D010 FEU4C509035 F4LC-DFSSQ-MW

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	22.5°	25°	30°	35°	40°	45°
0°	2458.2	2458.2	2458.2	2458.2	2458.2	2458.2	2458.2	2458.2	2458.2	2458.2	2458.2
2.5°	2440.6	2468.6	2472.1	2454.6	2447.6	2437.2	2461.6	2444.2	2451.2	2444.2	2440.6
5°	2409.3	2440.6	2444.2	2444.2	2437.2	2433.7	2444.2	2440.6	2437.2	2430.2	2440.6
7.5°	2395.3	2412.7	2430.2	2409.3	2419.7	2416.3	2440.6	2430.2	2426.7	2426.7	2419.7
10°	2402.3	2398.8	2412.7	2391.8	2398.8	2391.8	2412.7	2412.7	2405.7	2398.8	2395.3
12.5°	2346.3	2374.3	2374.3	2370.8	2363.8	2353.3	2374.3	2388.3	2367.3	2367.3	2363.8
15°	2315.0	2322.0	2325.4	2325.4	2322.0	2328.9	2339.3	2325.4	2328.9	2311.4	2318.4
17.5°	2280.1	2266.1	2276.5	2269.5	2273.1	2280.1	2294.0	2294.0	2273.1	2269.5	2276.5
20°	2199.7	2241.6	2245.2	2224.2	2227.7	2227.7	2252.2	2231.2	2245.2	2227.7	2234.6
22.5°	2161.3	2189.2	2192.8	2164.8	2182.2	2161.3	2185.8	2154.3	2189.2	2164.8	2175.2
25°	2112.4	2109.0	2119.4	2105.4	2109.0	2109.0	2126.4	2112.4	2122.9	2109.0	2112.4
27.5°	2032.2	2060.1	2056.6	2042.6	2049.6	2046.2	2081.1	2042.6	2063.5	2046.2	2053.1
30°	1962.3	1986.8	1979.8	1965.8	1965.8	1955.3	1993.7	1983.2	1979.8	1979.8	1976.2
32.5°	1892.4	1896.0	1889.0	1892.4	1896.0	1882.0	1913.4	1899.4	1896.0	1899.4	1903.0
35°	1798.1	1798.1	1805.1	1794.7	1808.7	1808.7	1836.6	1819.1	1815.7	1805.1	1815.7
37.5°	1714.4	1704.0	1707.4	1707.4	1714.4	1721.4	1735.3	1728.3	1728.3	1717.9	1724.9
40°	1602.7	1595.7	1606.1	1606.1	1616.6	1616.6	1630.6	1623.6	1634.0	1634.0	1634.0
42.5°	1505.0	1505.0	1498.0	1508.4	1511.9	1508.4	1532.9	1529.3	1532.9	1525.9	1529.3
45°	1400.1	1400.1	1393.1	1389.7	1407.1	1403.7	1431.6	1421.0	1435.0	1428.0	1431.6
47.5°	1256.9	1274.5	1263.9	1274.5	1295.4	1299.0	1316.3	1309.4	1323.3	1312.9	1326.9
50°	1120.9	1120.9	1131.3	1145.2	1166.2	1169.7	1190.7	1204.6	1211.6	1215.0	1218.6
52.5°	977.7	974.1	984.7	1002.1	1019.6	1033.6	1054.5	1075.4	1089.4	1110.3	1099.8
55°	810.0	817.0	827.6	848.5	876.4	893.8	911.3	939.2	963.7	974.1	995.1
57.5°	666.9	659.9	666.9	694.8	726.3	740.2	764.7	792.6	827.6	848.5	855.5
60°	516.7	520.3	527.2	551.7	576.1	597.1	607.6	652.9	684.4	705.3	719.3
62.5°	380.7	387.6	394.6	415.6	439.9	457.4	474.8	513.3	541.2	562.1	576.1
65°	265.4	268.8	279.4	289.8	314.3	331.7	345.6	377.1	405.0	422.5	432.9
67.5°	164.1	167.5	174.5	188.6	206.0	220.0	233.9	254.9	279.4	296.7	300.3
70°	83.8	87.3	90.7	101.3	115.2	122.2	132.6	150.2	167.5	181.5	188.6
72.5°	27.9	27.9	31.5	38.5	45.4	52.4	55.8	73.4	87.3	94.3	97.7
75°	7.0	7.0	7.0	7.0	7.0	10.5	10.5	20.9	27.9	34.9	38.5
77.5°	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	7.0	7.0
80°	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0



TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C50D010 FEU4C509035 F4LC-DFSSQ-MW

CANDELA DISTRIBUTION (continued):

	50°	55°	60°	65°	67.5°	70°	75°	80°	85°	90°
0°	2458.2	2458.2	2458.2	2458.2	2458.2	2458.2	2458.2	2458.2	2458.2	2458.2
2.5°	2458.2	2451.2	2447.6	2451.2	2451.2	2447.6	2458.2	2472.1	2489.5	2444.2
5°	2454.6	2447.6	2454.6	2433.7	2444.2	2437.2	2451.2	2447.6	2461.6	2447.6
7.5°	2444.2	2430.2	2433.7	2423.3	2437.2	2419.7	2430.2	2451.2	2437.2	2416.3
10°	2409.3	2402.3	2426.7	2391.8	2384.8	2398.8	2426.7	2405.7	2398.8	2405.7
12.5°	2374.3	2374.3	2384.8	2356.9	2360.3	2367.3	2381.2	2367.3	2374.3	2391.8
15°	2335.9	2328.9	2346.3	2325.4	2322.0	2315.0	2328.9	2328.9	2335.9	2325.4
17.5°	2290.5	2280.1	2280.1	2273.1	2269.5	2287.1	2294.0	2297.5	2301.0	2287.1
20°	2234.6	2231.2	2241.6	2231.2	2234.6	2238.2	2238.2	2231.2	2262.6	2224.2
22.5°	2175.2	2185.8	2171.8	2164.8	2171.8	2178.8	2178.8	2182.2	2175.2	2168.3
25°	2116.0	2122.9	2126.4	2105.4	2116.0	2105.4	2129.9	2133.3	2119.4	2126.4
27.5°	2063.5	2053.1	2049.6	2035.6	2042.6	2039.2	2042.6	2042.6	2063.5	2035.6
30°	1983.2	1972.8	1976.2	1965.8	1969.2	1965.8	1969.2	1969.2	1983.2	1979.8
32.5°	1906.4	1896.0	1899.4	1889.0	1889.0	1892.4	1885.5	1885.5	1896.0	1889.0
35°	1833.0	1808.7	1812.1	1808.7	1812.1	1798.1	1798.1	1794.7	1801.7	1784.2
37.5°	1728.3	1717.9	1714.4	1710.9	1714.4	1707.4	1714.4	1704.0	1714.4	1700.4
40°	1634.0	1627.0	1630.6	1609.7	1609.7	1613.1	1606.1	1602.7	1606.1	1620.1
42.5°	1539.9	1525.9	1518.9	1511.9	1515.4	1505.0	1501.4	1494.4	1501.4	1487.4
45°	1428.0	1428.0	1424.6	1407.1	1410.6	1410.6	1396.7	1382.7	1386.1	1386.1
47.5°	1326.9	1319.9	1316.3	1299.0	1295.4	1292.0	1277.9	1267.5	1267.5	1256.9
50°	1215.0	1208.1	1197.7	1180.1	1173.2	1152.2	1141.8	1127.9	1113.9	1113.9
52.5°	1110.3	1085.8	1071.9	1044.0	1033.6	1023.0	995.1	984.7	974.1	963.7
55°	984.7	963.7	935.8	904.3	890.4	872.9	844.9	824.0	810.0	813.6
57.5°	862.5	827.6	799.6	757.7	740.2	729.7	701.8	673.8	659.9	659.9
60°	712.3	684.4	649.5	611.0	597.1	579.7	544.6	527.2	516.7	506.3
62.5°	569.1	548.2	516.7	467.8	457.4	439.9	415.6	394.6	384.1	384.1
65°	426.0	405.0	377.1	342.2	328.2	314.3	293.3	272.4	261.8	258.4
67.5°	300.3	275.8	251.4	223.5	213.0	206.0	185.1	171.1	164.1	160.6
70°	181.5	167.5	150.2	129.2	118.7	111.7	97.7	87.3	83.8	80.3
72.5°	94.3	83.8	69.8	55.8	48.9	41.9	34.9	27.9	24.5	24.5
75°	34.9	27.9	17.5	10.5	7.0	7.0	7.0	7.0	7.0	7.0
77.5°	7.0	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
80°	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)