

LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P#

Luminaire Tested: **FLDSQ4C50D010 FEU4C509050 F4LC-DFSSQ-MW**

Issue Date: 12/13/2022

Tested By:

Approved By:



Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.



Test Information

Test Method: LM-79-08
 Report Number: P#
 Test Lab: INNOVATION CENTER
 Issue Date: 12/13/2022
 Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
 Product Line: FAIL-SAFE
 Catalog Number: FLDSQ4C50D010 FEU4C509050 F4LC-DFSSQ-MW
 Description: 4 INCH 5000 LUMEN FAIL-SAFE LED DOWNLIGHT WITH, 5000K, 90CRI LEDS AND F4LC-DFSSQ TRIM WITH MW FINISH
 Light Source: -
 Ballast/Driver: -

Summary


Lumens per Lamp: N/A
 Luminaire Lumens: 5367.0 lumens
 Efficiency: N/A
 Efficacy: 91.9 lumens/watt
 Spacing Criteria (0/90/45): 1.19 / 1.2 / 1.29
 Luminous Opening: Rectangular (W 0.33' x L: 0.33' x H: 0')
 CIE Type: Direct

Input Watts (W): 58.4
 Input Voltage (V):
 Input Current (Ain): NR
 Voltage Rise (V): NR
 Power Factor: NR
 Total Harmonic Distortion (THDi): NR
 Frequency (hertz): 60
 Stabilization Time: NR
 Operation Time: NR
 Ambient Temperature (°C): NR
 Test Distance: 25 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	GONIO 1 IN0055	4/22/2021	10/22/2021
Power Meter	XITRON 2801 IN0197	12/1/2020	12/1/2021
AC Power Source	CHROMA 61505 IN0196	12/1/2020	12/1/2021
DC Power Supply	AGILENT E3634A IN0198	11/30/2020	11/30/2021
Room Thermometer	ONSET IN0143	12/1/2020	12/1/2021

TEST NUMBER: P#
CATALOG NUMBER: FLDSQ4C50D010 FEU4C509050 F4LC-DFSSQ-MW

Luminous Intensity Polar Plot



TEST NUMBER: P#

CATALOG NUMBER: FLDSQ4C50D010 FEU4C509050 F4LC-DFSSQ-MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20	
RC	80					70					50					30					10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100				100
1	111	108	104	101	109	105	102	100	101	99	96	97	95	94	94	92	91	89				89
2	103	96	91	86	100	94	89	85	91	87	83	88	84	81	85	82	79	77				77
3	95	86	79	74	93	85	78	73	82	76	72	79	74	71	77	73	69	67				67
4	88	77	70	64	86	76	69	63	74	67	63	71	66	62	69	65	61	59				59
5	81	70	62	56	79	69	61	56	67	60	55	65	59	54	63	58	54	52				52
6	75	63	55	49	73	62	55	49	61	54	49	59	53	48	57	52	48	46				46
7	70	58	50	44	68	57	49	44	55	49	44	54	48	43	53	47	43	41				41
8	65	53	45	40	64	52	45	39	51	44	39	50	44	39	49	43	39	37				37
9	61	49	41	36	60	48	41	36	47	40	36	46	40	35	45	39	35	33				33
10	57	45	38	33	56	44	37	33	44	37	32	43	37	32	42	36	32	31				31

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	242428	242428	242428
5°	238512	241621	242308
10°	240574	239868	240917
15°	236356	236706	237425
20°	230858	234524	233436
25°	229866	229866	231378
30°	223455	225049	225450
35°	216488	218597	214804
40°	206331	210361	208573
45°	195268	199662	193331
50°	171966	186962	170900
55°	139272	171100	139894
60°	101912	141877	99866
65°	61941	101028	60297
70°	24149	54392	23162
75°	2647	14651	2647
80°	2000	2000	2000
85°	0	0	0

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C50D010 FEU4C509050 F4LC-DFSSQ-MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	237.2	4.4
10°-20°	671.1	12.5
20°-30°	995.7	18.6
30°-40°	1153.8	21.5
40°-50°	1106.2	20.6
50°-60°	813.3	15.2
60°-70°	351.3	6.5
70°-80°	37.9	0.7
80°-90°	0.5	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1904.0	35.5
0°-40°	3057.7	57.0
0°-60°	4977.3	92.7
0°-90°	5367.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5367.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2512	2512	2512	2512	2512	
5°	2462	2487	2495	2498	2502	235
15°	2366	2380	2370	2373	2377	667
25°	2159	2156	2159	2163	2173	989
35°	1838	1849	1856	1852	1824	1149
45°	1431	1435	1463	1442	1417	1088
55°	828	914	1017	910	832	745
65°	271	339	442	336	264	279
75°	7	11	39	7	7	22
85°	0	0	0	0	0	0
90°	0	0	0	0	0	

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C50D010 FEU4C509050 F4LC-DFSSQ-MW

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	22.5°	25°	30°	35°	40°	45°
0°	2512.5	2512.5	2512.5	2512.5	2512.5	2512.5	2512.5	2512.5	2512.5	2512.5	2512.5
2.5°	2494.6	2523.1	2526.7	2508.8	2501.7	2491.1	2516.0	2498.2	2505.3	2498.2	2494.6
5°	2462.5	2494.6	2498.2	2498.2	2491.1	2487.4	2498.2	2494.6	2491.1	2483.9	2494.6
7.5°	2448.2	2466.0	2483.9	2462.5	2473.1	2469.6	2494.6	2483.9	2480.3	2480.3	2473.1
10°	2455.4	2451.7	2466.0	2444.6	2451.7	2444.6	2466.0	2466.0	2458.9	2451.7	2448.2
12.5°	2398.2	2426.7	2426.7	2423.2	2416.1	2405.3	2426.7	2441.1	2419.6	2419.6	2416.1
15°	2366.1	2373.3	2376.8	2376.8	2373.3	2380.4	2391.0	2376.8	2380.4	2362.5	2369.6
17.5°	2330.4	2316.2	2326.8	2319.7	2323.3	2330.4	2344.7	2344.7	2323.3	2319.7	2326.8
20°	2248.3	2291.1	2294.8	2273.4	2276.9	2276.9	2301.9	2280.5	2294.8	2276.9	2284.0
22.5°	2209.0	2237.6	2241.2	2212.7	2230.4	2209.0	2234.1	2201.9	2237.6	2212.7	2223.3
25°	2159.1	2155.6	2166.2	2151.9	2155.6	2155.6	2173.3	2159.1	2169.8	2155.6	2159.1
27.5°	2077.1	2105.6	2102.0	2087.7	2094.9	2091.4	2127.0	2087.7	2109.1	2091.4	2098.5
30°	2005.6	2030.6	2023.5	2009.2	2009.2	1998.5	2037.8	2027.0	2023.5	2023.5	2019.9
32.5°	1934.3	1937.9	1930.8	1934.3	1937.9	1923.6	1955.7	1941.4	1937.9	1941.4	1945.0
35°	1837.9	1837.9	1845.0	1834.4	1848.6	1848.6	1877.2	1859.3	1855.8	1845.0	1855.8
37.5°	1752.2	1741.6	1745.1	1745.1	1752.2	1759.4	1773.6	1766.5	1766.5	1755.9	1763.0
40°	1638.1	1631.0	1641.6	1641.6	1652.4	1652.4	1666.6	1659.5	1670.1	1670.1	1670.1
42.5°	1538.2	1538.2	1531.1	1541.7	1545.3	1541.7	1566.7	1563.1	1566.7	1559.6	1563.1
45°	1431.0	1431.0	1423.9	1420.4	1438.2	1434.7	1463.2	1452.4	1466.7	1459.6	1463.2
47.5°	1284.7	1302.6	1291.8	1302.6	1324.0	1327.6	1345.4	1338.3	1352.6	1341.9	1356.2
50°	1145.6	1145.6	1156.3	1170.5	1191.9	1195.6	1217.0	1231.3	1238.4	1241.9	1245.5
52.5°	999.3	995.7	1006.4	1024.2	1042.1	1056.4	1077.8	1099.2	1113.5	1134.9	1124.1
55°	827.9	835.1	845.8	867.2	895.8	913.5	931.5	960.0	985.0	995.7	1017.1
57.5°	681.6	674.5	681.6	710.1	742.3	756.6	781.6	810.2	845.8	867.2	874.4
60°	528.1	531.8	538.9	563.9	588.8	610.2	621.0	667.3	699.5	720.9	735.2
62.5°	389.1	396.2	403.3	424.7	449.6	467.5	485.3	524.6	553.2	574.6	588.8
65°	271.3	274.8	285.5	296.2	321.2	339.0	353.2	385.4	414.0	431.9	442.5
67.5°	167.7	171.2	178.4	192.8	210.5	224.8	239.1	260.5	285.5	303.3	306.9
70°	85.6	89.3	92.8	103.5	117.8	124.9	135.6	153.5	171.2	185.5	192.8
72.5°	28.5	28.5	32.2	39.3	46.4	53.6	57.1	75.0	89.3	96.4	99.9
75°	7.1	7.1	7.1	7.1	7.1	10.8	10.8	21.4	28.5	35.7	39.3
77.5°	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	7.1	7.1
80°	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C50D010 FEU4C509050 F4LC-DFSSQ-MW

CANDELA DISTRIBUTION (continued):

	50°	55°	60°	65°	67.5°	70°	75°	80°	85°	90°
0°	2512.5	2512.5	2512.5	2512.5	2512.5	2512.5	2512.5	2512.5	2512.5	2512.5
2.5°	2512.5	2505.3	2501.7	2505.3	2505.3	2501.7	2512.5	2526.7	2544.5	2498.2
5°	2508.8	2501.7	2508.8	2487.4	2498.2	2491.1	2505.3	2501.7	2516.0	2501.7
7.5°	2498.2	2483.9	2487.4	2476.8	2491.1	2473.1	2483.9	2505.3	2491.1	2469.6
10°	2462.5	2455.4	2480.3	2444.6	2437.5	2451.7	2480.3	2458.9	2451.7	2458.9
12.5°	2426.7	2426.7	2437.5	2408.9	2412.4	2419.6	2433.8	2419.6	2426.7	2444.6
15°	2387.5	2380.4	2398.2	2376.8	2373.3	2366.1	2380.4	2380.4	2387.5	2376.8
17.5°	2341.1	2330.4	2330.4	2323.3	2319.7	2337.6	2344.7	2348.2	2351.9	2337.6
20°	2284.0	2280.5	2291.1	2280.5	2284.0	2287.6	2287.6	2280.5	2312.5	2273.4
22.5°	2223.3	2234.1	2219.8	2212.7	2219.8	2226.9	2226.9	2230.4	2223.3	2216.2
25°	2162.7	2169.8	2173.3	2151.9	2162.7	2151.9	2177.0	2180.5	2166.2	2173.3
27.5°	2109.1	2098.5	2094.9	2080.6	2087.7	2084.2	2087.7	2087.7	2109.1	2080.6
30°	2027.0	2016.4	2019.9	2009.2	2012.7	2009.2	2012.7	2012.7	2027.0	2023.5
32.5°	1948.5	1937.9	1941.4	1930.8	1930.8	1934.3	1927.1	1927.1	1937.9	1930.8
35°	1873.5	1848.6	1852.1	1848.6	1852.1	1837.9	1837.9	1834.4	1841.5	1823.6
37.5°	1766.5	1755.9	1752.2	1748.7	1752.2	1745.1	1752.2	1741.6	1752.2	1738.0
40°	1670.1	1663.0	1666.6	1645.2	1645.2	1648.7	1641.6	1638.1	1641.6	1655.9
42.5°	1573.9	1559.6	1552.5	1545.3	1548.8	1538.2	1534.6	1527.4	1534.6	1520.3
45°	1459.6	1459.6	1456.1	1438.2	1441.8	1441.8	1427.5	1413.3	1416.8	1416.8
47.5°	1356.2	1349.1	1345.4	1327.6	1324.0	1320.5	1306.1	1295.5	1295.5	1284.7
50°	1241.9	1234.8	1224.1	1206.2	1199.1	1177.7	1167.0	1152.8	1138.5	1138.5
52.5°	1134.9	1109.8	1095.6	1067.0	1056.4	1045.6	1017.1	1006.4	995.7	985.0
55°	1006.4	985.0	956.5	924.3	910.0	892.1	863.6	842.2	827.9	831.6
57.5°	881.5	845.8	817.3	774.5	756.6	745.8	717.3	688.7	674.5	674.5
60°	728.0	699.5	663.8	624.5	610.2	592.5	556.7	538.9	528.1	517.5
62.5°	581.7	560.3	528.1	478.2	467.5	449.6	424.7	403.3	392.6	392.6
65°	435.4	414.0	385.4	349.7	335.5	321.2	299.8	278.4	267.6	264.1
67.5°	306.9	281.9	257.0	228.5	217.7	210.5	189.1	174.9	167.7	164.1
70°	185.5	171.2	153.5	132.1	121.3	114.2	99.9	89.3	85.6	82.1
72.5°	96.4	85.6	71.3	57.1	49.9	42.8	35.7	28.5	25.0	25.0
75°	35.7	28.5	17.9	10.8	7.1	7.1	7.1	7.1	7.1	7.1
77.5°	7.1	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
80°	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)