

LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P#

Luminaire Tested: **FLDSQ4C55D010 FEU4C559050 F4LC-CSSQ-MW**

Issue Date: 12/13/2022

Tested By:

Approved By:



Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-08
 Report Number: P#
 Test Lab: INNOVATION CENTER
 Issue Date: 12/13/2022
 Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
 Product Line: FAIL-SAFE
 Catalog Number: FLDSQ4C55D010 FEU4C559050 F4LC-CSSQ-MW
 Description: 4 INCH 5500 LUMEN FAIL-SAFE LED DOWNLIGHT WITH, 5000K, 90CRI LEDS AND F4LC-CSSQ TRIM WITH MW FINISH
 Light Source: -
 Ballast/Driver: -

Summary


Lumens per Lamp: N/A
 Luminaire Lumens: 5999.0 lumens
 Efficiency: N/A
 Efficacy: 93.9 lumens/watt
 Spacing Criteria (0/90/45): 1.19 / 1.2 / 1.29
 Luminous Opening: Rectangular (W 0.33' x L: 0.33' x H: 0')
 CIE Type: Direct

Input Watts (W): 63.9
 Input Voltage (V):
 Input Current (Ain): NR
 Voltage Rise (V): NR
 Power Factor: NR
 Total Harmonic Distortion (THDi): NR
 Frequency (hertz): 60
 Stabilization Time: NR
 Operation Time: NR
 Ambient Temperature (°C): NR
 Test Distance: 25 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	GONIO 1 IN0055	4/22/2021	10/22/2021
Power Meter	XITRON 2801 IN0197	12/1/2020	12/1/2021
AC Power Source	CHROMA 61505 IN0196	12/1/2020	12/1/2021
DC Power Supply	AGILENT E3634A IN0198	11/30/2020	11/30/2021
Room Thermometer	ONSET IN0143	12/1/2020	12/1/2021

TEST NUMBER: P#
CATALOG NUMBER: FLDSQ4C55D010 FEU4C559050 F4LC-CSSQ-MW

Luminous Intensity Polar Plot



TEST NUMBER: P#

CATALOG NUMBER: FLDSQ4C55D010 FEU4C559050 F4LC-CSSQ-MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	111	108	104	101	109	105	102	100	101	99	96		97	95	94		94	92	91	89
2	103	96	91	86	100	94	89	85	91	87	83		88	84	81		85	82	79	77
3	95	86	79	74	93	85	78	73	82	76	72		79	74	71		77	73	69	67
4	88	77	70	64	86	76	69	63	74	67	63		71	66	62		69	65	61	59
5	81	70	62	56	79	69	61	56	67	60	55		65	59	54		63	58	54	52
6	75	63	55	49	73	62	55	49	61	54	49		59	53	48		57	52	48	46
7	70	58	50	44	68	57	49	44	55	49	44		54	48	43		53	47	43	41
8	65	53	45	40	64	52	45	39	51	44	39		50	44	39		49	43	39	37
9	61	49	41	36	60	48	41	36	47	40	36		46	40	35		45	39	35	33
10	57	45	38	33	56	44	37	33	44	37	32		43	37	32		42	36	32	31

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	270970	270970	270970
5°	266600	270068	270843
10°	268899	268115	269281
15°	264196	264586	265375
20°	258048	262145	260924
25°	256929	256929	258632
30°	249772	251543	252000
35°	241978	244334	240094
40°	230628	235137	233122
45°	218261	223174	216092
50°	192216	208983	191030
55°	155674	191236	156364
60°	113915	158570	111618
65°	69224	112923	67398
70°	26998	60796	25898
75°	2982	16366	2982
80°	2278	2278	2278
85°	0	0	0

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C55D010 FEU4C559050 F4LC-CSSQ-MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	265.1	4.4
10°-20°	750.1	12.5
20°-30°	1113.0	18.6
30°-40°	1289.6	21.5
40°-50°	1236.5	20.6
50°-60°	909.1	15.2
60°-70°	392.7	6.5
70°-80°	42.4	0.7
80°-90°	0.6	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2128.2	35.5
0°-40°	3417.8	57.0
0°-60°	5563.4	92.7
0°-90°	5999.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5999.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2808	2808	2808	2808	2808	
5°	2752	2780	2788	2792	2796	263
15°	2645	2661	2649	2653	2657	745
25°	2413	2409	2413	2417	2429	1105
35°	2054	2066	2074	2070	2038	1285
45°	1600	1604	1636	1612	1584	1216
55°	925	1021	1137	1017	930	833
65°	303	379	495	375	295	312
75°	8	12	44	8	8	25
85°	0	0	0	0	0	1
90°	0	0	0	0	0	

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C55D010 FEU4C559050 F4LC-CSSQ-MW

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	22.5°	25°	30°	35°	40°	45°
0°	2808.3	2808.3	2808.3	2808.3	2808.3	2808.3	2808.3	2808.3	2808.3	2808.3	2808.3
2.5°	2788.3	2820.2	2824.3	2804.3	2796.3	2784.4	2812.2	2792.4	2800.3	2792.4	2788.3
5°	2752.5	2788.3	2792.4	2792.4	2784.4	2780.3	2792.4	2788.3	2784.4	2776.4	2788.3
7.5°	2736.5	2756.4	2776.4	2752.5	2764.4	2760.5	2788.3	2776.4	2772.4	2772.4	2764.4
10°	2744.5	2740.5	2756.4	2732.5	2740.5	2732.5	2756.4	2756.4	2748.4	2740.5	2736.5
12.5°	2680.6	2712.5	2712.5	2708.6	2700.6	2688.5	2712.5	2728.6	2704.5	2704.5	2700.6
15°	2644.8	2652.7	2656.6	2656.6	2652.7	2660.7	2672.6	2656.6	2660.7	2640.7	2648.7
17.5°	2604.9	2588.9	2600.8	2592.8	2596.9	2604.9	2620.8	2620.8	2596.9	2592.8	2600.8
20°	2513.1	2560.9	2565.0	2541.1	2545.0	2545.0	2573.0	2549.0	2565.0	2545.0	2553.0
22.5°	2469.1	2501.0	2505.1	2473.2	2493.1	2469.1	2497.1	2461.2	2501.0	2473.2	2485.1
25°	2413.3	2409.4	2421.3	2405.3	2409.4	2409.4	2429.3	2413.3	2425.4	2409.4	2413.3
27.5°	2321.7	2353.6	2349.5	2333.6	2341.5	2337.6	2377.5	2333.6	2357.5	2337.6	2345.6
30°	2241.8	2269.8	2261.8	2245.8	2245.8	2233.8	2277.7	2265.7	2261.8	2261.8	2257.7
32.5°	2162.0	2166.1	2158.1	2162.0	2166.1	2150.1	2185.9	2170.0	2166.1	2170.0	2174.1
35°	2054.3	2054.3	2062.3	2050.4	2066.3	2066.3	2098.2	2078.2	2074.3	2062.3	2074.3
37.5°	1958.6	1946.7	1950.6	1950.6	1958.6	1966.6	1982.5	1974.5	1974.5	1962.6	1970.6
40°	1831.0	1823.0	1834.9	1834.9	1846.9	1846.9	1862.9	1854.9	1866.8	1866.8	1866.8
42.5°	1719.3	1719.3	1711.4	1723.2	1727.3	1723.2	1751.2	1747.2	1751.2	1743.3	1747.2
45°	1599.5	1599.5	1591.6	1587.7	1607.5	1603.6	1635.5	1623.5	1639.4	1631.4	1635.5
47.5°	1436.0	1456.0	1444.0	1456.0	1479.9	1484.0	1503.8	1495.9	1511.8	1499.9	1515.9
50°	1280.5	1280.5	1292.4	1308.4	1332.3	1336.4	1360.3	1376.2	1384.2	1388.1	1392.2
52.5°	1117.0	1112.9	1125.0	1144.8	1164.8	1180.8	1204.7	1228.6	1244.6	1268.5	1256.5
55°	925.4	933.4	945.4	969.4	1001.3	1021.1	1041.1	1073.0	1101.0	1112.9	1136.8
57.5°	761.9	753.9	761.9	793.8	829.7	845.7	873.7	905.6	945.4	969.4	977.3
60°	590.3	594.4	602.4	630.3	658.2	682.1	694.1	745.9	781.9	805.8	821.7
62.5°	434.9	442.9	450.8	474.8	502.6	522.6	542.5	586.4	618.3	642.2	658.2
65°	303.2	307.1	319.2	331.0	359.0	378.9	394.8	430.8	462.7	482.7	494.6
67.5°	187.5	191.4	199.4	215.5	235.3	251.3	267.2	291.2	319.2	339.0	343.1
70°	95.7	99.8	103.7	115.7	131.7	139.6	151.5	171.5	191.4	207.4	215.5
72.5°	31.9	31.9	36.0	43.9	51.9	59.9	63.8	83.8	99.8	107.7	111.7
75°	8.0	8.0	8.0	8.0	8.0	12.0	12.0	23.9	31.9	39.9	43.9
77.5°	4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1	8.0	8.0
80°	4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C55D010 FEU4C559050 F4LC-CSSQ-MW

CANDELA DISTRIBUTION (continued):

	50°	55°	60°	65°	67.5°	70°	75°	80°	85°	90°
0°	2808.3	2808.3	2808.3	2808.3	2808.3	2808.3	2808.3	2808.3	2808.3	2808.3
2.5°	2808.3	2800.3	2796.3	2800.3	2800.3	2796.3	2808.3	2824.3	2844.1	2792.4
5°	2804.3	2796.3	2804.3	2780.3	2792.4	2784.4	2800.3	2796.3	2812.2	2796.3
7.5°	2792.4	2776.4	2780.3	2768.4	2784.4	2764.4	2776.4	2800.3	2784.4	2760.5
10°	2752.5	2744.5	2772.4	2732.5	2724.5	2740.5	2772.4	2748.4	2740.5	2748.4
12.5°	2712.5	2712.5	2724.5	2692.6	2696.5	2704.5	2720.4	2704.5	2712.5	2732.5
15°	2668.7	2660.7	2680.6	2656.6	2652.7	2644.8	2660.7	2660.7	2668.7	2656.6
17.5°	2616.8	2604.9	2604.9	2596.9	2592.8	2612.9	2620.8	2624.7	2628.8	2612.9
20°	2553.0	2549.0	2560.9	2549.0	2553.0	2557.0	2557.0	2549.0	2584.9	2541.1
22.5°	2485.1	2497.1	2481.2	2473.2	2481.2	2489.2	2489.2	2493.1	2485.1	2477.1
25°	2417.4	2425.4	2429.3	2405.3	2417.4	2405.3	2433.3	2437.2	2421.3	2429.3
27.5°	2357.5	2345.6	2341.5	2325.6	2333.6	2329.7	2333.6	2333.6	2357.5	2325.6
30°	2265.7	2253.8	2257.7	2245.8	2249.8	2245.8	2249.8	2249.8	2265.7	2261.8
32.5°	2178.0	2166.1	2170.0	2158.1	2158.1	2162.0	2154.0	2154.0	2166.1	2158.1
35°	2094.2	2066.3	2070.2	2066.3	2070.2	2054.3	2054.3	2050.4	2058.3	2038.3
37.5°	1974.5	1962.6	1958.6	1954.7	1958.6	1950.6	1958.6	1946.7	1958.6	1942.6
40°	1866.8	1858.8	1862.9	1839.0	1839.0	1842.9	1834.9	1831.0	1834.9	1850.8
42.5°	1759.2	1743.3	1735.3	1727.3	1731.2	1719.3	1715.3	1707.3	1715.3	1699.3
45°	1631.4	1631.4	1627.5	1607.5	1611.6	1611.6	1595.6	1579.7	1583.6	1583.6
47.5°	1515.9	1507.9	1503.8	1484.0	1479.9	1476.0	1459.9	1448.0	1448.0	1436.0
50°	1388.1	1380.2	1368.3	1348.3	1340.3	1316.4	1304.5	1288.5	1272.6	1272.6
52.5°	1268.5	1240.5	1224.6	1192.7	1180.8	1168.7	1136.8	1125.0	1112.9	1101.0
55°	1125.0	1101.0	1069.1	1033.2	1017.2	997.2	965.3	941.4	925.4	929.5
57.5°	985.3	945.4	913.5	865.7	845.7	833.6	801.7	769.8	753.9	753.9
60°	813.8	781.9	742.0	698.1	682.1	662.2	622.2	602.4	590.3	578.4
62.5°	650.2	626.3	590.3	534.5	522.6	502.6	474.8	450.8	438.8	438.8
65°	486.6	462.7	430.8	390.9	375.0	359.0	335.1	311.2	299.1	295.2
67.5°	343.1	315.1	287.3	255.4	243.3	235.3	211.4	195.5	187.5	183.4
70°	207.4	191.4	171.5	147.6	135.6	127.6	111.7	99.8	95.7	91.8
72.5°	107.7	95.7	79.8	63.8	55.8	47.9	39.9	31.9	28.0	28.0
75°	39.9	31.9	20.0	12.0	8.0	8.0	8.0	8.0	8.0	8.0
77.5°	8.0	4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1
80°	4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1	4.1
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)