

LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P#

Luminaire Tested: **FLDSQ4C65D010 FEU4C659040 F4LC-DFSSQ-MW**

Issue Date: 12/13/2022

Tested By:

Approved By:



Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.



Test Information

Test Method: LM-79-08
 Report Number: P#
 Test Lab: INNOVATION CENTER
 Issue Date: 12/13/2022
 Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
 Product Line: FAIL-SAFE
 Catalog Number: FLDSQ4C65D010 FEU4C659040 F4LC-DFSSQ-MW
 Description: 4 INCH 6500 LUMEN FAIL-SAFE LED DOWNLIGHT WITH, 4000K, 90CRI LEDS AND F4LC-DFSSQ TRIM WITH MW FINISH
 Light Source: -
 Ballast/Driver: -

Summary


Lumens per Lamp: N/A
 Luminaire Lumens: 6647.0 lumens
 Efficiency: N/A
 Efficacy: 91.8 lumens/watt
 Spacing Criteria (0/90/45): 1.19 / 1.2 / 1.29
 Luminous Opening: Rectangular (W 0.33' x L: 0.33' x H: 0')
 CIE Type: Direct

Input Watts (W): 72.4
 Input Voltage (V):
 Input Current (Ain): NR
 Voltage Rise (V): NR
 Power Factor: NR
 Total Harmonic Distortion (THDi): NR
 Frequency (hertz): 60
 Stabilization Time: NR
 Operation Time: NR
 Ambient Temperature (°C): NR
 Test Distance: 25 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	GONIO 1 IN0055	4/22/2021	10/22/2021
Power Meter	XITRON 2801 IN0197	12/1/2020	12/1/2021
AC Power Source	CHROMA 61505 IN0196	12/1/2020	12/1/2021
DC Power Supply	AGILENT E3634A IN0198	11/30/2020	11/30/2021
Room Thermometer	ONSET IN0143	12/1/2020	12/1/2021

TEST NUMBER: P#
CATALOG NUMBER: FLDSQ4C65D010 FEU4C659040 F4LC-DFSSQ-MW

Luminous Intensity Polar Plot



TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C65D010 FEU4C659040 F4LC-DFSSQ-MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20	
RC	80					70					50					30					10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100				100
1	111	108	104	101	109	105	102	100	101	99	96	97	95	94	94	92	91	89				89
2	103	96	91	86	100	94	89	85	91	87	83	88	84	81	85	82	79	77				77
3	95	86	79	74	93	85	78	73	82	76	72	79	74	71	77	73	69	67				67
4	88	77	70	64	86	76	69	63	74	67	63	71	66	62	69	65	61	59				59
5	81	70	62	56	79	69	61	56	67	60	55	65	59	54	63	58	54	52				52
6	75	63	55	49	73	62	55	49	61	54	49	59	53	48	57	52	48	46				46
7	70	58	50	44	68	57	49	44	55	49	44	54	48	43	53	47	43	41				41
8	65	53	45	40	64	52	45	39	51	44	39	50	44	39	49	43	39	37				37
9	61	49	41	36	60	48	41	36	47	40	36	46	40	35	45	39	35	33				33
10	57	45	38	33	56	44	37	33	44	37	32	43	37	32	42	36	32	31				31

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	300244	300244	300244
5°	295396	299241	300093
10°	297949	297077	298371
15°	292725	293165	294044
20°	285916	290455	289110
25°	284684	284684	286568
30°	276746	278718	279219
35°	268116	270731	266031
40°	255542	260530	258313
45°	241841	247285	239439
50°	212991	231560	211655
55°	172496	211894	173253
60°	126227	175706	123679
65°	76713	125115	74681
70°	29904	67369	28691
75°	3281	18156	3281
80°	2500	2500	2500
85°	0	0	0

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C65D010 FEU4C659040 F4LC-DFSSQ-MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	293.7	4.4
10°-20°	831.1	12.5
20°-30°	1233.2	18.6
30°-40°	1428.9	21.5
40°-50°	1370.0	20.6
50°-60°	1007.3	15.2
60°-70°	435.1	6.5
70°-80°	47.0	0.7
80°-90°	0.6	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2358.1	35.5
0°-40°	3787.0	57.0
0°-60°	6164.3	92.7
0°-90°	6647.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	6647.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3112	3112	3112	3112	3112	
5°	3050	3081	3090	3094	3098	291
15°	2930	2948	2935	2939	2944	826
25°	2674	2670	2674	2678	2692	1224
35°	2276	2290	2298	2294	2258	1423
45°	1772	1777	1812	1786	1755	1347
55°	1025	1131	1260	1127	1030	923
65°	336	420	548	416	327	345
75°	9	13	49	9	9	27
85°	0	0	0	0	0	1
90°	0	0	0	0	0	

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C65D010 FEU4C659040 F4LC-DFSSQ-MW

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	22.5°	25°	30°	35°	40°	45°
0°	3111.7	3111.7	3111.7	3111.7	3111.7	3111.7	3111.7	3111.7	3111.7	3111.7	3111.7
2.5°	3089.5	3124.8	3129.3	3107.2	3098.3	3085.2	3116.0	3094.0	3102.8	3094.0	3089.5
5°	3049.8	3089.5	3094.0	3094.0	3085.2	3080.7	3094.0	3089.5	3085.2	3076.3	3089.5
7.5°	3032.1	3054.1	3076.3	3049.8	3063.0	3058.6	3089.5	3076.3	3071.8	3071.8	3063.0
10°	3041.0	3036.5	3054.1	3027.6	3036.5	3027.6	3054.1	3054.1	3045.3	3036.5	3032.1
12.5°	2970.1	3005.5	3005.5	3001.1	2992.3	2978.9	3005.5	3023.3	2996.6	2996.6	2992.3
15°	2930.4	2939.3	2943.6	2943.6	2939.3	2948.1	2961.3	2943.6	2948.1	2925.9	2934.8
17.5°	2886.2	2868.6	2881.7	2872.9	2877.4	2886.2	2903.9	2903.9	2877.4	2872.9	2881.7
20°	2784.5	2837.6	2842.1	2815.6	2819.9	2819.9	2850.9	2824.4	2842.1	2819.9	2828.7
22.5°	2735.9	2771.2	2775.7	2740.4	2762.4	2735.9	2766.9	2727.0	2771.2	2740.4	2753.5
25°	2674.0	2669.7	2682.8	2665.2	2669.7	2669.7	2691.7	2674.0	2687.3	2669.7	2674.0
27.5°	2572.5	2607.8	2603.3	2585.6	2594.5	2590.1	2634.3	2585.6	2612.1	2590.1	2599.0
30°	2483.9	2514.9	2506.1	2488.4	2488.4	2475.1	2523.8	2510.4	2506.1	2506.1	2501.6
32.5°	2395.6	2400.1	2391.2	2395.6	2400.1	2382.4	2422.1	2404.4	2400.1	2404.4	2408.9
35°	2276.2	2276.2	2285.0	2271.9	2289.5	2289.5	2324.9	2302.7	2298.4	2285.0	2298.4
37.5°	2170.1	2157.0	2161.3	2161.3	2170.1	2179.0	2196.7	2187.8	2187.8	2174.6	2183.5
40°	2028.8	2019.9	2033.1	2033.1	2046.4	2046.4	2064.1	2055.3	2068.4	2068.4	2068.4
42.5°	1905.0	1905.0	1896.2	1909.4	1913.9	1909.4	1940.4	1935.9	1940.4	1931.6	1935.9
45°	1772.3	1772.3	1763.5	1759.2	1781.2	1776.8	1812.2	1798.8	1816.5	1807.7	1812.2
47.5°	1591.1	1613.3	1599.9	1613.3	1639.8	1644.3	1666.3	1657.5	1675.1	1662.0	1679.6
50°	1418.9	1418.9	1432.0	1449.7	1476.2	1480.7	1507.2	1524.9	1533.7	1538.1	1542.6
52.5°	1237.6	1233.1	1246.5	1268.5	1290.7	1308.3	1334.8	1361.3	1379.0	1405.5	1392.2
55°	1025.4	1034.2	1047.6	1074.1	1109.4	1131.4	1153.6	1188.9	1220.0	1233.1	1259.6
57.5°	844.1	835.3	844.1	879.5	919.3	937.0	968.0	1003.4	1047.6	1074.1	1082.9
60°	654.1	658.6	667.4	698.4	729.3	755.8	769.1	826.5	866.3	892.8	910.5
62.5°	481.8	490.7	499.5	526.0	556.9	579.1	601.1	649.7	685.1	711.6	729.3
65°	336.0	340.3	353.6	366.8	397.8	419.8	437.5	477.3	512.7	534.9	548.0
67.5°	207.7	212.1	220.9	238.8	260.8	278.4	296.1	322.6	353.6	375.6	380.1
70°	106.0	110.5	114.9	128.2	145.9	154.7	167.9	190.1	212.1	229.7	238.8
72.5°	35.3	35.3	39.9	48.7	57.5	66.4	70.7	92.9	110.5	119.4	123.7
75°	8.8	8.8	8.8	8.8	8.8	13.3	13.3	26.5	35.3	44.2	48.7
77.5°	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	8.8	8.8
80°	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C65D010 FEU4C659040 F4LC-DFSSQ-MW

CANDELA DISTRIBUTION (continued):

	50°	55°	60°	65°	67.5°	70°	75°	80°	85°	90°
0°	3111.7	3111.7	3111.7	3111.7	3111.7	3111.7	3111.7	3111.7	3111.7	3111.7
2.5°	3111.7	3102.8	3098.3	3102.8	3102.8	3098.3	3111.7	3129.3	3151.3	3094.0
5°	3107.2	3098.3	3107.2	3080.7	3094.0	3085.2	3102.8	3098.3	3116.0	3098.3
7.5°	3094.0	3076.3	3080.7	3067.5	3085.2	3063.0	3076.3	3102.8	3085.2	3058.6
10°	3049.8	3041.0	3071.8	3027.6	3018.8	3036.5	3071.8	3045.3	3036.5	3045.3
12.5°	3005.5	3005.5	3018.8	2983.5	2987.8	2996.6	3014.3	2996.6	3005.5	3027.6
15°	2956.9	2948.1	2970.1	2943.6	2939.3	2930.4	2948.1	2948.1	2956.9	2943.6
17.5°	2899.4	2886.2	2886.2	2877.4	2872.9	2895.1	2903.9	2908.3	2912.8	2895.1
20°	2828.7	2824.4	2837.6	2824.4	2828.7	2833.2	2833.2	2824.4	2864.1	2815.6
22.5°	2753.5	2766.9	2749.2	2740.4	2749.2	2758.0	2758.0	2762.4	2753.5	2744.7
25°	2678.5	2687.3	2691.7	2665.2	2678.5	2665.2	2696.2	2700.5	2682.8	2691.7
27.5°	2612.1	2599.0	2594.5	2576.8	2585.6	2581.3	2585.6	2585.6	2612.1	2576.8
30°	2510.4	2497.3	2501.6	2488.4	2492.8	2488.4	2492.8	2492.8	2510.4	2506.1
32.5°	2413.2	2400.1	2404.4	2391.2	2391.2	2395.6	2386.7	2386.7	2400.1	2391.2
35°	2320.4	2289.5	2293.9	2289.5	2293.9	2276.2	2276.2	2271.9	2280.7	2258.5
37.5°	2187.8	2174.6	2170.1	2165.8	2170.1	2161.3	2170.1	2157.0	2170.1	2152.5
40°	2068.4	2059.6	2064.1	2037.6	2037.6	2041.9	2033.1	2028.8	2033.1	2050.8
42.5°	1949.2	1931.6	1922.7	1913.9	1918.2	1905.0	1900.5	1891.7	1900.5	1882.9
45°	1807.7	1807.7	1803.3	1781.2	1785.7	1785.7	1768.0	1750.3	1754.7	1754.7
47.5°	1679.6	1670.8	1666.3	1644.3	1639.8	1635.4	1617.6	1604.4	1604.4	1591.1
50°	1538.1	1529.2	1516.1	1493.9	1485.1	1458.5	1445.4	1427.7	1410.0	1410.0
52.5°	1405.5	1374.5	1356.8	1321.5	1308.3	1295.0	1259.6	1246.5	1233.1	1220.0
55°	1246.5	1220.0	1184.6	1144.8	1127.1	1104.9	1069.6	1043.1	1025.4	1029.9
57.5°	1091.7	1047.6	1012.2	959.2	937.0	923.7	888.3	853.0	835.3	835.3
60°	901.7	866.3	822.1	773.5	755.8	733.8	689.4	667.4	654.1	640.9
62.5°	720.4	693.9	654.1	592.2	579.1	556.9	526.0	499.5	486.2	486.2
65°	539.2	512.7	477.3	433.2	415.5	397.8	371.3	344.8	331.5	327.1
67.5°	380.1	349.1	318.3	282.9	269.6	260.8	234.3	216.6	207.7	203.2
70°	229.7	212.1	190.1	163.6	150.2	141.4	123.7	110.5	106.0	101.7
72.5°	119.4	106.0	88.4	70.7	61.9	53.0	44.2	35.3	31.0	31.0
75°	44.2	35.3	22.2	13.3	8.8	8.8	8.8	8.8	8.8	8.8
77.5°	8.8	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5
80°	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)