

LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P#

Luminaire Tested: **FLDSQ4C70D010 FEU4C709027 F4LC-DFSSQ-MW**

Issue Date: 12/13/2022

Tested By:

Approved By:



Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-08
 Report Number: P#
 Test Lab: INNOVATION CENTER
 Issue Date: 12/13/2022
 Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
 Product Line: FAIL-SAFE
 Catalog Number: FLDSQ4C70D010 FEU4C709027 F4LC-DFSSQ-MW
 Description: 4 INCH 7000 LUMEN FAIL-SAFE LED DOWNLIGHT WITH, 2700K, 90CRI LEDS AND F4LC-DFSSQ TRIM WITH MW FINISH
 Light Source: -
 Ballast/Driver: -

Summary


Lumens per Lamp: N/A
 Luminaire Lumens: 6613.0 lumens
 Efficiency: N/A
 Efficacy: 84.8 lumens/watt
 Spacing Criteria (0/90/45): 1.19 / 1.2 / 1.29
 Luminous Opening: Rectangular (W 0.33' x L: 0.33' x H: 0')
 CIE Type: Direct

Input Watts (W): 78
 Input Voltage (V):
 Input Current (Ain): NR
 Voltage Rise (V): NR
 Power Factor: NR
 Total Harmonic Distortion (THDi): NR
 Frequency (hertz): 60
 Stabilization Time: NR
 Operation Time: NR
 Ambient Temperature (°C): NR
 Test Distance: 25 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	GONIO 1 IN0055	4/22/2021	10/22/2021
Power Meter	XITRON 2801 IN0197	12/1/2020	12/1/2021
AC Power Source	CHROMA 61505 IN0196	12/1/2020	12/1/2021
DC Power Supply	AGILENT E3634A IN0198	11/30/2020	11/30/2021
Room Thermometer	ONSET IN0143	12/1/2020	12/1/2021

TEST NUMBER: P#
CATALOG NUMBER: FLDSQ4C70D010 FEU4C709027 F4LC-DFSSQ-MW

Luminous Intensity Polar Plot



TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C70D010 FEU4C709027 F4LC-DFSSQ-MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	111	108	104	101	109	105	102	100	101	99	96		97	95	94		94	92	91	89
2	103	96	91	86	100	94	89	85	91	87	83		88	84	81		85	82	79	77
3	95	86	79	74	93	85	78	73	82	76	72		79	74	71		77	73	69	67
4	88	77	70	64	86	76	69	63	74	67	63		71	66	62		69	65	61	59
5	81	70	62	56	79	69	61	56	67	60	55		65	59	54		63	58	54	52
6	75	63	55	49	73	62	55	49	61	54	49		59	53	48		57	52	48	46
7	70	58	50	44	68	57	49	44	55	49	44		54	48	43		53	47	43	41
8	65	53	45	40	64	52	45	39	51	44	39		50	44	39		49	43	39	37
9	61	49	41	36	60	48	41	36	47	40	36		46	40	35		45	39	35	33
10	57	45	38	33	56	44	37	33	44	37	32		43	37	32		42	36	32	31

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	298701	298701	298701
5°	293885	297711	298563
10°	296421	295559	296842
15°	291227	291667	292536
20°	284458	288976	287631
25°	283225	283225	285099
30°	275331	277292	277793
35°	266738	269341	264677
40°	254232	259208	256991
45°	240613	246016	238211
50°	211895	230374	210574
55°	171605	210817	172362
60°	125571	174819	123043
65°	76302	124476	74316
70°	29763	67002	28550
75°	3281	18044	3281
80°	2500	2500	2500
85°	0	0	0

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C70D010 FEU4C709027 F4LC-DFSSQ-MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	292.2	4.4
10°-20°	826.9	12.5
20°-30°	1226.9	18.6
30°-40°	1421.6	21.5
40°-50°	1363.0	20.6
50°-60°	1002.2	15.2
60°-70°	432.8	6.5
70°-80°	46.7	0.7
80°-90°	0.6	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2346.0	35.5
0°-40°	3767.6	57.0
0°-60°	6132.8	92.7
0°-90°	6613.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	6613.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3096	3096	3096	3096	3096	
5°	3034	3065	3074	3078	3082	289
15°	2915	2933	2920	2924	2928	822
25°	2660	2656	2660	2665	2678	1218
35°	2264	2278	2287	2282	2247	1416
45°	1763	1768	1803	1776	1746	1340
55°	1020	1126	1253	1121	1025	918
65°	334	418	545	413	326	344
75°	9	13	48	9	9	27
85°	0	0	0	0	0	1
90°	0	0	0	0	0	

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C70D010 FEU4C709027 F4LC-DFSSQ-MW

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	22.5°	25°	30°	35°	40°	45°
0°	3095.7	3095.7	3095.7	3095.7	3095.7	3095.7	3095.7	3095.7	3095.7	3095.7	3095.7
2.5°	3073.7	3108.9	3113.3	3091.3	3082.5	3069.4	3100.1	3078.2	3087.0	3078.2	3073.7
5°	3034.2	3073.7	3078.2	3078.2	3069.4	3064.9	3078.2	3073.7	3069.4	3060.6	3073.7
7.5°	3016.6	3038.5	3060.6	3034.2	3047.3	3043.0	3073.7	3060.6	3056.1	3056.1	3047.3
10°	3025.4	3020.9	3038.5	3012.1	3020.9	3012.1	3038.5	3038.5	3029.7	3020.9	3016.6
12.5°	2954.9	2990.1	2990.1	2985.8	2977.0	2963.7	2990.1	3007.8	2981.3	2981.3	2977.0
15°	2915.4	2924.2	2928.5	2928.5	2924.2	2933.0	2946.1	2928.5	2933.0	2911.0	2919.8
17.5°	2871.5	2853.9	2867.0	2858.2	2862.7	2871.5	2889.1	2889.1	2862.7	2858.2	2867.0
20°	2770.3	2823.0	2827.5	2801.2	2805.5	2805.5	2836.3	2809.9	2827.5	2805.5	2814.3
22.5°	2721.9	2757.0	2761.5	2726.3	2748.2	2721.9	2752.7	2713.1	2757.0	2726.3	2739.4
25°	2660.3	2656.0	2669.1	2651.5	2656.0	2656.0	2677.9	2660.3	2673.6	2656.0	2660.3
27.5°	2559.3	2594.5	2590.0	2572.4	2581.2	2576.9	2620.8	2572.4	2598.8	2576.9	2585.7
30°	2471.2	2502.1	2493.3	2475.7	2475.7	2462.4	2510.9	2497.6	2493.3	2493.3	2488.8
32.5°	2383.3	2387.8	2379.0	2383.3	2387.8	2370.2	2409.7	2392.1	2387.8	2392.1	2396.6
35°	2264.5	2264.5	2273.3	2260.2	2277.8	2277.8	2313.0	2290.9	2286.6	2273.3	2286.6
37.5°	2159.0	2145.9	2150.3	2150.3	2159.0	2167.8	2185.4	2176.6	2176.6	2163.5	2172.3
40°	2018.4	2009.6	2022.7	2022.7	2036.0	2036.0	2053.5	2044.8	2057.9	2057.9	2057.9
42.5°	1895.3	1895.3	1886.5	1899.6	1904.1	1899.6	1930.5	1926.0	1930.5	1921.7	1926.0
45°	1763.3	1763.3	1754.5	1750.2	1772.1	1767.7	1802.9	1789.6	1807.2	1798.4	1802.9
47.5°	1583.0	1605.0	1591.7	1605.0	1631.4	1635.9	1657.8	1649.0	1666.6	1653.5	1671.0
50°	1411.6	1411.6	1424.7	1442.3	1468.7	1473.1	1499.5	1517.1	1525.9	1530.2	1534.7
52.5°	1231.3	1226.8	1240.1	1262.0	1284.0	1301.6	1328.0	1354.4	1372.0	1398.3	1385.1
55°	1020.1	1028.9	1042.2	1068.6	1103.7	1125.6	1147.7	1182.9	1213.7	1226.8	1253.2
57.5°	839.8	831.0	839.8	875.0	914.6	932.2	963.1	998.2	1042.2	1068.6	1077.4
60°	650.7	655.2	664.0	694.9	725.5	751.9	765.2	822.2	861.9	888.3	905.9
62.5°	479.4	488.2	497.0	523.3	554.0	576.1	598.0	646.4	681.6	708.0	725.5
65°	334.2	338.6	351.8	364.9	395.8	417.7	435.3	474.9	510.1	532.1	545.2
67.5°	206.7	211.0	219.8	237.5	259.4	277.0	294.6	321.0	351.8	373.7	378.2
70°	105.5	110.0	114.3	127.6	145.1	153.9	167.0	189.1	211.0	228.6	237.5
72.5°	35.2	35.2	39.6	48.4	57.2	66.0	70.3	92.4	110.0	118.8	123.1
75°	8.8	8.8	8.8	8.8	8.8	13.3	13.3	26.4	35.2	44.0	48.4
77.5°	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	8.8	8.8
80°	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C70D010 FEU4C709027 F4LC-DFSSQ-MW

CANDELA DISTRIBUTION (continued):

	50°	55°	60°	65°	67.5°	70°	75°	80°	85°	90°
0°	3095.7	3095.7	3095.7	3095.7	3095.7	3095.7	3095.7	3095.7	3095.7	3095.7
2.5°	3095.7	3087.0	3082.5	3087.0	3087.0	3082.5	3095.7	3113.3	3135.2	3078.2
5°	3091.3	3082.5	3091.3	3064.9	3078.2	3069.4	3087.0	3082.5	3100.1	3082.5
7.5°	3078.2	3060.6	3064.9	3051.8	3069.4	3047.3	3060.6	3087.0	3069.4	3043.0
10°	3034.2	3025.4	3056.1	3012.1	3003.4	3020.9	3056.1	3029.7	3020.9	3029.7
12.5°	2990.1	2990.1	3003.4	2968.2	2972.5	2981.3	2998.9	2981.3	2990.1	3012.1
15°	2941.8	2933.0	2954.9	2928.5	2924.2	2915.4	2933.0	2933.0	2941.8	2928.5
17.5°	2884.6	2871.5	2871.5	2862.7	2858.2	2880.3	2889.1	2893.4	2897.9	2880.3
20°	2814.3	2809.9	2823.0	2809.9	2814.3	2818.7	2818.7	2809.9	2849.4	2801.2
22.5°	2739.4	2752.7	2735.1	2726.3	2735.1	2743.9	2743.9	2748.2	2739.4	2730.7
25°	2664.8	2673.6	2677.9	2651.5	2664.8	2651.5	2682.4	2686.7	2669.1	2677.9
27.5°	2598.8	2585.7	2581.2	2563.6	2572.4	2568.1	2572.4	2572.4	2598.8	2563.6
30°	2497.6	2484.5	2488.8	2475.7	2480.0	2475.7	2480.0	2480.0	2497.6	2493.3
32.5°	2400.9	2387.8	2392.1	2379.0	2379.0	2383.3	2374.5	2374.5	2387.8	2379.0
35°	2308.5	2277.8	2282.1	2277.8	2282.1	2264.5	2264.5	2260.2	2269.0	2247.0
37.5°	2176.6	2163.5	2159.0	2154.7	2159.0	2150.3	2159.0	2145.9	2159.0	2141.5
40°	2057.9	2049.1	2053.5	2027.2	2027.2	2031.5	2022.7	2018.4	2022.7	2040.3
42.5°	1939.3	1921.7	1912.9	1904.1	1908.4	1895.3	1890.8	1882.0	1890.8	1873.2
45°	1798.4	1798.4	1794.1	1772.1	1776.5	1776.5	1759.0	1741.4	1745.7	1745.7
47.5°	1671.0	1662.2	1657.8	1635.9	1631.4	1627.1	1609.3	1596.2	1596.2	1583.0
50°	1530.2	1521.4	1508.3	1486.2	1477.5	1451.1	1438.0	1420.4	1402.8	1402.8
52.5°	1398.3	1367.5	1349.9	1314.7	1301.6	1288.4	1253.2	1240.1	1226.8	1213.7
55°	1240.1	1213.7	1178.6	1138.9	1121.3	1099.3	1064.1	1037.7	1020.1	1024.6
57.5°	1086.2	1042.2	1007.0	954.3	932.2	919.0	883.8	848.6	831.0	831.0
60°	897.1	861.9	817.9	769.5	751.9	730.0	685.9	664.0	650.7	637.6
62.5°	716.8	690.4	650.7	589.2	576.1	554.0	523.3	497.0	483.7	483.7
65°	536.4	510.1	474.9	430.9	413.4	395.8	369.4	343.0	329.8	325.5
67.5°	378.2	347.3	316.7	281.5	268.2	259.4	233.1	215.5	206.7	202.2
70°	228.6	211.0	189.1	162.7	149.5	140.7	123.1	110.0	105.5	101.2
72.5°	118.8	105.5	87.9	70.3	61.5	52.7	44.0	35.2	30.9	30.9
75°	44.0	35.2	22.1	13.3	8.8	8.8	8.8	8.8	8.8	8.8
77.5°	8.8	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5
80°	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)