

LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P#

Luminaire Tested: **FLDSQ4C70D010 FEU4C709030 F4LC-DFSSQ-MW**

Issue Date: 12/13/2022

Tested By:

Approved By:



Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-08
 Report Number: P#
 Test Lab: INNOVATION CENTER
 Issue Date: 12/13/2022
 Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
 Product Line: FAIL-SAFE
 Catalog Number: FLDSQ4C70D010 FEU4C709030 F4LC-DFSSQ-MW
 Description: 4 INCH 7000 LUMEN FAIL-SAFE LED DOWNLIGHT WITH, 3000K, 90CRI LEDS AND F4LC-DFSSQ TRIM WITH MW FINISH
 Light Source: -
 Ballast/Driver: -

Summary


Lumens per Lamp: N/A
 Luminaire Lumens: 6875.0 lumens
 Efficiency: N/A
 Efficacy: 88.1 lumens/watt
 Spacing Criteria (0/90/45): 1.19 / 1.2 / 1.29
 Luminous Opening: Rectangular (W 0.33' x L: 0.33' x H: 0')
 CIE Type: Direct

Input Watts (W): 78
 Input Voltage (V):
 Input Current (Ain): NR
 Voltage Rise (V): NR
 Power Factor: NR
 Total Harmonic Distortion (THDi): NR
 Frequency (hertz): 60
 Stabilization Time: NR
 Operation Time: NR
 Ambient Temperature (°C): NR
 Test Distance: 25 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	GONIO 1 IN0055	4/22/2021	10/22/2021
Power Meter	XITRON 2801 IN0197	12/1/2020	12/1/2021
AC Power Source	CHROMA 61505 IN0196	12/1/2020	12/1/2021
DC Power Supply	AGILENT E3634A IN0198	11/30/2020	11/30/2021
Room Thermometer	ONSET IN0143	12/1/2020	12/1/2021

TEST NUMBER: P#
CATALOG NUMBER: FLDSQ4C70D010 FEU4C709030 F4LC-DFSSQ-MW

Luminous Intensity Polar Plot



TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C70D010 FEU4C709030 F4LC-DFSSQ-MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	111	108	104	101	109	105	102	100	101	99	96		97	95	94		94	92	91	89
2	103	96	91	86	100	94	89	85	91	87	83		88	84	81		85	82	79	77
3	95	86	79	74	93	85	78	73	82	76	72		79	74	71		77	73	69	67
4	88	77	70	64	86	76	69	63	74	67	63		71	66	62		69	65	61	59
5	81	70	62	56	79	69	61	56	67	60	55		65	59	54		63	58	54	52
6	75	63	55	49	73	62	55	49	61	54	49		59	53	48		57	52	48	46
7	70	58	50	44	68	57	49	44	55	49	44		54	48	43		53	47	43	41
8	65	53	45	40	64	52	45	39	51	44	39		50	44	39		49	43	39	37
9	61	49	41	36	60	48	41	36	47	40	36		46	40	35		45	39	35	33
10	57	45	38	33	56	44	37	33	44	37	32		43	37	32		42	36	32	31

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	310540	310540	310540
5°	305527	309508	310389
10°	308168	307267	308609
15°	302765	303214	304133
20°	295733	300425	299018
25°	294447	294447	296395
30°	286238	288277	288801
35°	277316	280013	275160
40°	264296	269473	267168
45°	250137	255759	247640
50°	220287	239501	218921
55°	178418	219161	179191
60°	130549	181727	127925
65°	79338	129407	77238
70°	30948	69654	29678
75°	3393	18789	3393
80°	2612	2612	2612
85°	0	0	0

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C70D010 FEU4C709030 F4LC-DFSSQ-MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	303.8	4.4
10°-20°	859.6	12.5
20°-30°	1275.5	18.6
30°-40°	1478.0	21.5
40°-50°	1417.0	20.6
50°-60°	1041.9	15.2
60°-70°	450.0	6.5
70°-80°	48.6	0.7
80°-90°	0.6	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2438.9	35.5
0°-40°	3916.9	57.0
0°-60°	6375.8	92.7
0°-90°	6875.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	6875.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3218	3218	3218	3218	3218	
5°	3154	3186	3196	3200	3205	301
15°	3031	3049	3035	3040	3045	854
25°	2766	2761	2766	2770	2784	1266
35°	2354	2368	2377	2372	2336	1472
45°	1833	1838	1874	1847	1815	1393
55°	1061	1170	1303	1166	1065	954
65°	348	434	567	430	338	357
75°	9	14	50	9	9	28
85°	0	0	0	0	0	1
90°	0	0	0	0	0	

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C70D010 FEU4C709030 F4LC-DFSSQ-MW

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	22.5°	25°	30°	35°	40°	45°
0°	3218.4	3218.4	3218.4	3218.4	3218.4	3218.4	3218.4	3218.4	3218.4	3218.4	3218.4
2.5°	3195.5	3232.0	3236.7	3213.7	3204.6	3191.0	3222.9	3200.1	3209.3	3200.1	3195.5
5°	3154.4	3195.5	3200.1	3200.1	3191.0	3186.3	3200.1	3195.5	3191.0	3181.8	3195.5
7.5°	3136.1	3158.9	3181.8	3154.4	3168.0	3163.6	3195.5	3181.8	3177.2	3177.2	3168.0
10°	3145.3	3140.6	3158.9	3131.5	3140.6	3131.5	3158.9	3158.9	3149.8	3140.6	3136.1
12.5°	3072.0	3108.5	3108.5	3104.1	3094.9	3081.1	3108.5	3127.0	3099.4	3099.4	3094.9
15°	3030.9	3040.1	3044.6	3044.6	3040.1	3049.2	3062.8	3044.6	3049.2	3026.3	3035.4
17.5°	2985.3	2967.0	2980.6	2971.5	2976.1	2985.3	3003.5	3003.5	2976.1	2971.5	2980.6
20°	2880.1	2934.9	2939.6	2912.1	2916.6	2916.6	2948.7	2921.3	2939.6	2916.6	2925.8
22.5°	2829.7	2866.3	2870.9	2834.4	2857.1	2829.7	2861.8	2820.6	2866.3	2834.4	2848.0
25°	2765.7	2761.2	2774.9	2756.6	2761.2	2761.2	2784.0	2765.7	2779.5	2761.2	2765.7
27.5°	2660.7	2697.3	2692.6	2674.3	2683.5	2679.0	2724.7	2674.3	2701.7	2679.0	2688.1
30°	2569.1	2601.2	2592.1	2573.8	2573.8	2560.0	2610.3	2596.5	2592.1	2592.1	2587.4
32.5°	2477.7	2482.4	2473.3	2477.7	2482.4	2464.1	2505.2	2486.9	2482.4	2486.9	2491.5
35°	2354.3	2354.3	2363.4	2349.8	2368.1	2368.1	2404.6	2381.7	2377.2	2363.4	2377.2
37.5°	2244.6	2231.0	2235.4	2235.4	2244.6	2253.7	2272.0	2262.9	2262.9	2249.2	2258.4
40°	2098.3	2089.2	2102.8	2102.8	2116.6	2116.6	2134.9	2125.8	2139.4	2139.4	2139.4
42.5°	1970.4	1970.4	1961.3	1974.9	1979.5	1974.9	2007.0	2002.3	2007.0	1997.8	2002.3
45°	1833.1	1833.1	1824.0	1819.5	1842.3	1837.8	1874.3	1860.5	1878.8	1869.7	1874.3
47.5°	1645.7	1668.6	1654.8	1668.6	1696.0	1700.7	1723.4	1714.3	1732.6	1719.0	1737.2
50°	1467.5	1467.5	1481.2	1499.4	1526.9	1531.5	1558.9	1577.2	1586.4	1590.8	1595.5
52.5°	1280.1	1275.4	1289.2	1312.0	1334.9	1353.2	1380.6	1408.0	1426.3	1453.7	1439.9
55°	1060.6	1069.7	1083.5	1110.9	1147.5	1170.2	1193.2	1229.7	1261.8	1275.4	1302.8
57.5°	873.1	864.0	873.1	909.7	950.9	969.2	1001.2	1037.8	1083.5	1110.9	1120.1
60°	676.5	681.2	690.3	722.4	754.3	781.7	795.5	854.8	896.0	923.5	941.7
62.5°	498.4	507.5	516.7	544.1	576.0	598.9	621.7	672.0	708.6	736.0	754.3
65°	347.5	352.0	365.8	379.4	411.5	434.2	452.5	493.7	530.3	553.2	566.8
67.5°	214.9	219.4	228.5	246.9	269.7	288.0	306.3	333.7	365.8	388.5	393.2
70°	109.7	114.3	118.8	132.6	150.9	160.0	173.7	196.6	219.4	237.6	246.9
72.5°	36.6	36.6	41.2	50.4	59.5	68.6	73.1	96.1	114.3	123.5	128.0
75°	9.1	9.1	9.1	9.1	9.1	13.8	13.8	27.4	36.6	45.7	50.4
77.5°	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7	9.1	9.1
80°	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C70D010 FEU4C709030 F4LC-DFSSQ-MW

CANDELA DISTRIBUTION (continued):

	50°	55°	60°	65°	67.5°	70°	75°	80°	85°	90°
0°	3218.4	3218.4	3218.4	3218.4	3218.4	3218.4	3218.4	3218.4	3218.4	3218.4
2.5°	3218.4	3209.3	3204.6	3209.3	3209.3	3204.6	3218.4	3236.7	3259.4	3200.1
5°	3213.7	3204.6	3213.7	3186.3	3200.1	3191.0	3209.3	3204.6	3222.9	3204.6
7.5°	3200.1	3181.8	3186.3	3172.7	3191.0	3168.0	3181.8	3209.3	3191.0	3163.6
10°	3154.4	3145.3	3177.2	3131.5	3122.3	3140.6	3177.2	3149.8	3140.6	3149.8
12.5°	3108.5	3108.5	3122.3	3085.8	3090.3	3099.4	3117.7	3099.4	3108.5	3131.5
15°	3058.4	3049.2	3072.0	3044.6	3040.1	3030.9	3049.2	3049.2	3058.4	3044.6
17.5°	2998.9	2985.3	2985.3	2976.1	2971.5	2994.4	3003.5	3008.0	3012.7	2994.4
20°	2925.8	2921.3	2934.9	2921.3	2925.8	2930.4	2930.4	2921.3	2962.3	2912.1
22.5°	2848.0	2861.8	2843.5	2834.4	2843.5	2852.6	2852.6	2857.1	2848.0	2838.8
25°	2770.4	2779.5	2784.0	2756.6	2770.4	2756.6	2788.7	2793.1	2774.9	2784.0
27.5°	2701.7	2688.1	2683.5	2665.2	2674.3	2669.8	2674.3	2674.3	2701.7	2665.2
30°	2596.5	2582.9	2587.4	2573.8	2578.3	2573.8	2578.3	2578.3	2596.5	2592.1
32.5°	2496.0	2482.4	2486.9	2473.3	2473.3	2477.7	2468.6	2468.6	2482.4	2473.3
35°	2400.0	2368.1	2372.5	2368.1	2372.5	2354.3	2354.3	2349.8	2358.9	2336.0
37.5°	2262.9	2249.2	2244.6	2240.1	2244.6	2235.4	2244.6	2231.0	2244.6	2226.3
40°	2139.4	2130.2	2134.9	2107.5	2107.5	2112.0	2102.8	2098.3	2102.8	2121.1
42.5°	2016.1	1997.8	1988.7	1979.5	1984.0	1970.4	1965.7	1956.6	1965.7	1947.5
45°	1869.7	1869.7	1865.2	1842.3	1846.9	1846.9	1828.6	1810.4	1814.8	1814.8
47.5°	1737.2	1728.1	1723.4	1700.7	1696.0	1691.5	1673.1	1659.5	1659.5	1645.7
50°	1590.8	1581.7	1568.1	1545.1	1536.0	1508.6	1495.0	1476.7	1458.4	1458.4
52.5°	1453.7	1421.7	1403.4	1366.8	1353.2	1339.4	1302.8	1289.2	1275.4	1261.8
55°	1289.2	1261.8	1225.2	1184.0	1165.7	1142.8	1106.3	1078.8	1060.6	1065.2
57.5°	1129.2	1083.5	1046.9	992.1	969.2	955.4	918.8	882.2	864.0	864.0
60°	932.6	896.0	850.3	800.0	781.7	758.9	713.1	690.3	676.5	662.9
62.5°	745.1	717.7	676.5	612.5	598.9	576.0	544.1	516.7	502.9	502.9
65°	557.7	530.3	493.7	448.0	429.7	411.5	384.0	356.6	342.8	338.3
67.5°	393.2	361.1	329.2	292.6	278.8	269.7	242.3	224.0	214.9	210.2
70°	237.6	219.4	196.6	169.2	155.4	146.2	128.0	114.3	109.7	105.2
72.5°	123.5	109.7	91.4	73.1	64.0	54.8	45.7	36.6	32.1	32.1
75°	45.7	36.6	22.9	13.8	9.1	9.1	9.1	9.1	9.1	9.1
77.5°	9.1	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7
80°	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7	4.7
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)