

LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P#

Luminaire Tested: **FLDSQ4C80D010 FEU4C809030 F4LC-DFSSQ-MW**

Issue Date: 12/13/2022

Tested By:

Approved By:



Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-08
 Report Number: P#
 Test Lab: INNOVATION CENTER
 Issue Date: 12/13/2022
 Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
 Product Line: FAIL-SAFE
 Catalog Number: FLDSQ4C80D010 FEU4C809030 F4LC-DFSSQ-MW
 Description: 4 INCH 8000 LUMEN FAIL-SAFE LED DOWNLIGHT WITH, 3000K, 90CRI LEDS AND F4LC-DFSSQ TRIM WITH MW FINISH
 Light Source: -
 Ballast/Driver: -

Summary


Lumens per Lamp: N/A
 Luminaire Lumens: 8731.0 lumens
 Efficiency: N/A
 Efficacy: 97.6 lumens/watt
 Spacing Criteria (0/90/45): 1.19 / 1.2 / 1.29
 Luminous Opening: Rectangular (W 0.33' x L: 0.33' x H: 0')
 CIE Type: Direct

Input Watts (W): 89.5
 Input Voltage (V):
 Input Current (Ain): NR
 Voltage Rise (V): NR
 Power Factor: NR
 Total Harmonic Distortion (THDi): NR
 Frequency (hertz): 60
 Stabilization Time: NR
 Operation Time: NR
 Ambient Temperature (°C): NR
 Test Distance: 25 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	GONIO 1 IN0055	4/22/2021	10/22/2021
Power Meter	XITRON 2801 IN0197	12/1/2020	12/1/2021
AC Power Source	CHROMA 61505 IN0196	12/1/2020	12/1/2021
DC Power Supply	AGILENT E3634A IN0198	11/30/2020	11/30/2021
Room Thermometer	ONSET IN0143	12/1/2020	12/1/2021

TEST NUMBER: P#
CATALOG NUMBER: FLDSQ4C80D010 FEU4C809030 F4LC-DFSSQ-MW

Luminous Intensity Polar Plot





TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C80D010 FEU4C809030 F4LC-DFSSQ-MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	111	108	104	101	109	105	102	100	101	99	96		97	95	94		94	92	91	89
2	103	96	91	86	100	94	89	85	91	87	83		88	84	81		85	82	79	77
3	95	86	79	74	93	85	78	73	82	76	72		79	74	71		77	73	69	67
4	88	77	70	64	86	76	69	63	74	67	63		71	66	62		69	65	61	59
5	81	70	62	56	79	69	61	56	67	60	55		65	59	54		63	58	54	52
6	75	63	55	49	73	62	55	49	61	54	49		59	53	48		57	52	48	46
7	70	58	50	44	68	57	49	44	55	49	44		54	48	43		53	47	43	41
8	65	53	45	40	64	52	45	39	51	44	39		50	44	39		49	43	39	37
9	61	49	41	36	60	48	41	36	47	40	36		46	40	35		45	39	35	33
10	57	45	38	33	56	44	37	33	44	37	32		43	37	32		42	36	32	31

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	394379	394379	394379
5°	388011	393057	394181
10°	391361	390224	391919
15°	384507	385076	386235
20°	375567	381523	379746
25°	373943	373943	376413
30°	363516	366101	366758
35°	352172	355612	349439
40°	335651	342213	339291
45°	317669	324806	314504
50°	279760	304153	278019
55°	226580	278342	227572
60°	165787	230801	162449
65°	100754	164362	98106
70°	39299	88471	37691
75°	4325	23859	4325
80°	3278	3278	3278
85°	0	0	0

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C80D010 FEU4C809030 F4LC-DFSSQ-MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	385.8	4.4
10°-20°	1091.7	12.5
20°-30°	1619.9	18.6
30°-40°	1876.9	21.5
40°-50°	1799.6	20.6
50°-60°	1323.1	15.2
60°-70°	571.5	6.5
70°-80°	61.7	0.7
80°-90°	0.8	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3097.4	35.5
0°-40°	4974.3	57.0
0°-60°	8097.0	92.7
0°-90°	8731.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	8731.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4087	4087	4087	4087	4087	
5°	4006	4046	4058	4064	4070	382
15°	3849	3872	3855	3861	3866	1085
25°	3512	3507	3512	3518	3536	1608
35°	2990	3007	3019	3013	2967	1870
45°	2328	2334	2380	2346	2305	1770
55°	1347	1486	1655	1480	1353	1212
65°	441	551	720	546	430	454
75°	12	18	64	12	12	36
85°	0	0	0	0	0	1
90°	0	0	0	0	0	

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C80D010 FEU4C809030 F4LC-DFSSQ-MW

CANDELA DISTRIBUTION (FULL):

	0°	5°	10°	15°	20°	22.5°	25°	30°	35°	40°	45°
0°	4087.3	4087.3	4087.3	4087.3	4087.3	4087.3	4087.3	4087.3	4087.3	4087.3	4087.3
2.5°	4058.1	4104.5	4110.5	4081.3	4069.7	4052.4	4092.9	4064.0	4075.6	4064.0	4058.1
5°	4006.0	4058.1	4064.0	4064.0	4052.4	4046.5	4064.0	4058.1	4052.4	4040.8	4058.1
7.5°	3982.8	4011.7	4040.8	4006.0	4023.3	4017.6	4058.1	4040.8	4034.9	4034.9	4023.3
10°	3994.4	3988.5	4011.7	3976.9	3988.5	3976.9	4011.7	4011.7	4000.1	3988.5	3982.8
12.5°	3901.3	3947.7	3947.7	3942.0	3930.4	3912.9	3947.7	3971.2	3936.1	3936.1	3930.4
15°	3849.2	3860.8	3866.5	3866.5	3860.8	3872.4	3889.7	3866.5	3872.4	3843.3	3854.9
17.5°	3791.2	3767.9	3785.2	3773.6	3779.6	3791.2	3814.4	3814.4	3779.6	3773.6	3785.2
20°	3657.6	3727.2	3733.1	3698.3	3704.0	3704.0	3744.7	3709.9	3733.1	3704.0	3715.6
22.5°	3593.6	3640.0	3646.0	3599.5	3628.4	3593.6	3634.4	3582.0	3640.0	3599.5	3616.8
25°	3512.4	3506.7	3524.0	3500.8	3506.7	3506.7	3535.6	3512.4	3529.9	3506.7	3512.4
27.5°	3379.0	3425.4	3419.5	3396.3	3407.9	3402.2	3460.2	3396.3	3431.1	3402.2	3413.8
30°	3262.7	3303.4	3291.8	3268.6	3268.6	3251.1	3315.0	3297.5	3291.8	3291.8	3285.9
32.5°	3146.6	3152.5	3140.9	3146.6	3152.5	3129.3	3181.5	3158.2	3152.5	3158.2	3164.2
35°	2989.8	2989.8	3001.4	2984.1	3007.3	3007.3	3053.8	3024.6	3019.0	3001.4	3019.0
37.5°	2850.5	2833.2	2838.9	2838.9	2850.5	2862.1	2885.4	2873.8	2873.8	2856.5	2868.1
40°	2664.8	2653.2	2670.5	2670.5	2688.0	2688.0	2711.3	2699.6	2716.9	2716.9	2716.9
42.5°	2502.3	2502.3	2490.7	2508.0	2513.9	2508.0	2548.8	2542.8	2548.8	2537.1	2542.8
45°	2328.0	2328.0	2316.4	2310.7	2339.6	2333.9	2380.3	2362.8	2386.0	2374.4	2380.3
47.5°	2089.9	2119.1	2101.5	2119.1	2153.9	2159.8	2188.7	2177.1	2200.3	2183.0	2206.2
50°	1863.7	1863.7	1881.0	1904.2	1939.0	1945.0	1979.8	2003.0	2014.6	2020.3	2026.2
52.5°	1625.7	1619.7	1637.3	1666.2	1695.3	1718.5	1753.3	1788.2	1811.4	1846.2	1828.7
55°	1346.9	1358.5	1376.0	1410.8	1457.2	1486.1	1515.3	1561.7	1602.4	1619.7	1654.6
57.5°	1108.8	1097.2	1108.8	1155.2	1207.6	1230.8	1271.5	1318.0	1376.0	1410.8	1422.4
60°	859.1	865.1	876.7	917.4	957.9	992.7	1010.3	1085.6	1137.9	1172.8	1196.0
62.5°	632.9	644.5	656.1	691.0	731.5	760.6	789.5	853.5	899.9	934.7	957.9
65°	441.3	447.0	464.5	481.8	522.5	551.4	574.7	627.0	673.4	702.6	719.9
67.5°	272.9	278.6	290.2	313.6	342.5	365.7	388.9	423.8	464.5	493.4	499.3
70°	139.3	145.2	150.9	168.4	191.6	203.2	220.5	249.7	278.6	301.8	313.6
72.5°	46.4	46.4	52.3	64.0	75.6	87.2	92.9	122.0	145.2	156.8	162.5
75°	11.6	11.6	11.6	11.6	11.6	17.5	17.5	34.8	46.4	58.0	64.0
77.5°	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9	11.6	11.6
80°	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P#
 CATALOG NUMBER: FLDSQ4C80D010 FEU4C809030 F4LC-DFSSQ-MW

CANDELA DISTRIBUTION (continued):

	50°	55°	60°	65°	67.5°	70°	75°	80°	85°	90°
0°	4087.3	4087.3	4087.3	4087.3	4087.3	4087.3	4087.3	4087.3	4087.3	4087.3
2.5°	4087.3	4075.6	4069.7	4075.6	4075.6	4069.7	4087.3	4110.5	4139.4	4064.0
5°	4081.3	4069.7	4081.3	4046.5	4064.0	4052.4	4075.6	4069.7	4092.9	4069.7
7.5°	4064.0	4040.8	4046.5	4029.2	4052.4	4023.3	4040.8	4075.6	4052.4	4017.6
10°	4006.0	3994.4	4034.9	3976.9	3965.3	3988.5	4034.9	4000.1	3988.5	4000.1
12.5°	3947.7	3947.7	3965.3	3918.8	3924.5	3936.1	3959.3	3936.1	3947.7	3976.9
15°	3884.0	3872.4	3901.3	3866.5	3860.8	3849.2	3872.4	3872.4	3884.0	3866.5
17.5°	3808.5	3791.2	3791.2	3779.6	3773.6	3802.8	3814.4	3820.1	3826.0	3802.8
20°	3715.6	3709.9	3727.2	3709.9	3715.6	3721.5	3721.5	3709.9	3762.0	3698.3
22.5°	3616.8	3634.4	3611.1	3599.5	3611.1	3622.7	3622.7	3628.4	3616.8	3605.2
25°	3518.3	3529.9	3535.6	3500.8	3518.3	3500.8	3541.5	3547.2	3524.0	3535.6
27.5°	3431.1	3413.8	3407.9	3384.7	3396.3	3390.6	3396.3	3396.3	3431.1	3384.7
30°	3297.5	3280.2	3285.9	3268.6	3274.3	3268.6	3274.3	3274.3	3297.5	3291.8
32.5°	3169.8	3152.5	3158.2	3140.9	3140.9	3146.6	3135.0	3135.0	3152.5	3140.9
35°	3047.9	3007.3	3013.0	3007.3	3013.0	2989.8	2989.8	2984.1	2995.7	2966.6
37.5°	2873.8	2856.5	2850.5	2844.8	2850.5	2838.9	2850.5	2833.2	2850.5	2827.3
40°	2716.9	2705.3	2711.3	2676.4	2676.4	2682.1	2670.5	2664.8	2670.5	2693.7
42.5°	2560.4	2537.1	2525.5	2513.9	2519.6	2502.3	2496.4	2484.8	2496.4	2473.2
45°	2374.4	2374.4	2368.7	2339.6	2345.5	2345.5	2322.3	2299.1	2304.8	2304.8
47.5°	2206.2	2194.6	2188.7	2159.8	2153.9	2148.2	2124.8	2107.5	2107.5	2089.9
50°	2020.3	2008.7	1991.4	1962.3	1950.7	1915.8	1898.5	1875.3	1852.1	1852.1
52.5°	1846.2	1805.5	1782.2	1735.8	1718.5	1701.0	1654.6	1637.3	1619.7	1602.4
55°	1637.3	1602.4	1556.0	1503.7	1480.5	1451.3	1404.9	1370.1	1346.9	1352.8
57.5°	1434.0	1376.0	1329.6	1259.9	1230.8	1213.3	1166.8	1120.4	1097.2	1097.2
60°	1184.4	1137.9	1079.9	1016.0	992.7	963.8	905.6	876.7	859.1	841.8
62.5°	946.3	911.5	859.1	777.9	760.6	731.5	691.0	656.1	638.6	638.6
65°	708.3	673.4	627.0	569.0	545.8	522.5	487.7	452.9	435.4	429.7
67.5°	499.3	458.6	418.1	371.7	354.1	342.5	307.7	284.5	272.9	267.0
70°	301.8	278.6	249.7	214.8	197.3	185.7	162.5	145.2	139.3	133.6
72.5°	156.8	139.3	116.1	92.9	81.2	69.6	58.0	46.4	40.7	40.7
75°	58.0	46.4	29.1	17.5	11.6	11.6	11.6	11.6	11.6	11.6
77.5°	11.6	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9
80°	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9
82.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)