

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P579711

Luminaire Tested: **HC410D010-HM40525830-41MDW**

Issue Date: 9/9/2021

Test Information

Test Method: LM-41-14
Report Number: P579711
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2106-266-6)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 9/9/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: HALO COMMERCIAL
Catalog Number: HC410D010-HM40525830-41MDW
Description: HALO COMMERCIAL 4" ROUND, NEW CONSTRUCTION FRAME, WITH 4" MEDIUM DISTRIBUTION, WHITE TRIM
Light Source: (1) HIGH LUMEN LED 80CRI / 3000K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1022.8 lumens
Efficiency: N/A
Efficacy: 103.3 lumens/watt
Spacing Criteria (0/90/45): 1.04 / 1.04 / 1.01
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct


Input Watts (W): 9.9
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P579711

CATALOG NUMBER: HC410D010-HM40525830-41MDW

Luminous Intensity Polar Plot





TEST NUMBER: P579711

CATALOG NUMBER: HC410D010-HM40525830-41MDW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100
1	111	108	104	101	109	105	102	100	101	99	97	97	95	94	94	92	91	89			89
2	104	97	92	87	101	95	90	86	92	88	84	89	85	82	86	83	81	79			79
3	97	88	82	76	94	87	81	76	84	79	75	81	77	73	79	75	72	70			70
4	90	80	73	68	88	79	73	67	77	71	67	75	70	66	73	68	65	63			63
5	84	74	66	61	82	73	66	61	71	65	60	69	64	59	67	63	59	57			57
6	79	68	60	55	77	67	60	55	65	59	54	64	58	54	62	57	54	52			52
7	74	63	55	50	73	62	55	50	61	54	50	59	54	49	58	53	49	47			47
8	70	58	51	46	68	58	51	46	56	50	46	55	50	45	54	49	45	44			44
9	66	54	47	42	65	54	47	42	53	46	42	52	46	42	51	46	42	40			40
10	62	51	44	39	61	50	44	39	49	43	39	48	43	39	48	42	39	37			37

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	86724
5°	86263
10°	84680
15°	82901
20°	79348
25°	73778
30°	65303
35°	51543
40°	38563
45°	29672
50°	24063
55°	19978
60°	17663
65°	16344
70°	15075
75°	13821
80°	12644
85°	10048



TEST NUMBER: P579711

CATALOG NUMBER: HC410D010-HM40525830-41MDW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	65.9	6.4
10°-20°	182.1	17.8
20°-30°	247.2	24.2
30°-40°	214.1	20.9
40°-50°	134.4	13.1
50°-60°	84.6	8.3
60°-70°	55.5	5.4
70°-80°	30.6	3.0
80°-90°	8.4	0.8
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	495.1	48.4
0°-40°	709.2	69.3
0°-60°	928.3	90.8
0°-90°	1022.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1022.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	703	
5°	697	66
15°	649	182
25°	542	247
35°	342	214
45°	170	134
55°	93	85
65°	56	56
75°	29	31
85°	7	8
90°	0	



TEST NUMBER: P579711

CATALOG NUMBER: HC410D010-HM40525830-41MDW

CANDELA DISTRIBUTION (FULL):

	0°
0°	703.1
2.5°	698.8
5°	696.7
7.5°	689.6
10°	676.1
12.5°	662.7
15°	649.2
17.5°	630.8
20°	604.5
22.5°	574.8
25°	542.1
27.5°	504.6
30°	458.5
32.5°	402.5
35°	342.3
37.5°	287.0
40°	239.5
42.5°	202.0
45°	170.1
47.5°	146.0
50°	125.4
52.5°	107.8
55°	92.9
57.5°	80.1
60°	71.6
62.5°	63.8
65°	56.0
67.5°	48.1
70°	41.8
72.5°	34.7
75°	29.0
77.5°	22.6
80°	17.8
82.5°	12.1
85°	7.1
87.5°	2.8
90°	0.0



Report Generated By 670245859 / DESKTOP-HRDQ47P





— 0°-180°







(END OF REPORT)