

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P580076

Luminaire Tested: **HC420D010-HM40525935-41WDWB**

Issue Date: 9/9/2021

Test Information

Test Method: LM-41-14
Report Number: P580076
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2106-266-10)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 9/9/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: HALO COMMERCIAL
Catalog Number: HC420D010-HM40525935-41WDWB
Description: HALO COMMERCIAL 4" ROUND, NEW CONSTRUCTION FRAME, WITH 4" WIDE DISTRIBUTION, WHITE BAFFLE TRIM
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1957.2 lumens
Efficiency: N/A
Efficacy: 97.9 lumens/watt
Spacing Criteria (0/90/45): 1.14 / 1.14 / 1.07
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct


Input Watts (W): 20
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P580076

CATALOG NUMBER: HC420D010-HM40525935-41WDWB

Luminous Intensity Polar Plot





TEST NUMBER: P580076

CATALOG NUMBER: HC420D010-HM40525935-41WDWB

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	112	108	105	102	109	106	103	100	102	99	97	98	96	94	94	93	92	90	90	90	90
2	104	98	93	89	102	96	92	88	93	89	86	90	87	84	87	84	82	80	80	80	80
3	98	89	83	78	95	88	82	78	85	80	76	83	78	75	80	77	74	72	72	72	72
4	91	82	75	70	89	81	74	69	78	73	69	76	72	68	74	70	67	65	65	65	65
5	86	75	68	63	84	74	68	63	72	67	62	71	65	61	69	64	61	59	59	59	59
6	80	70	62	57	79	69	62	57	67	61	57	66	60	56	64	59	56	54	54	54	54
7	76	64	57	52	74	64	57	52	62	56	52	61	56	51	60	55	51	49	49	49	49
8	71	60	53	48	70	59	53	48	58	52	48	57	51	47	56	51	47	46	46	46	46
9	67	56	49	44	66	55	49	44	54	48	44	53	48	44	52	47	44	42	42	42	42
10	64	52	46	41	62	52	45	41	51	45	41	50	45	41	49	44	41	39	39	39	39

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	160670
5°	161432
10°	162535
15°	164180
20°	161426
25°	154007
30°	139921
35°	112873
40°	78302
45°	51424
50°	34445
55°	24515
60°	20944
65°	24079
70°	25822
75°	24877
80°	22375
85°	20662



TEST NUMBER: P580076

CATALOG NUMBER: HC420D010-HM40525935-41WDWB

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	124.3	6.3
10°-20°	361.2	18.5
20°-30°	516.0	26.4
30°-40°	461.0	23.6
40°-50°	236.4	12.1
50°-60°	107.5	5.5
60°-70°	80.2	4.1
70°-80°	54.6	2.8
80°-90°	16.2	0.8
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1001.4	51.2
0°-40°	1462.4	74.7
0°-60°	1806.3	92.3
0°-90°	1957.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1957.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1303	
5°	1304	124
15°	1286	361
25°	1132	516
35°	750	461
45°	295	236
55°	114	107
65°	82	80
75°	52	55
85°	15	16
90°	0	



TEST NUMBER: P580076

CATALOG NUMBER: HC420D010-HM40525935-41WDWB

CANDELA DISTRIBUTION (FULL):

0°	
0°	1302.6
2.5°	1297.7
5°	1303.8
7.5°	1303.8
10°	1297.7
12.5°	1291.6
15°	1285.7
17.5°	1267.4
20°	1229.8
22.5°	1183.7
25°	1131.6
27.5°	1066.1
30°	982.4
32.5°	875.7
35°	749.6
37.5°	614.9
40°	486.3
42.5°	379.7
45°	294.8
47.5°	230.4
50°	179.5
52.5°	140.7
55°	114.0
57.5°	95.8
60°	84.9
62.5°	82.5
65°	82.5
67.5°	80.1
70°	71.6
72.5°	61.8
75°	52.2
77.5°	41.3
80°	31.5
82.5°	23.1
85°	14.6
87.5°	6.1
90°	0.0



Report Generated By 670245859 / DESKTOP-HRDQ47P





— 0°-180°







(END OF REPORT)