

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P580206

Luminaire Tested: **HC4R25D010-HM40525930-42RMDC**

Issue Date: 9/23/2021

Test Information

Test Method: LM-41-14
Report Number: P580206
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2106-266-13)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 9/23/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: HALO COMMERCIAL
Catalog Number: HC4R25D010-HM40525930-42RMDC
Description: HALO COMMERCIAL 4" ROUND, RETROFIT FRAME, WITH 4" MEDIUM DISTRIBUTION, SPECULAR TRIM
Light Source: (1) HIGH LUMEN LED 90CRI / 3000K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2179.5 lumens
Efficiency: N/A
Efficacy: 81.3 lumens/watt
Spacing Criteria (0/90/45): 1.02 / 1.02 / 0.96
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct


Input Watts (W): 26.8
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P580206

CATALOG NUMBER: HC4R25D010-HM40525930-42RMDC

Luminous Intensity Polar Plot





TEST NUMBER: P580206

CATALOG NUMBER: HC4R25D010-HM40525930-42RMDC

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

| | | | | | | | | | | | | | | | | | | | | | |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|----|---|
| RF | 20 | | | | 20 | | | | 20 | | | | 20 | | | | 20 | | | | |
| RC | 80 | | | | 70 | | | | 50 | | | | 30 | | | | 10 | | | 0 | |
| RW | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 0 |
| RCR | | | | | | | | | | | | | | | | | | | | | |
| 0 | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 | | | |
| 1 | 113 | 111 | 108 | 106 | 111 | 108 | 106 | 104 | 104 | 103 | 101 | 101 | 99 | 98 | 97 | 96 | 95 | 93 | | | |
| 2 | 108 | 103 | 99 | 95 | 105 | 101 | 97 | 94 | 98 | 95 | 92 | 95 | 92 | 90 | 92 | 90 | 88 | 86 | | | |
| 3 | 102 | 95 | 90 | 86 | 100 | 94 | 89 | 86 | 91 | 87 | 84 | 89 | 86 | 83 | 87 | 84 | 82 | 80 | | | |
| 4 | 97 | 89 | 83 | 79 | 95 | 88 | 82 | 78 | 86 | 81 | 77 | 84 | 80 | 77 | 82 | 78 | 76 | 74 | | | |
| 5 | 92 | 83 | 77 | 73 | 90 | 82 | 76 | 72 | 80 | 75 | 72 | 78 | 74 | 71 | 77 | 73 | 70 | 69 | | | |
| 6 | 87 | 78 | 71 | 67 | 85 | 77 | 71 | 67 | 75 | 70 | 66 | 74 | 69 | 66 | 72 | 68 | 65 | 64 | | | |
| 7 | 82 | 73 | 66 | 62 | 81 | 72 | 66 | 62 | 71 | 65 | 62 | 69 | 65 | 61 | 68 | 64 | 61 | 60 | | | |
| 8 | 78 | 68 | 62 | 58 | 77 | 68 | 62 | 58 | 67 | 61 | 57 | 65 | 61 | 57 | 65 | 60 | 57 | 56 | | | |
| 9 | 74 | 64 | 58 | 54 | 73 | 64 | 58 | 54 | 63 | 57 | 54 | 62 | 57 | 54 | 61 | 57 | 53 | 52 | | | |
| 10 | 70 | 61 | 55 | 51 | 69 | 60 | 54 | 51 | 59 | 54 | 50 | 58 | 54 | 50 | 58 | 53 | 50 | 49 | | | |

AVERAGE LUMINANCE (cd/sqm):

| | 0° |
|-----|--------|
| 0° | 246987 |
| 5° | 252277 |
| 10° | 262233 |
| 15° | 262340 |
| 20° | 242545 |
| 25° | 209603 |
| 30° | 170514 |
| 35° | 125250 |
| 40° | 72409 |
| 45° | 33841 |
| 50° | 15639 |
| 55° | 5441 |
| 60° | 1727 |
| 65° | 1226 |
| 70° | 1010 |
| 75° | 667 |
| 80° | 0 |
| 85° | 0 |



TEST NUMBER: P580206

CATALOG NUMBER: HC4R25D010-HM40525930-42RMDC

ZONAL LUMENS:

| Zone | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10° | 196.6 | 9.0 |
| 10°-20° | 569.4 | 26.1 |
| 20°-30° | 701.2 | 32.2 |
| 30°-40° | 511.9 | 23.5 |
| 40°-50° | 166.9 | 7.7 |
| 50°-60° | 27.9 | 1.3 |
| 60°-70° | 4.3 | 0.2 |
| 70°-80° | 1.5 | 0.1 |
| 80°-90° | 0.0 | 0.0 |
| 90°-100° | 0.0 | 0.0 |
| 100°-110° | 0.0 | 0.0 |
| 110°-120° | 0.0 | 0.0 |
| 120°-130° | 0.0 | 0.0 |
| 130°-140° | 0.0 | 0.0 |
| 140°-150° | 0.0 | 0.0 |
| 150°-160° | 0.0 | 0.0 |
| 160°-170° | 0.0 | 0.0 |
| 170°-180° | 0.0 | 0.0 |
| 0°-30° | 1467.1 | 67.3 |
| 0°-40° | 1979.0 | 90.8 |
| 0°-60° | 2173.7 | 99.7 |
| 0°-90° | 2179.5 | 100.0 |
| 90°-120° | 0.0 | 0.0 |
| 90°-150° | 0.0 | 0.0 |
| 90°-180° | 0.0 | 0.0 |
| 0°-180° | 2179.5 | 100.0 |

CANDELA DISTRIBUTION:

| | 0° | Flux |
|-----|------|------|
| 0° | 2002 | |
| 5° | 2038 | 197 |
| 15° | 2054 | 569 |
| 25° | 1540 | 701 |
| 35° | 832 | 512 |
| 45° | 194 | 167 |
| 55° | 25 | 28 |
| 65° | 4 | 4 |
| 75° | 1 | 1 |
| 85° | 0 | 0 |
| 90° | 0 | |



TEST NUMBER: P580206

CATALOG NUMBER: HC4R25D010-HM40525930-42RMDC

CANDELA DISTRIBUTION (FULL):

| 0° | |
|-------|--------|
| 0° | 2002.4 |
| 2.5° | 2003.7 |
| 5° | 2037.5 |
| 7.5° | 2076.9 |
| 10° | 2093.7 |
| 12.5° | 2088.1 |
| 15° | 2054.4 |
| 17.5° | 1970.1 |
| 20° | 1847.8 |
| 22.5° | 1700.3 |
| 25° | 1540.1 |
| 27.5° | 1372.9 |
| 30° | 1197.2 |
| 32.5° | 1017.3 |
| 35° | 831.8 |
| 37.5° | 645.0 |
| 40° | 449.7 |
| 42.5° | 293.7 |
| 45° | 194.0 |
| 47.5° | 127.9 |
| 50° | 81.5 |
| 52.5° | 47.8 |
| 55° | 25.3 |
| 57.5° | 9.8 |
| 60° | 7.0 |
| 62.5° | 5.6 |
| 65° | 4.2 |
| 67.5° | 2.8 |
| 70° | 2.8 |
| 72.5° | 1.4 |
| 75° | 1.4 |
| 77.5° | 1.4 |
| 80° | 0.0 |
| 82.5° | 0.0 |
| 85° | 0.0 |
| 87.5° | 0.0 |
| 90° | 0.0 |



Report Generated By 670245859 / DESKTOP-HRDQ47P





— 0°-180°







(END OF REPORT)