

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P580291

Luminaire Tested: **HC430D010-HM43040835-41WDBB**

Issue Date: 9/9/2021

Test Information

Test Method: LM-41-14
Report Number: P580291
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2106-266-11)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 9/9/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: HALO COMMERCIAL
Catalog Number: HC430D010-HM43040835-41WDBB
Description: HALO COMMERCIAL 4" ROUND, NEW CONSTRUCTION FRAME, WITH 4" WIDE DISTRIBUTION, BLACK BAFFLE TRIM
Light Source: (1) HIGH LUMEN LED 80CRI / 3500K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2552.1 lumens
Efficiency: N/A
Efficacy: 91.1 lumens/watt
Spacing Criteria (0/90/45): 1.1 / 1.1 / 1.03
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct


Input Watts (W): 28
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P580291

CATALOG NUMBER: HC430D010-HM43040835-41WDBB

Luminous Intensity Polar Plot





TEST NUMBER: P580291

CATALOG NUMBER: HC430D010-HM43040835-41WDBB

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100
1	113	110	107	105	111	108	106	103	104	102	100	100	99	97	97	96	94	93			93
2	107	102	97	94	105	100	96	93	97	93	91	94	91	89	91	89	87	85			85
3	101	94	89	84	99	93	88	84	90	86	82	87	84	81	85	82	80	78			78
4	95	87	81	77	93	86	80	76	84	79	75	82	78	74	80	76	73	72			72
5	90	81	75	70	88	80	74	70	78	73	69	76	72	68	75	71	68	66			66
6	85	75	69	64	83	74	68	64	73	67	63	71	67	63	70	66	62	61			61
7	80	70	64	59	79	69	63	59	68	63	59	67	62	58	66	61	58	56			56
8	76	65	59	55	74	65	59	54	64	58	54	63	58	54	62	57	54	52			52
9	72	61	55	51	71	61	55	51	60	54	50	59	54	50	58	53	50	49			49
10	68	58	51	47	67	57	51	47	56	51	47	55	50	47	55	50	47	45			45

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	254524
5°	254765
10°	255256
15°	258969
20°	252521
25°	236917
30°	209567
35°	159356
40°	100410
45°	57651
50°	30588
55°	12688
60°	3404
65°	2860
70°	2128
75°	1859
80°	1350
85°	2689



TEST NUMBER: P580291

CATALOG NUMBER: HC430D010-HM43040835-41WDBB

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	195.7	7.7
10°-20°	567.9	22.3
20°-30°	792.5	31.1
30°-40°	652.2	25.6
40°-50°	268.7	10.5
50°-60°	60.6	2.4
60°-70°	9.7	0.4
70°-80°	3.6	0.1
80°-90°	1.3	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1556.1	61.0
0°-40°	2208.3	86.5
0°-60°	2537.5	99.4
0°-90°	2552.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2552.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2064	
5°	2058	196
15°	2028	568
25°	1741	793
35°	1058	652
45°	330	269
55°	59	61
65°	10	10
75°	4	4
85°	2	1
90°	0	



TEST NUMBER: P580291

CATALOG NUMBER: HC430D010-HM43040835-41WDBB

CANDELA DISTRIBUTION (FULL):

0°	
0°	2063.5
2.5°	2053.6
5°	2057.6
7.5°	2049.7
10°	2038.0
12.5°	2032.0
15°	2028.0
17.5°	1992.7
20°	1923.8
22.5°	1837.3
25°	1740.8
27.5°	1624.9
30°	1471.4
32.5°	1282.5
35°	1058.3
37.5°	832.1
40°	623.6
42.5°	454.4
45°	330.5
47.5°	236.1
50°	159.4
52.5°	100.3
55°	59.0
57.5°	29.6
60°	13.8
62.5°	11.8
65°	9.8
67.5°	7.9
70°	5.9
72.5°	3.9
75°	3.9
77.5°	1.9
80°	1.9
82.5°	1.9
85°	1.9
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-HRDQ47P





— 0°-180°







(END OF REPORT)