

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P581071

Luminaire Tested: **HC405D010-HM40525930-41MDC**

Issue Date: 9/9/2021

**Test Information**

Test Method: LM-41-14  
Report Number: P581071  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2106-266-4)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 9/9/2021  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: HALO COMMERCIAL  
Catalog Number: HC405D010-HM40525930-41MDC  
Description: HALO COMMERCIAL 4" ROUND, NEW CONSTRUCTION FRAME, WITH 4" MEDIUM DISTRIBUTION, SPECULAR TRIM  
Light Source: (1) HIGH LUMEN LED 90CRI / 3000K CCT  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 586.7 lumens  
Efficiency: N/A  
Efficacy: 97.8 lumens/watt  
Spacing Criteria (0/90/45): 1 / 1 / 0.96  
Luminous Opening: Circular (Dia: 0.33' x H: 0')  
CIE Type: Direct


Input Watts (W): 6  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P581071

CATALOG NUMBER: HC405D010-HM40525930-41MDC

### Luminous Intensity Polar Plot





TEST NUMBER: P581071

CATALOG NUMBER: HC405D010-HM40525930-41MDC

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20			
RC	80				70				50				30				10		0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	113	111	108	106	111	108	106	104	104	103	101	101	99	98	97	96	95	93		
2	108	103	99	95	105	101	97	94	98	95	92	95	92	90	92	90	88	86		
3	102	95	90	86	100	94	89	86	91	87	84	89	86	83	87	84	82	80		
4	97	89	83	79	95	88	82	78	86	81	77	84	80	77	82	78	76	74		
5	91	83	77	72	90	82	76	72	80	75	72	78	74	71	77	73	70	69		
6	87	78	71	67	85	77	71	67	75	70	66	74	69	66	72	68	65	64		
7	82	73	66	62	81	72	66	62	71	65	62	69	65	61	68	64	61	60		
8	78	68	62	58	77	68	62	58	67	61	57	65	61	57	65	60	57	56		
9	74	64	58	54	73	64	58	54	63	57	54	62	57	54	61	57	53	52		
10	71	61	55	51	69	60	54	51	59	54	50	58	54	50	58	53	50	49		

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	67951
5°	69214
10°	71329
15°	70552
20°	64778
25°	55881
30°	45534
35°	33714
40°	19354
45°	9350
50°	4452
55°	1570
60°	567
65°	321
70°	289
75°	143
80°	0
85°	0



TEST NUMBER: P581071

CATALOG NUMBER: HC405D010-HM40525930-41MDC

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	53.8	9.2
10°-20°	153.2	26.1
20°-30°	187.0	31.9
30°-40°	137.5	23.4
40°-50°	45.6	7.8
50°-60°	8.1	1.4
60°-70°	1.2	0.2
70°-80°	0.3	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	393.9	67.1
0°-40°	531.4	90.6
0°-60°	585.1	99.7
0°-90°	586.7	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	586.7	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	551	
5°	559	54
15°	552	153
25°	411	187
35°	224	137
45°	54	46
55°	7	8
65°	1	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P581071

CATALOG NUMBER: HC405D010-HM40525930-41MDC

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	550.9
2.5°	551.4
5°	559.0
7.5°	567.3
10°	569.5
12.5°	564.3
15°	552.5
17.5°	528.1
20°	493.5
22.5°	453.2
25°	410.6
27.5°	366.2
30°	319.7
32.5°	273.4
35°	223.9
37.5°	173.8
40°	120.2
42.5°	79.4
45°	53.6
47.5°	35.8
50°	23.2
52.5°	13.7
55°	7.3
57.5°	3.1
60°	2.3
62.5°	1.5
65°	1.1
67.5°	0.8
70°	0.8
72.5°	0.3
75°	0.3
77.5°	0.3
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-HRDQ47P







— 0°-180°







(END OF REPORT)