

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P581216

Luminaire Tested: **HC455D010-HM44560930-41NDC**

Issue Date: 9/9/2021

Test Information

Test Method: LM-41-14
Report Number: P581216
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2106-266-1)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 9/9/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: HALO COMMERCIAL
Catalog Number: HC455D010-HM44560930-41NDC
Description: HALO COMMERCIAL 4" ROUND, NEW CONSTRUCTION FRAME, WITH 4" NARROW DISTRIBUTION, SPECULAR TRIM
Light Source: (1) HIGH LUMEN LED 90CRI / 3000K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4113.6 lumens
Efficiency: N/A
Efficacy: 79.1 lumens/watt
Spacing Criteria (0/90/45): 0.84 / 0.84 / 0.85
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct


Input Watts (W): 52
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P581216

CATALOG NUMBER: HC455D010-HM44560930-41NDC

Luminous Intensity Polar Plot





TEST NUMBER: P581216

CATALOG NUMBER: HC455D010-HM44560930-41NDC

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	114	111	108	106	111	109	106	104	105	103	101	101	100	98	97	96	95	94			
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	93	91	89	87			
3	103	96	91	87	101	95	90	87	92	88	85	90	87	84	88	85	83	81			
4	97	90	85	80	96	89	84	80	87	82	79	85	81	78	83	80	77	76			
5	93	84	79	74	91	83	78	74	82	77	73	80	76	73	78	75	72	71			
6	88	79	73	69	87	78	73	69	77	72	68	75	71	68	74	70	67	66			
7	84	75	69	64	82	74	68	64	73	68	64	71	67	64	70	66	63	62			
8	80	70	64	60	78	70	64	60	69	64	60	68	63	60	67	62	59	58			
9	76	66	61	57	75	66	60	57	65	60	56	64	59	56	63	59	56	55			
10	72	63	57	53	71	62	57	53	62	57	53	61	56	53	60	56	53	51			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	605898
5°	605117
10°	593327
15°	551688
20°	474458
25°	381153
30°	297588
35°	208339
40°	106931
45°	54285
50°	27210
55°	10150
60°	4120
65°	3240
70°	1984
75°	1334
80°	1989
85°	0



TEST NUMBER: P581216

CATALOG NUMBER: HC455D010-HM44560930-41NDC

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	462.1	11.2
10°-20°	1192.6	29.0
20°-30°	1284.8	31.2
30°-40°	844.1	20.5
40°-50°	262.5	6.4
50°-60°	51.5	1.3
60°-70°	10.9	0.3
70°-80°	4.0	0.1
80°-90°	1.1	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2939.4	71.5
0°-40°	3783.5	92.0
0°-60°	4097.5	99.6
0°-90°	4113.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4113.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	4912	
5°	4887	462
15°	4320	1193
25°	2801	1285
35°	1384	844
45°	311	262
55°	47	52
65°	11	11
75°	3	4
85°	0	1
90°	0	



TEST NUMBER: P581216

CATALOG NUMBER: HC455D010-HM44560930-41NDC

CANDELA DISTRIBUTION (FULL):

0°	
0°	4912.2
2.5°	4887.2
5°	4887.2
7.5°	4848.3
10°	4737.2
12.5°	4559.3
15°	4320.3
17.5°	4000.8
20°	3614.6
22.5°	3197.9
25°	2800.6
27.5°	2431.1
30°	2089.4
32.5°	1767.0
35°	1383.6
37.5°	964.1
40°	664.1
42.5°	458.4
45°	311.2
47.5°	211.2
50°	141.8
52.5°	88.9
55°	47.2
57.5°	19.5
60°	16.7
62.5°	13.8
65°	11.1
67.5°	8.3
70°	5.5
72.5°	5.5
75°	2.8
77.5°	2.8
80°	2.8
82.5°	2.8
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-HRDQ47P





— 0°-180°







(END OF REPORT)