

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P582190

Luminaire Tested: **HC630D010-HM63040840-61WDBB**

Issue Date: 9/16/2021

**Test Information**

Test Method: LM-41-14  
Report Number: P582190  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2105-241-11)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 9/16/2021  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: HALO COMMERCIAL  
Catalog Number: HC630D010-HM63040840-61WDBB  
Description: HALO COMMERCIAL 6" ROUND, NEW CONSTRUCTION FRAME, WITH 6" WIDE DISTRIBUTION, BLACK BAFFLE TRIM  
Light Source: (1) HIGH LUMEN LED 80CRI / 4000K CCT  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 3161.0 lumens  
Efficiency: N/A  
Efficacy: 112.9 lumens/watt  
Spacing Criteria (0/90/45): 1.32 / 1.32 / 1.14  
Luminous Opening: Circular (Dia: 0.5' x H: 0')  
CIE Type: Direct


Input Watts (W): 28  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P582190

CATALOG NUMBER: HC630D010-HM63040840-61WDBB

### Luminous Intensity Polar Plot





TEST NUMBER: P582190

CATALOG NUMBER: HC630D010-HM63040840-61WDBB

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	113	110	107	105	110	108	105	103	104	102	100	100	98	97	97	95	94	92	92	92	92
2	107	101	97	93	104	100	95	92	96	93	90	93	91	88	90	88	86	85	85	85	85
3	100	93	88	83	98	92	87	83	89	85	81	87	83	80	84	81	79	77	77	77	77
4	95	86	80	75	93	85	79	75	83	78	74	81	77	73	79	75	72	71	71	71	71
5	89	80	73	68	87	79	73	68	77	72	67	75	70	67	73	69	66	65	65	65	65
6	84	74	67	62	82	73	67	62	71	66	62	70	65	61	69	64	61	59	59	59	59
7	79	68	62	57	77	68	61	57	66	61	57	65	60	56	64	59	56	54	54	54	54
8	74	64	57	52	73	63	57	52	62	56	52	61	56	52	60	55	52	50	50	50	50
9	70	59	53	48	69	59	53	48	58	52	48	57	52	48	56	51	48	46	46	46	46
10	66	56	49	45	65	55	49	45	54	48	45	53	48	44	53	48	44	43	43	43	43

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	112261
5°	113091
10°	115061
15°	119620
20°	124634
25°	129080
30°	127355
35°	106107
40°	68042
45°	33980
50°	13484
55°	4578
60°	1316
65°	921
70°	769
75°	1017
80°	758
85°	0



TEST NUMBER: P582190

CATALOG NUMBER: HC630D010-HM63040840-61WDBB

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	196.5	6.2
10°-20°	597.8	18.9
20°-30°	976.1	30.9
30°-40°	956.8	30.3
40°-50°	366.9	11.6
50°-60°	53.8	1.7
60°-70°	8.0	0.3
70°-80°	4.1	0.1
80°-90°	1.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1770.4	56.0
0°-40°	2727.2	86.3
0°-60°	3147.9	99.6
0°-90°	3161.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3161.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	2048	
5°	2055	197
15°	2108	598
25°	2134	976
35°	1586	957
45°	438	367
55°	48	54
65°	7	8
75°	5	4
85°	0	1
90°	0	



TEST NUMBER: P582190

CATALOG NUMBER: HC630D010-HM63040840-61WDBB

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	2047.8
2.5°	2043.1
5°	2055.1
7.5°	2062.2
10°	2067.0
12.5°	2083.7
15°	2107.7
17.5°	2126.9
20°	2136.4
22.5°	2138.9
25°	2134.0
27.5°	2100.5
30°	2011.9
32.5°	1844.3
35°	1585.5
37.5°	1267.0
40°	950.8
42.5°	677.8
45°	438.3
47.5°	268.2
50°	158.1
52.5°	91.0
55°	47.9
57.5°	21.5
60°	12.0
62.5°	9.6
65°	7.1
67.5°	7.1
70°	4.8
72.5°	4.8
75°	4.8
77.5°	2.4
80°	2.4
82.5°	2.4
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-HRDQ47P







— 0°-180°







(END OF REPORT)