

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P582714

Luminaire Tested: **HC650D010-HM64560827-61WDH**

Issue Date: 9/16/2021

Test Information

Test Method: LM-41-14
Report Number: P582714
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2105-241-8)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 9/16/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: HALO COMMERCIAL
Catalog Number: HC650D010-HM64560827-61WDH
Description: HALO COMMERCIAL 6" ROUND, NEW CONSTRUCTION FRAME, WITH 6" WIDE DISTRIBUTION, HAZE TRIM
Light Source: (1) HIGH LUMEN LED 80CRI / 2700K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4775.7 lumens
Efficiency: N/A
Efficacy: 99.5 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.18 / 1.08
Luminous Opening: Circular (Dia: 0.5' x H: 0')
CIE Type: Direct


Input Watts (W): 48
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P582714

CATALOG NUMBER: HC650D010-HM64560827-61WDH

Luminous Intensity Polar Plot





TEST NUMBER: P582714

CATALOG NUMBER: HC650D010-HM64560827-61WDH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	113	110	107	105	110	108	105	103	103	101	100	100	98	97	96	95	94	92	92	92	92
2	106	101	96	93	104	99	95	92	96	92	90	93	90	88	90	88	86	84	84	84	84
3	100	93	87	83	98	91	86	82	89	84	81	86	83	80	84	81	78	77	77	77	77
4	94	86	79	75	92	85	79	74	82	77	73	80	76	72	78	75	72	70	70	70	70
5	89	79	73	68	87	78	72	68	76	71	67	75	70	66	73	69	66	64	64	64	64
6	83	73	67	62	82	73	66	62	71	65	61	70	65	61	68	64	60	59	59	59	59
7	79	68	62	57	77	68	61	57	66	60	56	65	60	56	64	59	56	54	54	54	54
8	74	64	57	52	73	63	57	52	62	56	52	61	56	52	60	55	51	50	50	50	50
9	70	59	53	48	69	59	53	48	58	52	48	57	52	48	56	51	48	46	46	46	46
10	66	56	49	45	65	55	49	45	54	49	45	53	48	45	53	48	44	43	43	43	43

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	187035
5°	188284
10°	190461
15°	194365
20°	195457
25°	189368
30°	171792
35°	139682
40°	92717
45°	51602
50°	28929
55°	16066
60°	8859
65°	6706
70°	4664
75°	3431
80°	2052
85°	2013



TEST NUMBER: P582714

CATALOG NUMBER: HC650D010-HM64560827-61WDH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	326.6	6.8
10°-20°	965.6	20.2
20°-30°	1423.3	29.8
30°-40°	1273.0	26.7
40°-50°	552.3	11.6
50°-60°	162.3	3.4
60°-70°	51.8	1.1
70°-80°	18.3	0.4
80°-90°	2.6	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2715.5	56.9
0°-40°	3988.5	83.5
0°-60°	4703.0	98.5
0°-90°	4775.7	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4775.7	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3412	
5°	3422	327
15°	3425	966
25°	3131	1423
35°	2087	1273
45°	666	552
55°	168	162
65°	52	52
75°	16	18
85°	3	3
90°	0	



TEST NUMBER: P582714

CATALOG NUMBER: HC650D010-HM64560827-61WDH

CANDELA DISTRIBUTION (FULL):

0°	
0°	3411.8
2.5°	3402.1
5°	3421.5
7.5°	3428.0
10°	3421.5
12.5°	3421.5
15°	3424.7
17.5°	3405.3
20°	3350.4
22.5°	3256.7
25°	3130.7
27.5°	2953.0
30°	2713.9
32.5°	2429.6
35°	2087.2
37.5°	1696.2
40°	1295.6
42.5°	946.7
45°	665.6
47.5°	474.9
50°	339.2
52.5°	242.3
55°	168.1
57.5°	113.0
60°	80.8
62.5°	64.6
65°	51.7
67.5°	38.7
70°	29.1
72.5°	22.6
75°	16.2
77.5°	12.9
80°	6.5
82.5°	3.2
85°	3.2
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-HRDQ47P





— 0°-180°







(END OF REPORT)