

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P583072

Luminaire Tested: **HC655D010-HM64560927-61WDBB**

Issue Date: 9/16/2021

Test Information

Test Method: LM-41-14
Report Number: P583072
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2105-241-11)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 9/16/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: HALO COMMERCIAL
Catalog Number: HC655D010-HM64560927-61WDBB
Description: HALO COMMERCIAL 6" ROUND, NEW CONSTRUCTION FRAME, WITH 6" WIDE DISTRIBUTION, BLACK BAFFLE TRIM
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3712.2 lumens
Efficiency: N/A
Efficacy: 71.4 lumens/watt
Spacing Criteria (0/90/45): 1.32 / 1.32 / 1.14
Luminous Opening: Circular (Dia: 0.5' x H: 0')
CIE Type: Direct


Input Watts (W): 52
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P583072

CATALOG NUMBER: HC655D010-HM64560927-61WDBB

Luminous Intensity Polar Plot





TEST NUMBER: P583072

CATALOG NUMBER: HC655D010-HM64560927-61WDBB

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100
1	113	110	107	105	110	108	105	103	104	102	100	100	98	97	97	95	94	92			92
2	107	101	97	93	104	100	95	92	96	93	90	93	91	88	90	88	86	85			85
3	100	93	88	83	98	92	87	83	89	85	81	87	83	80	84	81	79	77			77
4	95	86	80	75	93	85	79	75	83	78	74	81	77	73	79	75	72	71			71
5	89	80	73	68	87	79	73	68	77	72	67	75	70	67	73	69	66	65			65
6	84	74	67	62	82	73	67	62	71	66	62	70	65	61	69	64	61	59			59
7	79	68	62	57	77	68	61	57	66	61	57	65	60	56	64	59	56	54			54
8	74	64	57	52	73	63	57	52	62	56	52	61	56	52	60	55	52	50			50
9	70	59	53	48	69	59	53	48	58	52	48	57	52	48	56	51	48	46			46
10	66	56	49	45	65	55	49	45	54	48	45	53	48	44	53	48	44	43			43

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	131837
5°	132803
10°	135123
15°	140478
20°	146371
25°	151593
30°	149561
35°	124611
40°	79907
45°	39903
50°	15829
55°	5381
60°	1546
65°	1090
70°	914
75°	1207
80°	884
85°	0



TEST NUMBER: P583072

CATALOG NUMBER: HC655D010-HM64560927-61WDBB

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	230.8	6.2
10°-20°	702.0	18.9
20°-30°	1146.3	30.9
30°-40°	1123.7	30.3
40°-50°	430.8	11.6
50°-60°	63.2	1.7
60°-70°	9.4	0.3
70°-80°	4.9	0.1
80°-90°	1.1	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2079.1	56.0
0°-40°	3202.8	86.3
0°-60°	3696.9	99.6
0°-90°	3712.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3712.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2405	
5°	2413	231
15°	2475	702
25°	2506	1146
35°	1862	1124
45°	515	431
55°	56	63
65°	8	9
75°	6	5
85°	0	1
90°	0	



TEST NUMBER: P583072

CATALOG NUMBER: HC655D010-HM64560927-61WDBB

CANDELA DISTRIBUTION (FULL):

0°	
0°	2404.9
2.5°	2399.4
5°	2413.3
7.5°	2421.8
10°	2427.4
12.5°	2447.2
15°	2475.2
17.5°	2497.8
20°	2509.0
22.5°	2511.9
25°	2506.2
27.5°	2466.8
30°	2362.7
32.5°	2165.8
35°	1862.0
37.5°	1488.0
40°	1116.6
42.5°	796.0
45°	514.7
47.5°	315.0
50°	185.6
52.5°	106.9
55°	56.3
57.5°	25.3
60°	14.1
62.5°	11.2
65°	8.4
67.5°	8.4
70°	5.7
72.5°	5.7
75°	5.7
77.5°	2.8
80°	2.8
82.5°	2.8
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-HRDQ47P





— 0°-180°







(END OF REPORT)