

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P583102

Luminaire Tested: **HC655D010-HM64560935-61NDC**

Issue Date: 9/16/2021

Test Information

Test Method: LM-41-14
Report Number: P583102
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2105-241-1)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 9/16/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: HALO COMMERCIAL
Catalog Number: HC655D010-HM64560935-61NDC
Description: HALO COMMERCIAL 6" ROUND, NEW CONSTRUCTION FRAME, WITH 6" NARROW DISTRIBUTION, SPECULAR TRIM
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 5177.1 lumens
Efficiency: N/A
Efficacy: 99.6 lumens/watt
Spacing Criteria (0/90/45): 0.93 / 0.93 / 0.88
Luminous Opening: Circular (Dia: 0.5' x H: 0')
CIE Type: Direct


Input Watts (W): 52
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P583102

CATALOG NUMBER: HC655D010-HM64560935-61NDC

Luminous Intensity Polar Plot





TEST NUMBER: P583102

CATALOG NUMBER: HC655D010-HM64560935-61NDC

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	114	111	108	106	111	109	107	105	105	103	101	101	100	98	98	97	96	94			
2	108	103	99	96	106	102	98	95	98	96	93	96	93	91	93	91	89	87			
3	103	97	92	88	101	95	91	87	93	89	86	90	87	84	88	85	83	82			
4	98	90	85	81	96	89	84	80	87	83	79	85	81	79	83	80	78	76			
5	93	85	79	75	91	84	79	75	82	77	74	80	76	73	79	75	73	71			
6	88	80	74	70	87	79	73	69	77	73	69	76	72	68	75	71	68	67			
7	84	75	69	65	83	74	69	65	73	68	64	72	67	64	71	67	64	62			
8	80	71	65	61	79	70	65	61	69	64	60	68	64	60	67	63	60	59			
9	76	67	61	57	75	66	61	57	65	60	57	65	60	57	64	60	56	55			
10	73	63	58	54	72	63	57	54	62	57	54	61	57	53	61	56	53	52			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	309186
5°	309805
10°	314902
15°	317198
20°	289959
25°	227844
30°	166779
35°	118307
40°	55962
45°	21351
50°	9560
55°	2600
60°	1118
65°	869
70°	545
75°	720
80°	0
85°	0



TEST NUMBER: P583102

CATALOG NUMBER: HC655D010-HM64560935-61NDC

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	538.6	10.4
10°-20°	1544.8	29.8
20°-30°	1718.3	33.2
30°-40°	1073.4	20.7
40°-50°	255.0	4.9
50°-60°	36.5	0.7
60°-70°	7.5	0.1
70°-80°	3.1	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3801.6	73.4
0°-40°	4875.0	94.2
0°-60°	5166.5	99.8
0°-90°	5177.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5177.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	5640	
5°	5630	539
15°	5589	1545
25°	3767	1718
35°	1768	1073
45°	275	255
55°	27	36
65°	7	8
75°	3	3
85°	0	0
90°	0	



TEST NUMBER: P583102

CATALOG NUMBER: HC655D010-HM64560935-61NDC

CANDELA DISTRIBUTION (FULL):

0°	
0°	5640.0
2.5°	5616.2
5°	5629.8
7.5°	5650.1
10°	5657.0
12.5°	5653.6
15°	5589.0
17.5°	5371.4
20°	4970.3
22.5°	4406.0
25°	3766.8
27.5°	3154.8
30°	2634.7
32.5°	2203.0
35°	1767.8
37.5°	1298.7
40°	782.0
42.5°	452.1
45°	275.4
47.5°	176.7
50°	112.1
52.5°	64.6
55°	27.2
57.5°	13.6
60°	10.2
62.5°	10.2
65°	6.7
67.5°	6.7
70°	3.4
72.5°	3.4
75°	3.4
77.5°	3.4
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-HRDQ47P





— 0°-180°







(END OF REPORT)