

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P584134

Luminaire Tested: **HC825D010-HM82555835-81MDH**

Issue Date: 10/21/2021

Test Information

Test Method: LM-41-14
Report Number: P584134
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2109-368-5)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 10/21/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: HALO COMMERCIAL
Catalog Number: HC825D010-HM82555835-81MDH
Description: HALO COMMERCIAL 8" ROUND, NEW CONSTRUCTION FRAME, WITH 8" MEDIUM DISTRIBUTION, HAZE TRIM
Light Source: (1) HIGH LUMEN LED 80CRI / 3500K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2524.6 lumens
Efficiency: N/A
Efficacy: 94.2 lumens/watt
Spacing Criteria (0/90/45): 0.68 / 0.68 / 0.81
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct


Input Watts (W): 26.8
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P584134

CATALOG NUMBER: HC825D010-HM82555835-81MDH

Luminous Intensity Polar Plot





TEST NUMBER: P584134

CATALOG NUMBER: HC825D010-HM82555835-81MDH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94			
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	90	89	87			
3	103	96	91	87	101	95	90	87	92	88	85	90	87	84	88	85	83	81			
4	97	90	85	80	96	89	84	80	87	82	79	85	81	78	83	80	77	76			
5	93	84	79	74	91	83	78	74	82	77	73	80	76	73	78	75	72	71			
6	88	79	73	69	87	78	73	69	77	72	68	76	71	68	74	70	67	66			
7	84	75	69	64	82	74	68	64	73	68	64	71	67	64	70	66	63	62			
8	80	70	64	60	79	70	64	60	69	64	60	68	63	60	67	63	60	58			
9	76	67	61	57	75	66	61	57	65	60	56	64	60	56	63	59	56	55			
10	73	63	57	54	72	63	57	53	62	57	53	61	56	53	60	56	53	52			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	115460
5°	105216
10°	89894
15°	78393
20°	69874
25°	61982
30°	50747
35°	29140
40°	12934
45°	7527
50°	4342
55°	2478
60°	1375
65°	876
70°	613
75°	405
80°	302
85°	601



TEST NUMBER: P584134

CATALOG NUMBER: HC825D010-HM82555835-81MDH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	307.7	12.2
10°-20°	690.3	27.3
20°-30°	826.3	32.7
30°-40°	499.9	19.8
40°-50°	140.1	5.5
50°-60°	43.5	1.7
60°-70°	12.5	0.5
70°-80°	3.4	0.1
80°-90°	1.2	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1824.2	72.3
0°-40°	2324.1	92.1
0°-60°	2507.6	99.3
0°-90°	2524.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2524.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3744	
5°	3399	308
15°	2456	690
25°	1822	826
35°	774	500
45°	173	140
55°	46	43
65°	12	12
75°	3	3
85°	2	1
90°	0	



TEST NUMBER: P584134

CATALOG NUMBER: HC825D010-HM82555835-81MDH

CANDELA DISTRIBUTION (FULL):

	0°
0°	3744.3
2.5°	3638.2
5°	3399.1
7.5°	3129.0
10°	2870.9
12.5°	2645.4
15°	2455.6
17.5°	2288.2
20°	2129.3
22.5°	1982.3
25°	1821.7
27.5°	1640.5
30°	1425.2
32.5°	1146.7
35°	774.1
37.5°	481.9
40°	321.3
42.5°	230.7
45°	172.6
47.5°	126.5
50°	90.5
52.5°	63.2
55°	46.1
57.5°	30.7
60°	22.3
62.5°	15.4
65°	12.0
67.5°	8.6
70°	6.8
72.5°	3.4
75°	3.4
77.5°	1.7
80°	1.7
82.5°	1.7
85°	1.7
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-HRDQ47P





— 0°-180°







(END OF REPORT)